



Commonwealth Edison
LaSalle County Nuclear Station
2601 N. 21st. R.
Marseilles, Illinois 61341
Telephone 815/357-6761

June 8, 1992


Mr. A. B. Davis
Region III Administrator
U.S. Nuclear Regulatory Commission
799 Roosevelt Road
Glen Ellyn, Illinois 60137

Dear Sir:

This Special Report is submitted in accordance with LaSalle Unit 1 Operating License, NPF-11, Appendix A, Technical Specification 3.7.5.3. On May 8, 1992 the 'O' Diesel Generator CO2 System exceeded its 14 day time clock because of the replacement of the CO2 Control Panel which makes the CO2 System inoperable.

In accordance with the Action Statement of Technical Specification 3.7.5.3 an hourly fire watch was established to inspect the generator room during the time period that the CO2 system is inoperable.

A Special Report is required because the CO2 System inoperability exceeded the allowable 14 day time clock. The CO2 System will be returned to service upon completion of the modification.


G. J. Diederich
for Station Manager
LaSalle County Station

GJD/JB/mkl

cc: Nuclear Licensing Administrator
NRC Resident Inspector
NRC Document Control Desk
INPO Records Center
IDMS Resident Inspector

9206150345 920608
PDR ADDCK 03000373
S PDR

JE22 1/0