

February 12, 1996

MEMORANDUM TO: Dennis M. Crutchfield, Director
 Division of Reactor Program Management

FROM: Alfred E. Chaffee, Chief [Original signed by]
 Events Assessment and
 Generic Communications Branch
 Division of Reactor Program Management

SUBJECT: OPERATING REACTORS EVENTS BRIEFING
 FEBRUARY 7, 1996 - BRIEFING 96-02

On February 7, 1996, we conducted an Operating Reactors Events Briefing (96-02) to inform senior managers from offices of the Chairman, ACRS, AEOD, RES, WCFO, NRR and regional offices of selected events that occurred since our last briefing on January 31, 1996. Attachment 1 lists the attendees. Attachment 2 presents the significant elements of the discussed events.

Attachment 3 contains reactor scram statistics for week ending February 4, 1996. No significant events were identified for input into the NRC Performance Indicator Program.

Attachments: As stated (3)

cc w/atts:
 See next page

CONTACT: Kathy Gray, NRR
 (301) 415-1166

DISTRIBUTION: (w/atts)

Central Files
 PUBLIC
 LKilgore, SECY
 PECB R/F

NRC FILE CENTER COPY

DOCUMENT NAME: G:\KAG\ORTRANS

To receive a copy of this document, indicate in the box: "C" = Copy without attachment/enclosure "E" = Copy with attachment/enclosure "N" = No copy

OFFICE	PECB	E	PECB	E	PECB	C/PECB	N
	<i>KGray</i>						
NAME	KGray:vst		TKoshy <i>JK</i>		EGoodwin <i>F</i>	ACHaffee	
DATE	2/08/96		2/8/96		2/9/96 <i>JK</i>	2/12/96	

OFFICIAL RECORD COPY

*OPERATING
 IDAR-5-1-Expanding
 OPM-6-Meeting*

*OF03
 11*

9602200119 960212
 PDR ORG NRR
 PDR

CC:

W. Russell, NRR (O-12G18)
F. Miraglia, NRR (O-12G18)
F. Gillespie, NRR (O-12G18)
R. Zimmerman, NRR (O-12G18)
A. Thadani, NRR (O-12G18)
S. Varga, NRR (O-14E4)
J. Zwolinski, NRR (O-14H3)
J. Roe, NRR (O-13E4)
E. Adensam, NRR (O-13E4)
B. Sheron, NRR (O-7D26)
G. Lainas, NRR (O-7D26)
G. Holahan, NRR (O-8E2)
M. Virgilio, NRR (O-8E2)
S. Rosenberg, NRR (O-10E4)
R. L. Spessard, NRR (O-9A2)
B. Boger, NRR (O-10H5)
M. Markley, ACRS (T-2E26)
E. Jordan, AEOD (T-4D18)
C. Rossi, AEOD (T-4A9)
F. Congel, AEOD (T-4D28)
K. Brockman, AEOD (T-4A23)
S. Rubin, AEOD (T-4D28)
M. Harper, AEOD (T-4A9)
V. McCree, EDO (O-17G21)
J. Gilliland, PA (O-2G4)
D. Morrison, RES (T-10F12)
W. Hill, SECY (O-16G15)
T. Martin, Region I
R. Cooper, Region I
S. Ebnetter, Region II
E. Merschhoff, Region II
S. Vias, Region II
H. Miller, Region III
W. Axelson, Region III
L. Callan, Region IV
J. Dyer, Region IV
K. Perkins, Region IV/WCFO
S. Newton, INPO
J. Zimmer, DOE

J. Stone (O-13E16)
K. Thomas (O-13E16)
W. Bateman (O-13E16)

LIST OF ATTENDEES

OPERATING REACTORS EVENTS FULL BRIEFING (96-02)

FEBRUARY 7, 1996

<u>NAME</u>	<u>OFFICE</u>	<u>NAME</u>	<u>OFFICE</u>
A. CHAFFEE	NRR	S. LEE	NRR
D. SKEEN	NRR	D. JACKSON	NRR
T. KOSHY	NRR	K. THOMAS	NRR
K. GRAY	NRR	G. WEST	NRR
E. BENNER	NRR	W. LYON	NRR
N. HUNEMULLER	NRR	M. MARKLEY	ACRS
E. GOODWIN	NRR	J. ROSENTHAL	AEOD
D. O'NEAL	NRR	H. SCOTT	RES
B. GRIMES	NRR	K. PERKINS	RIV/WCFO
R. JONES	NRR	D. LEW	CHRMAN/TA

TELEPHONE ATTENDANCE
(AT ROLL CALL)

Regions

Region I
Region II
Region III
Region IV

Resident Inspectors

F. Ringwald, Wolf Creek

Misc.

OPERATING REACTORS EVENTS BRIEFING 96-02

**LOCATION: 0-10 B11, WHITE FLINT
WEDNESDAY, FEBRUARY 7, 1996, 11:00 A.M.**

WOLF CREEK, UNIT 1

**PLANT TRIP WITH MULTIPLE
COMPLICATIONS (AIT)**

PRESENTED BY:

**EVENTS ASSESSMENT AND GENERIC COMMUNICATIONS BRANCH
DIVISION OF REACTOR PROGRAM MANAGEMENT, NRR**

WOLF CREEK, UNIT 1
PLANT TRIP WITH MULTIPLE COMPLICATIONS
JANUARY 30, 1996

PROBLEMS

MANUAL REACTOR TRIP FROM ICE BUILD UP CAUSING LOW LEVEL FOR CIRCULATING WATER PUMPS AND CAVITATION AT LOW FLOW SERVICE WATER PUMP. INITIALLY, FIVE CONTROL RODS FAILED TO INSERT COMPLETELY. ONE TRAIN OF EMERGENCY SERVICE WATER TRIPPED DUE TO ICING. STEAM DRIVEN EMERGENCY FEEDWATER PUMP DEVELOPED LEAK.

CAUSE

- CAUSE OF CONTROL ROD FAILURE TO INSERT IS UNKNOWN.
- ICE BUILD UP AT NORMAL AND EMERGENCY SERVICE WATER INTAKE STRUCTURE.

SAFETY SIGNIFICANCE

- REDUCTION OF SHUTDOWN MARGIN.
- POTENTIAL LOSS OF ULTIMATE HEAT SINK.

BACKGROUND

- CIRCULATING AND NON-ESSENTIAL SERVICE WATER SYSTEMS SHARE SAME PUMP HOUSE.

CONTACT: THOMAS KOSHY, NRR/DRPM/PECB
REFERENCE: 10 CFR 50.72 #29904
PN 4-96-005

AIT: YES
SIGEVENT: TBD

- TWO TRAINS OF EMERGENCY SERVICE WATER (ESW) SHARE ONE PUMP HOUSE. WHEN SERVICE WATER UNAVAILABLE, ESW PROVIDES COOLING FOR EMERGENCY DIESEL GENERATORS AND OTHER SAFEGUARD HEAT LOADS.

DISCUSSION

- DUE TO DECREASING WATER LEVEL IN SERVICE WATER PUMP BAY, "A" TRAIN OF EMERGENCY SERVICE WATER WAS STARTED AT 3:11 A.M. AND TRAIN "B" ESW WAS STARTED AT 3:23 A.M..
- AT 04:37 PLANT WAS TRIPPED FROM 80% POWER DUE TO DECREASING FORE BAY LEVEL.
- FIVE RODS FAILED TO FULLY INSERT.
- ROD "F6" 18 STEPS OUT; "H2" & "H8" 12 STEPS OUT; "K10" & "K6" 6 STEPS OUT.
- 20 MINUTES AFTER TRIP, ROD BOTTOM LIGHT APPEARED FOR RODS F6, H8, AND K10. 58 MINUTES LATER ROD H2 BOTTOMED; 80 MINUTES LATER ROD K6 BOTTOM LIGHT APPEARED.
- TRAIN "A" ESW WAS TRIPPED AT 8:47 A.M. DUE TO ICING.
- TURBINE DRIVEN EMERGENCY FEEDWATER PUMP WAS TRIPPED AT 8:50 A.M., JANUARY 30, 1996, DUE TO A LEAK FROM INBOARD PACKING. MAINTENANCE WAS PERFORMED; THE PUMP WAS CONSIDERED FUNCTIONAL IN THE EVENING OF JANUARY 30, 1996. PUMP TESTING NOT DONE DUE TO PLANT CONDITIONS.

- THE LICENSEE DECLARED AN UNUSUAL EVENT (UE) AT 9:46 A.M.. (TECHNICAL SUPPORT CENTER WAS NOT ACTIVATED AT THAT TIME).
- ESW BAY DECREASED TO 1085.8 FEET. IF BAY LEVEL DECREASES TO 1083 FEET AN ALERT WILL BE DECLARED. IF LEVEL DECREASES TO 1070 FEET A SITE AREA EMERGENCY WILL BE DECLARED.
- DIESEL FIRE PUMP CAN BE LINED UP TO FEED STEAM GENERATORS. FOUR DC ACTUATED SECONDARY RELIEF VALVES AVAILABLE. BACK UP NITROGEN SUPPLY AVAILABLE FOR LONG TERM. "B" SERVICE WATER PUMP CAN COOL EDG.
- TWO SKID MOUNTED DIESEL GENERATORS WERE BROUGHT ON SITE (ONE 480V AND ONE 4160V).
- ESW "A" RECOVERED AT 4:43 P.M.
- EXITED UE AT 6:58 P.M. WHEN "A" ESW PUMP WAS DECLARED OPERABLE. HOWEVER, AT 8:25 P.M., "A" ESW PUMP WAS ONCE AGAIN MANUALLY TRIPPED DUE TO ICE. LICENSEE DID NOT DECLARE A UE WHEN THE PUMP WAS LOST.
- UE WAS DECLARED AGAIN AT 10:00 A.M. ON JANUARY 31, 1996, WHEN DIVERS FOUND WEDGE OF TIGHTLY PACKED ICE ON "A" ESW PUMP TRASH RACKS.
- AT 10:00 A.M. ON FEBRUARY 2, 1996, AFTER ICE WAS CLEARED, "A" ESW PUMP WAS DECLARED OPERABLE.

OTHER COMPLICATIONS

- AT 5:45 P.M. REACTOR COOLANT PUMP "A" WAS TRIPPED DUE TO OIL SPRAYING.
- PRIMARY ACTIVITY INCREASED TO 2.6 M CURIES/GRAM AND IT DECREASED DURING THE COOLDOWN.
- CONOSEAL LEAKAGE ESTIMATED TO BE 60 DROPS PER MIN.

ROD TESTING RESULTS

- FULL FLOW COLD DROP TESTS CONDUCTED HAD THE FOLLOWING RESULTS. ALL STUCK RODS AND A FEW OTHER DISPLAYED PROBLEMS AT VARYING LEVELS.

H2 PAUSED AT 96 STEPS, STOPPED AT 90, INSERTED TO 30 STEPS IN 2 HRS. WITH AGITATION FROM ROD CONTROL SYSTEM. (BELIEVED TO BE HAFNIUM ROD)

F6 STOPPED AT 18 SLOWLY INSERTED TO 6 STEPS IN 2 HRS. AND REQUIRED AGITATION TO FULLY INSERT

K6 STOPPED AT 30 STEPS, SLOWLY INSERTED TO 18 IN 74 MINS.

K10 STOPPED AT 12 STEPS, FULLY INSERTED IN 22 MINS.

B8 PAUSED AT 12 STEP, STOPPED AT 6 AND TOOK 9 MINS. TO FULLY INSERT.

H14 STOPPED AT 12, FULLY INSERTED IN 10 MINS.

P8 STOPPED AT 12, FULLY INSERTED IN 17 MINS.


F10 FULLY INSERTED WHEN POWER WAS REMOVED.

- NUMBER OF RODS DID NOT EXHIBIT THE EXPECTED NUMBER OF RECOILS.
- A LATER TEST OF ROD "H8" CAUSED THE ROD TO BE STUCK AT 18 STEPS AND WAS DRIVEN TO BOTTOM BY THE ROD CONTROL SYSTEM IN 10 MINUTES.

NRC ACTIONS

- REGION AND THE HEADQUARTERS ENTERED THE MONITORING MODE.
- AN AIT STARTED ON FEBRUARY 6, 1996.
- AN INFORMATION NOTICE, PRIMARILY DEVELOPED ON SOUTH TEXAS UNIT CONCERNS, WILL SHARE THE ROD PROBLEMS EXPERIENCED AT WOLF CREEK. A FURTHER FOLLOW UP NOTICE IS PLANNED.
- A MANAGEMENT CALL WAS CONDUCTED WITH THE REGULATORY RESPONSE GROUP ON FEBRUARY 6, 1996.
- AN INFORMATION NOTICE IS ANTICIPATED FOR ADDRESSING THE COMMON-MODE FAILURE FROM FRAZIL ICE. (RECENTLY ADDRESSED IN INFORMATION NOTICE 92-49).

1-4



CCWS = Component Cooling Water System
 ESWS = Essential Service Water System
 SWS = Service Water System
 CWS = Circulating Water System


11/91

Figure 1-1. Cooling Water Systems Functional Diagram for Wolf Creek

FOR TRAINING PURPOSES ONLY

BRIEFING 96-02


WOLF CREEK, UNIT 1



Essential Service Water Pumphouse (WCGS-EF-2)

WOLF CREEK

BRIEFING 96-02
WOLF CREEK, UNIT 1
12.15.97.03



CONTROL BANK	NUMBER OF RODS
A	4
B	8
C	8
D	5
TOTAL	25

SHUTDOWN BANK	NUMBER OF RODS
S_A	8
S_B	8
S_C	4
S_D	4
S_E	4
TOTAL	28


Rev. 0

⊗ PROBLEM RODS AT FIRST RX TRIP

▤ STUCK DURING DROP TEST

WOLF CREEK
UPDATED SAFETY ANALYSIS REPORT
FIGURE 4.3-36
ROD CLUSTER CONTROL ASSEMBLY
PATTERN

BRIEFING 96-02
 WOLF CREEK, UNIT 1
 FOR TRAINING PURPOSES ONLY



00
 01
 02
 03
 04
 05
 06
 07
 08
 09
 10
 11
 12
 13
 14
 15
 16
 17
 18
 19
 20
 21
 22
 23
 24
 25
 26
 27
 28
 29
 30
 31
 32
 33
 34
 35
 36
 37
 38
 39
 40
 41
 42
 43
 44
 45
 46
 47
 48
 49
 50
 51
 52
 53
 54
 55
 56
 57
 58
 59
 60
 61
 62
 63
 64
 65
 66
 67
 68
 69
 70
 71
 72
 73
 74
 75
 76
 77
 78
 79
 80
 81
 82
 83
 84
 85
 86
 87
 88
 89
 90
 91
 92
 93
 94
 95
 96
 97
 98
 99
 100

REACTOR SCRAM

Reporting Period: 01/29/96 to 02/04/96

<u>DATE</u>	<u>PLANT & UNIT</u>	<u>POWER</u>	<u>TYPE</u>	<u>CAUSE</u>	<u>COMPLICATIONS</u>	<u>YTD ABOVE 15%</u>	<u>YTD BELOW 15%</u>	<u>YTD TOTAL</u>
01/30/96	WOLF CREEK 1	80	SM	Other	YES	1	0	1
02/03/96	MCGUIRE 1	100	SM	Maintenance Error	NO	1	0	1
02/04/96	LASALLE 2	55	SM	Design or Installati	NO	1	0	1

DESCRIPTION OF COMPLICATION(S) 01/29/96 TO 02/04/96

<u>SITE</u>	<u>UNIT</u>	<u>COMPLICATIONS</u>
WOLF CREEK	1	SEVERAL CONTROL RODS DID NOT INSERT FULLY, REQUIRING OPERATORS TO BORATE.

Note: Year To Date (YTD) Totals Include Events Within The Calendar Year Indicated By The End Date Of The Specified Reporting Period

COMPARISON OF WEEKLY SCRAM STATISTICS WITH INDUSTRY AVERAGES

PERIOD ENDING
02/04/96

<u>SCRAM CAUSE</u>	NUMBER OF SCRAMS	1996 WEEKLY AVERAGE (YTD)	1995 WEEKLY AVERAGE	1994 WEEKLY AVERAGE	1993 WEEKLY AVERAGE	1992 WEEKLY AVERAGE
POWER GREATER THAN OR EQUAL TO 15%						
EQUIPMENT FAILURE	0	1.20	1.81	1.52	1.83	2.62
DESIGN/INSTALLATION ERROR	1	0.20	0.12	0.08	0.04	-
OPERATING ERROR	0	0.00	0.15	0.21	0.27	0.31
MAINTENANCE ERROR	1	0.60	0.38	0.54	0.52	0.50
EXTERNAL	0	0.00	0.21	0.17	0.13	-
OTHER	1	0.20	0.08	-	0.02	-
Subtotal	3	2.20	2.75	2.52	2.81	3.43
POWER LESS THAN 15%						
EQUIPMENT FAILURE	0	0.00	0.10	0.27	0.38	0.42
DESIGN/INSTALLATION ERROR	0	0.00	-	0.02	-	-
OPERATING ERROR	0	0.00	0.13	0.08	0.13	0.15
MAINTENANCE ERROR	0	0.00	0.08	-	0.02	0.08
EXTERNAL	0	0.00	-	-	0.04	-
OTHER	0	0.00	-	-	-	-
Subtotal	0	0.00	0.31	0.37	0.57	0.65
TOTAL	3	2.20	3.06	2.89	3.38	4.08

<u>SCRAM TYPE</u>	NO. OF SCRAMS	1996 WEEKLY AVERAGE (YTD)	1995 WEEKLY AVERAGE	1994 WEEKLY AVERAGE	1993 WEEKLY AVERAGE	1992 WEEKLY AVERAGE
TOTAL AUTOMATIC SCRAMS	0	0.80	1.92	2.19	2.44	3.06
TOTAL MANUAL SCRAMS	3	1.40	1.13	0.69	0.94	1.02

TOTALS MAY DIFFER BECAUSE OF ROUNDING OFF

NOTES

1. PLANT SPECIFIC DATA BASED ON INITIAL REVIEW OF 50.72 REPORTS FOR THE WEEK OF INTEREST. PERIOD IS MIDNIGHT SUNDAY THROUGH MIDNIGHT SUNDAY. SCRAMS ARE DEFINED AS REACTOR PROTECTIVE ACTUATIONS WHICH RESULT IN ROD MOTION, AND EXCLUDE PLANNED TESTS OR SCRAMS AS PART OF PLANNED SHUTDOWN IN ACCORDANCE WITH A PLANT PROCEDURE. THERE ARE 111 REACTORS HOLDING AN OPERATING LICENSE.
2. PERSONNEL RELATED PROBLEMS INCLUDE HUMAN ERROR, PROCEDURAL DEFICIENCIES, AND MANUAL STEAM GENERATOR LEVEL CONTROL PROBLEMS.
3. COMPLICATIONS: RECOVERY COMPLICATED BY EQUIPMENT FAILURES OR PERSONNEL ERRORS UNRELATED TO CAUSE OF SCRAM.
4. "OTHER" INCLUDES AUTOMATIC SCRAMS ATTRIBUTED TO ENVIRONMENTAL CAUSES (LIGHTNING), SYSTEM DESIGN, OR UNKNOWN CAUSE.

OEAB SCRAM DATA

Manual and Automatic Scrams for 1987	-----	435
Manual and Automatic Scrams for 1988	-----	291
Manual and Automatic Scrams for 1989	-----	252
Manual and Automatic Scrams for 1990	-----	226
Manual and Automatic Scrams for 1991	-----	206
Manual and Automatic Scrams for 1992	-----	212
Manual and Automatic Scrams for 1993	-----	175
Manual and Automatic Scrams for 1994	-----	150
Manual and Automatic Scrams for 1995	-----	159
Manual and Automatic Scrams for 1996	--(YTD 02/04/96)--	11