

June 8, 1992

Docket Nos. 50-338  
and 50-339

DISTRIBUTION

Docket File  
NRC & Local PDRs  
PD22 Rdg  
SVarga  
GLainas  
HBerkow  
LEngle  
DMiller  
ATOalston  
ACRS (10)  
OGC  
MSinkule, RII

Mr. W. L. Stewart  
Senior Vice President - Nuclear  
Virginia Electric and Power Company  
5000 Dominion Blvd.  
Glen Allen, Virginia 23060

Dear Mr. Stewart:

SUBJECT: NORTH ANNA UNITS 1 AND 2 - SUPPLEMENTAL SAFETY EVALUATION FOR  
STATION BLACKOUT RULE, 10 CFR 50.63 (TAC NOS. M68572 AND M68573)

We have evaluated your submittals dated February 10 and March 17, 1992 which addressed several open items described in our Supplemental Safety Evaluation dated December 6, 1991. We find your responses to be acceptable. However, until Generic Issue B-56, "Emergency Diesel Generator Reliability," is resolved, we require that you commit to an emergency diesel generator program which, as a minimum, contains the five elements of Section 1.2 of Regulatory Guide 1.155, "Station Blackout." We request that you respond expeditiously to bring this issue to closure.

This requirement affects fewer than 10 respondents and, therefore, is not subject to Office of Management and Budget review under P.L. 96-511. Should you have any questions, please call me at 301-504-1480.

Sincerely,

(Original Signed By)

Leon B. Engle, Project Manager  
Project Directorate II-2  
Division of Reactor Projects - I/II  
Office of Nuclear Reactor Regulation

cc: See next page

OFFICE	LA:PD22	PM:PD22	D:PD22		
NAME	DMiller	LEngle	HBerkow		
DATE	6/15/92	6/18/92	6/18/92	1/1	1/1

OFFICIAL RECORD COPY  
FILENAME: NA68572.LTR

NRC FILE CENTER COPY

9206160074 920608  
FDR ADOCK 05000338  
P PDR

LF01  
111

Mr. W. L. Stewart  
Virginia Electric & Power Company

North Anna Power Station  
Units 1 and 2

cc:

Mr. William C. Porter, Jr.  
County Administrator  
Louisa County  
P.O. Box 160  
Louisa, Virginia 23093

C.M.G. Buttery, M.D., M.P.H.  
State Health Commissioner  
Office of the Commissioner  
Virginia Department of Health  
P.O. Box 2448  
Richmond, Virginia 23218

Michael W. Maupin, Esq.  
Hunton and Williams  
P.O. Box 1535  
Richmond, Virginia 23212

Regional Administrator, R11  
U.S. Nuclear Regulatory Commission  
101 Marietta Street, N.W., Suite 2900  
Atlanta, Georgia 30323

Dr. W. T. Lough  
Virginia State Corporation Commission  
Division of Energy Regulation  
P.O. Box 1197  
Richmond, Virginia 23209

Mr. G. E. Kane, Manager  
North Anna Power Station  
P.O. Box 402  
Mineral, Virginia 23117

Old Dominion Electric Cooperative  
4201 Dominion Blvd.  
Glen Allen, Virginia 23060

Mr. J. P. O'Hanlon  
Vice President - Nuclear Operations  
Virginia Electric and Power Company  
5000 Dominion Blvd.  
Glen Allen, Virginia 23060

Mr. E. Wayne Harrell  
Vice President - Nuclear Services  
Virginia Electric and Power Co.  
5000 Dominion Blvd.  
Glen Allen, Virginia 23060

Mr. Martin Bowling  
Manager - Nuclear Licensing  
Virginia Electric and Power Co.  
5000 Dominion Blvd.  
Glen Allen, Virginia 23060

Office of the Attorney General  
Supreme Court Building  
101 North 8th Street  
Richmond, Virginia 23219

Senior Resident Inspector  
North Anna Power Station  
U.S. Nuclear Regulatory Commission  
Route 2, Box 78  
Mineral, Virginia 231172