



PERRY NUCLEAR POWER PLANT

10 CENTER ROAD
PERRY, OHIO 44081
(216) 259-3737

Mail Address:
P.O. BOX 97
PERRY, OHIO 44081

Donald C. Shelton
SENIOR VICE PRESIDENT
NUCLEAR

February 13, 1996
PY-CEI/OEPA-0244L

Ohio Environmental Protection Agency
P.O. Box 163669
Columbus, Ohio 43216-3669

Gentlemen:

Enclosed are the NPDES monthly report forms for the month of January, 1996.

If you have questions or require additional information, please contact Donna Tizzano at (216) 280-5514.

Very truly yours,

A handwritten signature in dark ink, appearing to be 'D. Shelton', written over a horizontal line.

DCS:DGT:vh

Enclosure

cc: NRC Project Manager
NRC Resident Inspector Office
NRC Document Control Desk
NRC Region III

000057

9602200268 960131
PDR ADDCK 05000440
R PDR

Operating Companies
Cleveland Electric Illuminating
Toledo Edison

IE 25
111

CLEVELAND ELECTRIC ILLUM CO 3IB00016002 JAN 96
NUCLEAR GROUP
C/O PERRY NUCLEAR POWER PLANT
10 CENTER ROAD ROOM E240
NORTH PERRY 44081 LAKE

1 1

OHIO
63461

002 DISCHARGE FROM CHEMICAL CLEANING
LAGOON E PLANT

FORM

CEI, PERRY

D.G. TIZZANO

1	1	2	3	2	2	2
999	999	96	1	96	96	96

CONDUI	PH	RESIDUE	O&G	PHOS-T	COPPER	IRON
FLOW		T NFLT	TOTAL	P-WET	CU,TOT	FE,TOT
MGD	S.U.	MG/L	MG/L	MG/L	MG/L	UG/L
50050	00400	00530	00550	00665	01042	01045

01
02
03
04
05
06
07
08
09
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31

NO DISCHARGE OCCURRED DURING THE MONTH

REPORTER



CLEVELAND ELECTRIC ILLUM CO 31B00016800 JAN 96
NUCLEAR GROUP
C/O PERRY NUCLEAR POWER PLANT
10 CENTER ROAD ROOM E240
NORTH PERRY 44081 LAKE

1 1

OHIO
63461

800 INTAKE WATER AT INLET TO PLANT
FROM LAKE ERIE

FORM

CEI, PERRY

D.G. TIZZANO

1
999

WATER
TEMP
F.

00011

01	32
02	31
03	31
04	31
05	31
06	31
07	31
08	31
09	31
10	31
11	32
12	32
13	32
14	32
15	31
16	31
17	31
18	32
19	33
20	31
21	31
22	31
23	32
24	32
25	31
26	32
27	31
28	31
29	32
30	32
31	32

975
31
33
31

NONE

REPORTER



CLEVELAND ELECTRIC ILLUM CO 3IB00016004 JAN 98
 NUCLEAR GROUP
 C/O PERRY NUCLEAR POWER PLANT
 10 CENTER ROAD ROOM E240
 NORTH PERRY 44081 LAKE

1 1

OHIO
 63461

004 POINT REP OF DISCHARGE PRIOR TO
 ENTRY TO TUNNEL

FORM

CEI, PERRY

D.G.TIZZANO

1 1 3 3
 999 999 1 1

WATER CONDUI CHLOR PH
 TEMP FLOW FREE A
 F. MGD MG/L S.U.

00011 50050 50064 00400

01	43	100.9	0.00	
02	41	105.8	0.00	8.0
03	41	93.5	0.00	
04	40	94.9	0.00	
05	41	89.6	0.00	8.0
06	41	92.5	0.00	
07	40	108.9	0.00	
08	41	95.4	0.00	
09	42	86.4	0.00	8.0
10	42	90.5	0.00	
11	42	85.9	0.00	
12	43	58.9	0.00	8.1
13	44	93.4	0.00	
14	43	100.4	0.00	
15	40	104.2	0.00	
16	42	107.9	0.00	8.4
17	45	119.0	0.00	
18	47	153.7	0.00	
19	45	75.4	0.00	8.2
20	41	100.3	0.00	
21	40	96.8	0.00	
22	42	101.0	0.00	
23	44	97.5	0.00	8.2
24	44	111.2	0.00	
25	42	105.3	0.00	
26	43	103.0	0.00	8.2
27	37	118.2	0.00	
28	36	107.9	0.00	
29	32	80.2	0.00	
30	32	80.8	0.00	8.0
31	32	80.8	0.00	
	1267	3040.2	0.00	73.1
	41	98.0	0.00	8.1
	47	153.7	0.00	8.4
	32	58.9	0.00	8.0

NONE

REPORTER

CLEVELAND ELECTRIC ILLUM CO 3IB00016001 JAN 96
 NUCLEAR GROUP
 C/O PERRY NUCLEAR POWER PLANT
 10 CENTER ROAD ROOM E240
 NORTH PERRY 44081 LAKE

1 1

OHIO
 63461

001 DISCHARGE FROM REGENERATE
 NEUTRALIZATION PITS

FORM

CEI, PERRY

D.G. TIZZANO

	1 999	1 999	1 999	2 96	3 1
CONDUIT FLOW MGD	PH (MAX) S.U.	PH (MIN) S.U.	RESIDUE T NFLT MG/L	O&G TOTAL MG/L	
50050	00401	00402	00530	00550	
01 AH	AH	AH			
02 AH	AH	AH			
03 AH	AH	AH			
04 AH	AH	AH			
05 0.0190	8.5	7.6	5	AA	
06 AH	AH	AH			
07 AH	AH	AH			
08 AH	AH	AH			
09 AH	AH	AH			
10 AH	AH	AH			
11 0.0174	8.5	8.5	5	AA	
12 AH	AH	AH			
13 AH	AH	AH			
14 AH	AH	AH			
15 AH	AH	AH			
16 AH	AH	AH			
17 0.0196	6.8	6.8	5	AA	
18 AH	AH	AH			
19 AH	AH	AH			
20 AH	AH	AH			
21 AH	AH	AH			
22 AH	AH	AH			
23 AH	AH	AH			
24 0.0200	7.3	7.3	7	AA	
25 AH	AH	AH			
26 AH	AH	AH			
27 AH	AH	AH			
28 AH	AH	AH			
29 0.0207	7.9	7.8	3	AA	
30 AH	AH	AH			
31 AH	AH	AH			
0.0967	39.0	38.0	25	AA	
0.0193	7.8	7.6	5	AA	
0.0207	8.5	8.5	7	AA	
0.0174	6.8	6.8	3	AA	

AA - BELOW DETECTABLE LIMIT (5 mg/l for O&G and 2.5 mg/l for RESIDUE)
 AH - SAMPLE NOT TAKEN, NO DISCHARGE PERFORMED THIS DATE

REPORTER