



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D.C. 20555

June 3, 1992

Docket No. 52-002

APPLICANT: Combustion Engineering, Inc. (ABB-CE)  
PROJECT: CE System 80+  
SUBJECT: PUBLIC MEETING APRIL 27-30, 1992, REGARDING SEISMIC AND STRUCTURAL DESIGN ISSUES

A public meeting was held between representatives of ABB-CE and the Nuclear Regulatory Commission (NRC) staff from April 27 through 30, 1992, at the Phillips Building in Bethesda, Maryland, regarding seismic ground motion issues for input to the seismic design of System 80+ and the structural design issues for System 80+. A list of attendees for each day is provided in Enclosure 1. The agenda for each day is provided in Enclosure 2. The summary for the orientation session on the morning of April 28, 1992, was published separately May 4, 1992. The material presented to the staff is provided in Enclosure 3.

ABB-CE presented the Control Motion Spectra (CMS) used for input to the seismic analysis, including two new spectra (CMS-1 and CMS-3). The Combustion Engineering Standard Safety Analysis Report-Design Certification (CESSAR-DC) will be revised later, not in time for the draft safety evaluation report (DSER), to incorporate these new inputs. ABB-CE stated that the System 80+ civil structures design is standardized for all applicable sites. ABB-CE believed that they had been designed for the most severe loads resulting from the generic site categories considered, since soil profiles were selected to produce soil column frequencies which correspond to the principle structural frequencies. They also clarified the use of the term "84th percentile spectrum" by stating that the enveloping spectrum will be compared to the 84th percentile seismic design response spectrum for the specific site being considered. Piping and components, however, may be designed to conditions that envelope a subgroup of generic sites.

ABB-CE stated that some structural modifications had been made and these modifications are being incorporated into the Soil Structure Interaction (SSI) analysis. The CESSAR-DC contains the preliminary SSI. Results of a final SSI analysis will not be available for the DSER but will be added to CESSAR-DC prior to the final safety evaluation report (FSER). During the four days of meetings, commitments were made by ABB-CE to provide responses to staff questions. These are listed below.

1. ABB-CE is to provide a sensitivity study on the effects of variations in soil properties, using Case B-3.5 which demonstrates that bounding

9206160259 920603  
PDR ADOCK 05200002  
A PDR

NRC FILE CENTER COPY

LEO 11

June 3, 1992

conditions are used. ABB-CE is also to provide data to support this position in soil depths greater than 300 feet.

2. To support NRC confirmatory SSI analysis, ABB-CE will provide the following input: stick model of the structures including the containment shell, dimensions of basemat, input data for soil Cases B-3.5 and B-4, low strain soil properties, unit weights, Poisson's ratio, constrained modulus and Young's modulus (E) for P-wave, digitized values of G/Gmax vs.  $\epsilon$  and damping vs.  $\epsilon$ .
3. Provide site acceptance criteria to be added to CESSAR-DC. Consider near field earthquake (< 25 km) for vertical motion vs. horizontal motion. Also, consider that vertical motion may be the same as or greater than the horizontal motion in the near field earthquakes.
4. Recheck case B-1 vs. B-2 using a shear wave velocity of 11,000 fps for rock. Determine the peak frequency shift with the change in shear wave velocity.
5. List all COL action items to demonstrate that the site can meet the envelope. Clearly describe definitions of input ground motions and how they are to be applied at specific sites.
6. Provide the cut-off frequency for the SHAKE calculations.
7. Perform an SSI analysis for Case A-1 to compare to fixed base case. Confirm that fixed base case is to be used for embedment up to 52 feet.
8. Specific soil properties should be defined clearly in CESSAR-DC.
9. Specify input for analysis and acceptance criteria for buried piping.
10. How was the equipment hatch modeled for the structural analysis? In the final analysis, will it be modeled as an axisymmetric mass or lumped mass at actual location?
11. Address how the variability of structural elements (parameters such as the effects of concrete cracking) are accounted for.
12. Provide support for statement in CESSAR-DC on page 3.7-15 regarding broadened spectrum.
13. Address the treatment of common walls, i.e., half to each adjacent area, in the stick models.
14. Address bending or flexural shear of wall intersections.
15. Revised CESSAR-DC must better address design analysis of the non-seismic Category I structures which may cause damage to seismic Category I structures.


16. Define the fragility level of the containment shell structure beyond the SSE.
17. References must be placed in CESSAR-DC for eastern North America CMS-2 spectra.
18. Revised CESSAR-DC, especially Sections 2.5 and 3.7, must incorporate appropriate responses to RAI's.
19. Assess the effects of sticks connected to sidewalls vs. not connected.
20. Define criteria for evaluating containment performance (Service Level C with pressure-temperature profile, fragility curve with conditional containment failure probability, CCFP).
21. Submit summary report with additional information to augment response to RAI 220.55.
22. Provide the basis for the spring constant used for the compressible material between the containment shell sphere and the concrete support dish. The specifications for this material must account for a 60-year design life.
23. Identify the documentation of the ANSYS verification problem(s) for elastic-plastic analysis.
24. How are localized strains around reinforced areas for penetrations and around the transition region between the containment shell and the concrete support dish evaluated? SANDIA strain criteria should be considered for localized effects at penetrations and the transition region.
25. Rerun the buckling analysis with model refinements and new seismic design requirements. Address the anomaly of present results showing buckling at the top of the containment shell sphere and provide a basis for reasonableness of results (e.g., obtain results that are physically realistic on the location where buckling occurs).
26. Transmit to NRC the pre-buckling stresses after ABB-CE is satisfied with results for the Level B and Level D performance.
27. Detailed design criteria for penetrations must be established. Provide evaluation of ultimate capacity on the basis of the code and the "severe accident" criteria. ITAAC should address confirmation after designs of as-purchased penetration assemblies are available.
28. Provide justification of the factor of safety of 2 used for level C.

June 3, 1992

Finally, NRC requested copies of the following documents to be made available for audit at the ABB-CE office at Rockville, Maryland:

1. Fixed Base Analysis Calculation/Design No. FB-01 Title: ALWR System 80+ FB Analysis (Job No. 8503-003-1355)
2. SSI Analysis-Calculation/Design No. ALWR-I (Job No. 8503-003)
3. Report No.: 01-8503-1784 Rev. 0, August 1990, Title: Seismic Analysis of Reactor Building of System 80+ certified design by ABB Impell.

ABB-CE stated that a schedule for submittal of all of the above items would be provided.



Thomas V. Wambach, Project Manager  
Standardization Project Directorate  
Associate Directorate for Advanced Reactors  
and License Renewal  
Office of Nuclear Reactor Regulation

Enclosures:

1. List of attendees
2. NRC Meeting/Audit Agenda
3. ABB-CE Presentations

cc w/enclosures:  
See next page

June 3, 1992

Finally, NRC requested copies of the following documents to be made available for audit at the ABB-CE office at Rockville, Maryland:

1. Fixed Base Analysis Calculation/Design No. FB-01 Title: ALWR System 80+ FB Analysis (Job No. 8503-003-1355)
2. SSI Analysis-Calculation/Design No. ALWR-I (Job No. 8503-003)
3. Report No.: 01-8503-1784 Rev. 0, August 1990, Title: seismic Analysis of Reactor Building of System 80+ certified design by ABB Impell.

ABB-CE stated that a schedule for submittal of all of the above items would be provided.

Original Signed By:

Thomas V. Wambach, Project Manager  
 Standardization Project Directorate  
 Associate Directorate for Advanced Reactors  
 and License Renewal  
 Office of Nuclear Reactor Regulation

Enclosures:

1. List of attendees
2. NRC Meeting/Audit Agenda
3. ABB-CE Presentations

cc w/enclosures:  
See next page

DISTRIBUTION:

Docket File	PDST R/F	DCrutchfield	WTravers
NRC PDR	RPierson	JNWilson	TMurley/FMiraglia, 12G18
TWambach	JMoore, 15B18	ACRS (10)	EJordan, 3701
PShea	GBagchi, 7H15	RRothman, 7H15	RPichumani, 7H15
TCheng, 7H15	DTerao, 7H15	SLee, 7H15	DTang, 7H15
PTKuo, 11F23	CMcCracken		

OFC:	LA:PDST	PM:PDST	SC:PDST	
NAME:	PShea <i>POS</i>	TWambach:sg <i>TW</i>	JNWilson <i>JN</i>	
DATE:	<i>06/2/92</i>	<i>06/2/92</i>	<i>06/3/92</i>	

OFFICIAL RECORD COPY:  
DOCUMENT NAME: MTGSUMWK.TW

Combustion Engineering, Inc.

Docket No. 52-002

cc: Mr. C. B. Brinkman, Acting Director  
Nuclear Systems Licensing  
Combustion Engineering, Inc.  
1000 Prospect Hill Road  
Windsor, Connecticut 06095-0500

Mr. C. B. Brinkman, Manager  
Washington Nuclear Operations  
Combustion Engineering, Inc.  
12300 Twinbrook Parkway, Suite 330  
Rockville, Maryland 20852

Mr. Stan Ritterbusch  
Nuclear Systems Licensing  
Combustion Engineering, Inc.  
1000 Prospect Hill Road  
Post Office Box 500  
Windsor, Connecticut 06095-0500

Mr. Daniel F. Giessing  
U. S. Department of Energy  
NE-42  
Washington, D.C. 20585

Mr. Steve Goldberg  
Budget Examiner  
725 17th Street, N.W.  
Washington, D.C. 20503

Mr. Raymond Ng  
1776 Eye Street, N.W.  
Suite 300  
Washington, D.C. 20006

Mr. Mark McCabe  
U.S. Department of Justice/EAG  
555 4th Street, N.W.  
Room 11-809  
Washington, D.C. 20001

ATTENDEE LIST  
SEISMOLOGICAL REVIEW  
APRIL 27, 1992

<u>NAME</u>	<u>ORGANIZATION</u>
THOMAS V. WAMBACH	NRC/NRR/PDST
CHARLES B. BRINKMAN	ABB/CE
ROBERT P. KENNEDY	SMC
I. M. IDRIS	UC DAVIS
STAVROS DERMITZAKIS	ABB IMPELL
SOHRAB ESFANDIARI	ABB IMPELL
GOUTAM BAGCHI	NRC/NRR/ESGB
ROBERT ROTHMAN	NRC/NRR/ESGB
RAMON PICHUMANI	NRC/NRR/ESGB
CARL J. COSTANTINO	CCNY
THOMAS M. CHENG	NRC/NRR/ESGB
TING-YU LO	LLNL
DAVID TERAQ	NRC/NRR
SAM LEE	NRC/NRR
DAVID TANG	NRC/NRR/DET/ESGB
P. T. KUO	NRC/ESGB
TODD OSWALD	DUKE ENGINEERING
DAN PECK	ABB-CE
DAVE BAISLEY	ABB-CE
LYLE GERDES	ABB-CE
STAN RITTERBUSCH	ABB-CE

ATTENDEES LIST  
STRUCTURAL DESIGN  
APRIL 28, 1992

<u>NAME</u>	<u>ORGANIZATION</u>
THOMAS V. WAMBACH	NRC/NRR/PDST
RAMAN PICHUMANI	NRC/NRR/ESGB
CARL J. COSTANTINO	CCNY
THOMAS M. CHENG	NRC/NRR/DET/ESGB
TING-YU LO	LLNL
DAVID TANG	NRC/NRR/DET/ESGB
P. T. KUO	NRC/NRR/DET/ESGB
R. L. ROTHMAN	NRC/NRR/DET/ESGB
RICK PARLER	DUKE ENGINEER
TODD OSWALD	DUKE ENGINEER
FRANK SNIPES	DUKE ENGINEER
STAN TERBUSCH	ABB-CE
SOHRAB ESFANDIARI	ABB-IMPELL
LYLE GERDES	ABB-CE
STAVROS DERMITZAKIS	ABB-IMPELL
DAN PECK	ABB-CE



ATTENDEES LIST

STRUCTURAL DESIGN

APRIL 29, 1992

NAME

ORGANIZATION

THOMAS V. WAMBACH	NRC/NRR/PDST
DAVID TANG	NRC/NRR/DET/ESGB
P. T. KUO	NRC/NRR/DET/ESGB
DAN PECK	ABB-CE
LYLE GERDES	ABB-CE
RUSS MITCHELL	ABB-CE
BILL FOX	DUKE ENGINEER & SERVICE
STAVROS DERMITZAVIS	ABB-IMPELL
TODD OSWALD	DUKE ENGINEER
FRANK SNIPES	DUKE ENGINEER
RICK PARLER	DUKE ENGINEER
RAMAN PICHUMANI	NRC/NRR/ESGB

P.M. ONLY

THOMAS CHENG	NRC/NRR/DET/ESGB
FAUAD FANOUS	AMES LABS
DELWNY BLUHM	AMES LAB
LOWEL GREIMANN	AMES LAB
TONY D'ANGELO	NRC/NRR/DST/SPLB
JIM CASSIDY	DUKE ENGINEER

ATTENDEES LIST

STRUCTURAL DESIGN

APRIL 30, 1992

NAME

ORGANIZATION

THOMAS V. WAMBACH	NRC/NRR/PDST
DAVID TANG	NRC/NRR/DET/ESGB
LOWEL GREIMANN	AMES LAB
P. T. KUO	NRC/NRR/DET/ESGB
FAUAD FANOUS	AMES LABS
TODD OSWALD	DUKE ENGINEER
FRANK SNIPES	DUKE ENGINEER
RICK PARLER	DUKE ENGINEER
JIM CASSIDY	DUKE ENGINEER
BILL FOX	DUKE ENGINEER & SERVICE
RICK TURK	ABB-CE
LYLE GERDES	ABB-CE

NRC MEETING/AUDIT AGENDA

APRIL 27-30, 1992

WASHINGTON, D.C.

APRIL 27

9:00 A.M.

INTRODUCTIONS

CONTROL MOTION SELECTION AND APPLICATION

12:00 NOON

LUNCH

1:00 P.M.

SEISMOLOGICAL REVIEW

SEISMIC DESIGN BASIS

SSE MOTIONS

INPUT MOTION

METHODS OF ANALYSIS

FOUNDATION MATERIAL PROPERTIES

DEGRADATION RELATIONSHIPS

VARIATION OF SOIL

NRC MEETING / AUDIT AGENDA

APRIL 27-30, 1992

WASHINGTON, D.C.

APRIL 28

9:00 A.M.

ORIENTATION OF NEW STAFF REVIEWERS TO THE SYSTEM 80+  
DESIGN

GENERAL LAYOUT

SYSTEM OVERVIEW

12:00 NOON

LUNCH

1:00 P.M.

STRUCTURAL REVIEW

DYNAMIC MODEL

ANALYSIS METHODS

SPECTRA

CODES AND STANDARDS

FORCES IN DESIGN

DESIGN DETAILS

SITE ACCEPTANCE

EFFECTS OF OBE = 1/3 SSE

NRC MEETING / AUDIT AGENDA

APRIL 27-30, 1992

WASHINGTON, D.C.

APRIL 29

9:00 A. M. DISCUSSIONS ON SEISMOLOGICAL AND STRUCTURAL DESIGN

MATERIAL AUDIT / REVIEW

12:00 NOON LUNCH

1:00 P. M. CONTAINMENT BUCKLING  
CONTAINMENT MODEL  
SEISMIC INPUT  
CRITICAL LOAD COMBINATIONS  
LOCATION OF BUCKLING  
FACTOR OF SAFETY  
MARGIN FOR BEYOND DESIGN BASIS

CONTAINMENT PERFORMANCE  
PRESSURE\_TEMPERATURE PROFILES  
CONTAINMENT INTEGRITY  
PENETRATIONS

NRC MEETING / AUDIT AGENDA

APRIL 27-30, 1992

WASHINGTON, D.C.

APRIL 30

9:00 A.M.

DISCUSSIONS ON CONTAINMENT PERFORMANCE AND BUCKLING

MATERIAL AUDIT / REVIEW

11:00 A.M.

WRAP-UP

**SELECTION OF CONTROL MOTION  
FOR THE  
SYSTEM 80+ STANDARD DESIGN**

Prepared by:

**ABB COMBUSTION ENGINEERING**

April 27, 1992

## AGENDA

- OBJECTIVES
- SELECTION PROCESS
- SITE ACCEPTANCE CRITERIA FOR CONTROL MOTION
- APPLICATION OF CONTROL MOTION TO SEISMIC SSI ANALYSES
- CONCLUSIONS



## OBJECTIVES

- Develop a control motion that provides potential for a safe standardized seismic design.
- Develop a control motion that provides the owners of the System 80+ design with high confidence that the design is suitable for most sites in the U.S.

Exception: Sites near major active faults, as for example certain sites in California.

- Develop a control motion in full compliance with:
  - SRP, Sections 2.5, Rev.2 and 3.7, Rev.2
  - EPRI URD
- Develop a control motion which exceeds SRP guidance for added safety

## SELECTION PROCESS

- Control Motion Spectra are anchored to 0.3 g horizontal Peak Ground Acceleration (84th percentile PGA).
- Control Motion Spectra are applied to 13 generic site conditions, 12 soil cases and one rock case.

## SELECTION PROCESS

- Chronological Order of Selection:
  - *Originally, CMS2 was developed for application to a hypothetical rock outcrop for the 12 soil cases, and direct application to the foundation level for the rock case.*
  - *These soil cases were chosen such that application of CMS2 at the rock outcrop would result in surface motions which would envelop the expected surface motion covering both shallow and deep soil sites as well as rock sites.*
  - *CMS2 is anchored to 0.3 g in the horizontal directions and 0.2 g in the vertical direction.*
  - *84th percentile spectrum*
  - *Combination of NUREG/CR-0098 and typical Eastern North America spectra for rock, with maximum ground velocity of 24 in/sec/g (therefore, maximum ground velocity is 7.2 in/sec in the horizontal direction and 4.8 in/sec in the vertical direction).*

## SELECTION PROCESS

- *To address NRC concerns regarding possible low frequency deficiencies in CMS2 and to demonstrate full design conformance for a RG 1.60 spectrum defined at the free-field ground surface, the System 80+ is also designed for CMS1 and CMS3 as additional control motions.*
- *CMS1 (RG 1.60 spectrum) is used to envelop conditions for deep soil sites. It is anchored to 0.3 g in all directions (horizontal and vertical).*
- *CMS3 is developed for application at the rock outcrop of shallow sites.*

### *84th percentile spectrum*

*CMS3 is anchored to 0.3 g in the horizontal directions and 0.2 g in the vertical direction.*

*In full compliance with NUREG/CR-0098 spectra with 36 in/sec/g ground velocity.*

*Enriched with high frequency content up to 15 Hz (NUREG/CR-0098 has cutoff frequency of 8 Hz)*




Figure 2.2 - Derivation of CMS2

Damping = 5%




Figure 2.1 - CMS1, CMS2 and CMS3  
(5% Damping)

## SELECTION PROCESS

- *The envelope of the amplified free-field surface motions resulting from the application of CMS2 at the rock outcrop significantly exceeds a RG 1.60 spectrum. This provides a technically sound seismic design basis for shallow and deep soil sites as well as for rock sites.*




Figure 3.3 - Comparison of CMS1 with Horizontal Ground Surface Motions Computed from Application of CMS2 at the Rock Outcrop



## SELECTION PROCESS

- *The envelope of the amplified free-field motions at the foundation level resulting from the application of CMS2 at the rock outcrop significantly exceeds 60% of CMS2 and 60% of the RG 1.60 spectrum. Note that it also exceeds 100% of RG 1.60 over the frequency range of interest for structural response.*




Figure 3.4 - Comparison of 60% of CMS1 with Horizontal Motions at Foundation Level Computed from Application of CMS2 at Rock Outcrop

## SELECTION PROCESS

• Various Upper Bound Earthquake Scenarios Covered by the System 80+ Design Control Motions

Magnitude	Distance (km)
6.0	15
6.75	25
7.0	30
7.25	40
7.5	50

*All earthquakes of either lower magnitude or at higher fault distances than the above five scenarios are also covered by the System 80+ design control motions.*

System 80+ Design Spectra,  $M = 6$ ,  $R = 15$




Figure 2.3 - Comparison of CMS2 and CMS3 with Attenuation Relationships by Campell, Geomatrix and Idriss ( $M=6$ ,  $R=15$  km)

System 80+ Design Spectra,  $M = 6.75$ ,  $R = 25$




Figure 2.4 - Comparison of CMS2 and CMS3 with Attenuation Relationships by Campell, Geomatrix and Idriss ( $M=6.75$ ,  $R=25$  km)

System 80+ Design Spectra,  $M = 7, R = 30$




Figure 2.5 - Comparison of CMS2 and CMS3 with Attenuation Relationships by Campbell, Geomatrix and Idriss ( $M=7, R=30$  km)

System 80+ Design Spectra,  $M = 7.25$ ,  $R = 40$




Figure 2.6 - Comparison of CMS2 and CMS3 with Attenuation Relationships by Campbell, Geomatrix and Idriss ( $M=7.25$ ,  $R=40$  km)

System 80+ Design Spectra,  $M = 7.5$ ,  $R = 50$




Figure 2.7 - Comparison of CMS2 and CMS3 with Attenuation Relationships by Campell, Geomatrix and Idriss ( $M=7.5$ ,  $R=50$  km)



## SITE ACCEPTANCE CRITERIA FOR CONTROL MOTION

- Site-specific response spectra to fall below one or more of the three control motions of the System 80+ standard design.
  - *CMS1 to be used for deep soil sites or rock sites. Compare site-specific free-field surface spectra with CMS1.*
  - *If site-specific spectra exceed CMS1, compare site-specific surface spectra to the System 80+ envelope surface spectra.*
  - *CMS2 or CMS3 to be used for all soil sites (shallow and deep) as well as rock sites. Compare site-specific rock outcrop spectra with CMS2 or CMS3.*
  - *If site-specific rock outcrop spectra exceed CMS2 and CMS3, then site specific spectra should be developed at the surface elevation and compared to the System 80+ envelope of surface spectra.*

## SITE ACCEPTANCE CRITERIA FOR CONTROL MOTION

- Compliance with SRP (Section 2.5.2.6, Rev. 2)

- *CMS1 complies with 2.5.2.6 Item 3b.*

*'Where only estimates of peak ground acceleration are available, it is acceptable to select a peak ground acceleration and use this acceleration as the high frequency asymptote to standardized response spectra such as described in Regulatory Guide 1.60''*

- *CMS2 and CMS3 comply with 2.5.2.6 Item 1:*

*'Both horizontal and vertical component site-specific spectra should be developed statistically from response spectra or recorded strong motion records...''*

*"An 84th percentile response spectrum for the records should be presented for each damping value of interest and compared to the SSE free-field and design response spectrum."*

- *CMS2 and CMS3 also comply with 2.5.2.6 Item 3a.*

*'If strong motion records are not available, site specific peak ground acceleration, velocity, and displacement (if necessary) should be determined for appropriate magnitude, distance, and foundation conditions. Then response spectra may be determined by scaling the acceleration, velocity and displacement values by appropriate amplification factors (NUREG/CR-0098).''*

## APPLICATION OF CONTROL MOTION TO SEISMIC SSI ANALYSES

- Computation of Site Response
  - *CMS2 is applied at the rock outcrop for each soil case  
Motion (S) at the ground surface is obtained through  
convolution.  
Strain-iterated properties are computed for each soil case  
and used as standard in all SSI analyses*
  - *CMS3 is applied at the rock outc. op for each case  
Motion (S) at the ground surface is obtained through  
convolution.  
Use standard strain-iterated properties from CMS2  
analysis.*
- Soil-Structure Interaction Analysis
  - *Use SASSI methodology*
  - *Input motion is applied at ground surface  
For CMS2 and CMS3, surface motion (S) is provided as  
input motion  
CMS1 is directly applied at the free-field ground surface*




Figure 3.1 - Outline of Application of Control Motions CMS2 and CMS3 in SSI Analyses





Figure 3.2 - Outline of Application of Control Motion CMS1 in SSI Analyses



Amendment I  
December 21, 1990

**SYSTEM 80+**™

COMPARISON OF 2% H+V RESPONSE SPECTRA  
(SSE, IIS, NODE 210, 0-180 DIRECTION)

Figure

3.7B-7

## CONCLUSIONS

- Control motions developed qualify the System 80+ standard plant for the majority of sites in the U.S.
- Control motions and use in SSI analyses are in full compliance with SRP
- Control motions provide conservatism beyond minimum SRP guidance since for shallow and rock sites, they are rich in high frequency content (characteristic of Eastern North America motions).

## Mass Model


### Translational Masses

- building structure
- equipment
- piping

### Center of Mass

### Mass Moment of Inertia






270°

DIVISION 2 | DIVISION 1

SYSTEM 80+™



# Stiffness Properties


Axial Area and Centroid

Moment of Inertia


Shear Center

Shear Area

Torsional Constant




STICK MODEL OF INTERNAL STRUCTURE



ANSYS Axisymmetric Containment Model

SYSTEM 80+™



SEISMIC DESIGN AND ANALYSIS  
OF THE  
SYSTEM 80+ CATEGORY I STRUCTURES

Prepared by:

ABB COMBUSTION ENGINEERING

April 28, 1992

SYSTEM 80+<sup>TM</sup>

## AGENDA

- DEVELOPMENT OF DYNAMIC MODEL
- ANALYSIS METHOD AND  
GENERATION OF FLOOR RESPONSE SPECTRA




## DEVELOPMENT OF DYNAMIC MODEL

- Methodology and Assumptions
- Preliminary Model
- Final Model

## METHODOLOGY AND ASSUMPTIONS

## GENERAL ANALYSIS APPROACH




## STRUCTURAL MODEL DEVELOPMENT

- DEVELOPMENT OF 3-D FEM
  - STEEL CONTAINMENT VESSEL (SCV)
  - CONCRETE SHIELD BUILDING (SB)
  - INTERNAL STRUCTURE (IS)
  
  - MASSES
  - MODAL ANALYSIS
  
- DEVELOPMENT OF EQUIVALENT 3-D STICK MODEL
  - COMPUTATION OF TORSIONAL CONSTANT AND CENTER
  - COMPUTATION OF SHEAR AREAS AND MOMENTS OF INERTIA
  
- FIXED-BASE NATURAL FREQUENCIES
  
- EVALUATION OF MEMBER FORCES IN FEM


## DEVELOPMENT OF 3-D FEM

- STEEL CONTAINMENT VESSEL

- SSI SEISMIC ANALYSIS



- DETAILED CONTAINMENT ANALYSIS




## DEVELOPMENT OF 3-D FEM

- **SHIELD BUILDING**
  - AXISYMMETRIC SHELL ELEMENTS
  
- **INTERNAL STRUCTURE**
  - SELECT MAJOR ELEVATIONS BASED ON:
    - FLOORS
    - SIGNIFICANT STIFFNESS DISCONTINUITIES ALONG HEIGHT
  - EACH FLOOR ASSUMED RIGID IN ITS OWN PLANE
  - LOAD RESISTING ELEMENTS (STIFFNESS):
    - CONCRETE WALLS  
(INCLUDE OUTSIDE WALLS FROM GROUND LEVEL TO BASEMAT)  
USE QUADRILATERAL SHELL ELEMENTS
    - MASSIVE CONCRETE WALLS NEAR REACTOR CAVITY  
USE 8-NODE SOLID ELEMENTS
    - NARROW WALLS, WALLS WITH LARGE OPENINGS  
USE 3-D BEAM ELEMENTS
    - SLABS OF SIGNIFICANT THICKNESS  
USE QUADRILATERAL SHELL ELEMENTS
  - BASEMAT MODELED RIGID (10 ft. THICK)

## DEVELOPMENT OF EQUIVALENT 3-D BEAM STICK MODEL

### SHIELD BUILDING

- LUMP MASSES AT NODAL POINTS ALONG HEIGHT OF STICK
- DETERMINE  $I_{xx}$ ,  $I_{yy}$ ,  $J$ ,  $A_x$ ,  $A_y$ ,  $A_z$ , BASED ON MODAL ANALYSIS



Stick Model of Shield Building




Figure 220.16-1 - Detailed Axisymmetric Model of Shield Building



## DEVELOPMENT OF EQUIVALENT 3-D BEAM STICK MODEL

### INTERNAL STRUCTURE

#### COMPUTE TORSIONAL CONSTANT J AND TORSIONAL CENTER ( $e_x$ , $e_y$ )

- ISOLATE EACH SECTION OF FEM MODEL
- CONSTRAIN TOP AND BOTTOM BOUNDARIES IN-PLANE (X, Y, ZZ); ALLOW SECTION TO WARP (XX, YY, Z FREE)
- APPLY TORQUE; MEASURE TORSIONAL ROTATIONS
- COMPUTE J
- DETERMINE TORSIONAL CENTER  $e_x$ ,  $e_y$


## DEVELOPMENT OF EQUIVALENT 3-D BEAM STICK MODEL

- COMPUTE SHEAR AREAS  $A_x$ ,  $A_y$ , AND MOMENTS OF INERTIA  $I_{xx}$ ,  $I_{yy}$ 
  - DEVELOP SEPARATE CANTILEVER MODEL FOR EACH FLOOR OF THE FEM
  - MULTIPLE SUPERIMPOSED SECTIONS OF A SINGLE FLOOR
  - CHOOSE LONG CANTILEVER (MAXIMIZING BENDING DEFORMATION) TO COMPUTE MOMENTS OF INERTIA  $I_{xx}$ ,  $I_{yy}$
  - CHOOSE SHORT CANTILEVER (MAXIMIZING SHEAR DEFORMATION) TO COMPUTE SHEAR AREAS  $A_x$ ,  $A_y$
  - FREE END OF CANTILEVER CONSTRAINED IN ALL 6 DOF
  - APPLY MOMENTS  $M_x$ ,  $M_y$  AT FREE END
  - COMPUTE  $I_{xx}$ ,  $I_{yy}$  BASED ON TOP LATERAL DISPLACEMENT
  - COMPUTE CENTROID OF AXIAL AREA ( $d_x$ ,  $d_y$ ) BASED ON VERTICAL EDGE DISPLACEMENTS AT TOP
  - APPLY FORCES  $P_x$ ,  $P_y$  AT TORSIONAL CENTER ( $e_x$ ,  $e_y$ )
  - COMPUTE  $A_x$ ,  $A_y$  BASED ON LATERAL DISPLACEMENT AT TOP;  
SUBTRACT DISPLACEMENT DUE TO BENDING DEFORMATION

# DEVELOPMENT OF EQUIVALENT 3-D BEAM STICK MODEL

## EXAMPLE


### ISOLATED SECTION OF FEM




DEVELOPMENT OF EQUIVALENT 3-D BEAM STICK MODEL

EXAMPLE

UNIFORM-SECTION "LONG" FEM CANTILEVER






THREE DIMENSIONAL MODEL OF INTERIOR STRUCTURE

**Figure 220.16-1 - Detailed 3D Finite Element Model of Internal Structure**

# DEVELOPMENT OF EQUIVALENT 3-D BEAM STICK MODEL


## INTERNAL STRUCTURE STICK MODEL



Stick Model of Internal Structure  
(for Horizontal Analysis)

# DEVELOPMENT OF EQUIVALENT 3-D BEAM STICK MODEL

## NSSS MODEL




## EVALUATION OF MEMBER FORCES IN FEM

- OBTAIN MAXIMUM INTERNAL FORCES OF EACH FLOOR FROM SSI ANALYSIS OF STICK MODEL
- APPLY MAXIMUM FORCES STATICALLY TO EACH ISOLATED FLOOR SECTION OF THE FEM
- COMPUTE INDIVIDUAL MEMBER FORCES



PRELIMINARY MODEL

## FIXED-BASE NATURAL FREQUENCIES



FUNDAMENTAL FREQUENCIES (FIXED BASE; HORIZONTAL DIR.)


### INDIVIDUAL STICKS (STAND ALONE)


SHIELD BUILDING:	7.4 Hz
STEEL CONTAINMENT VESSEL:	5.5 Hz
INTERNAL STRUCTURE:	8.0 Hz
NSSS:	12.5 Hz

COMBINED RB MODEL: 5.6 Hz

FINAL MODEL

SYSTEM 80+™







BASEMAT

ELEVATION 50+0







**SECTION B**  
**90 - 270**









ANALYSIS METHOD AND  
GENERATION OF FLOOR RESPONSE SPECTRA


- PRELIMINARY SEISMIC SSI ANALYSIS
- FINAL SEISMIC SSI ANALYSIS

PRELIMINARY SEISMIC SSI ANALYSIS


## SEISMIC SSI ANALYSIS

- SITE PLAN AND ELEVATION
- ANALYSIS FEATURES
- SASSI METHODOLOGY
  - SITE RESPONSE
  - COMPUTATION OF FOUNDATION IMPEDANCES
  - STRUCTURAL MODEL
  - COMPUTATION OF STRUCTURAL RESPONSE AND GENERATION OF RESPONSE SPECTRA
- ANALYSES CASES
- SSE RESULTS
- OBE RESULTS
- COMMON BASEMAT ANALYSIS
- CORRELATION OF SHAKE WITH SASSI
- UTILIZATION OF SSI RESULTS

# SITE PLAN AND ELEVATION



PLAN



TYP. SECTION

## ANALYSIS FEATURES


### DESIRED FEATURES:

- THREE-DIMENSIONAL ANALYSIS
- EMBEDMENT EFFECTS
- MULTIPLE FOUNDATIONS; EFFECT OF ADJACENT STRUCTURES
- WAVE SCATTERING AND RADIATION DAMPING

# SASSI METHODOLOGY

## SITE RESPONSE

- SITE CONSISTS OF HORIZONTAL SOIL LAYERS OVERLYING BEDROCK
- HORIZONTAL ANALYSIS: VERTICALLY PROPAGATING S -WAVES
- VERTICAL ANALYSIS: VERTICALLY PROPAGATING P-WAVES
- CONTROL MOTION SPECIFIED AT GROUND SURFACE
- MODULE SITE







# SASSI METHODOLOGY

GENERAL SUBSTRUCTURING APPROACH FORMULATED IN THE FREQUENCY DOMAIN USING COMPLEX RESPONSE AND FINITE ELEMENT METHOD.


AXISYMMETRIC CAPABILITIES FOR COMPUTATION OF FOUNDATION IMPEDANCES




## SASSI METHODOLOGY

### COMPUTATION OF FOUNDATION IMPEDANCES

- AXISYMMETRIC MODEL OF REACTOR BUILDING FOUNDATION, FOUNDATION OF ADJACENT BUILDINGS AND NEAR-FIELD SOIL
- AXISYMMETRIC SOLID ELEMENTS CONNECTED TO SEMI-INFINITE LAYERED ZONES REPRESENTED BY AXISYMMETRIC TRANSMITTING BOUNDARIES
- MODULE HOUSE:
  - FORMS STIFFNESS AND MASS MATRICES OF FOUNDATIONS, NEAR-FIELD SOIL
- MODULE AXSYS:
  - FORMS TOTAL STIFFNESS OF COMPLETE FOUNDATION/SOIL SYSTEM
  - COMPUTES DYNAMIC FLEXIBILITY MATRIX AND SCATTERING PROPERTIES
  - INVERTS DYNAMIC FLEXIBILITY MATRIX TO OBTAIN IMPEDANCES
  - TRANSFORMS IMPEDANCES TO CARTESIAN COORDINATES



Axisymmetric Transmitting Boundaries for Impedance Analysis




Axisymmetric Finite Element Mesh for the Near-Field Soil and Foundations

## SASSI METHODOLOGY

### STRUCTURAL MODEL


- STICK MODEL OF SCV, SB, IS AND NSSS MODEL
- STICK MODEL OF ADJACENT BUILDINGS
- NSSS MODEL ATTACHED TO STICK MODEL OF INTERNAL STRUCTURE
- MOD. ELEM. USE FORMS STIFFNESS AND MASS MATRICES OF BUILDING STICK MODELS AND NSSS MODEL




## SASSI METHODOLOGY

### COMPUTATION OF STRUCTURAL RESPONSE


- USE SOIL IMPEDANCES, MASS AND STIFFNESS MATRICES OF STICK & NSSS MODELS
- GENERATE TRANSFER FUNCTIONS AT SELECTED LOCATIONS
- PERFORM INTERPOLATION OF TRANSFER FUNCTIONS OVER FREQUENCY RANGE OF ANALYSIS.
- COMPUTE FFT OF CONTROL MOTION. MULTIPLY FFT OF CONTROL MOTION WITH TRANSFER FUNCTION. RETURN TO TIME DOMAIN THROUGH INVERSE FFT.
- GENERATE RESPONSE ACCELERATION TIME HISTORIES
- COMPUTE RESPONSE SPECTRA.




SITE RESPONSE



FINITE ELEMENT MODEL OF FOUNDATION + SOIL (AXISYMMETRIC)




FINITE ELEMENT MODEL OF SUPERSTRUCTURES (FULL 3-D)





CASE 1: Z-DIR MOTION  
CASE 2: X-DIR MOTION  
CASE 3: Y-DIR MOTION




COMPARISON OF INPUTS AND SELECTION OF CASE FOUNDATIONS  
TAPE 1 = TAPE 1(1)  
TAPE 2 = TAPE 2(1)  
TAPE 10 = TAPE 1(2)  
TAPE 4 = TAPE 4(1)  
TAPE 3 = TAPE 4(2)  
ANALYSIS



TAPE 5 = TAPE 5 (ALL CASES)  
CASE 1: Z-DIR TAPE 10 = TAPE 10 (Z-DIR)  
CASE 2: X-DIR TAPE 10 = TAPE 9 (X-DIR)  
CASE 3: Y-DIR TAPE 10 = TAPE 4 (Y-DIR)



CASE 1: Z-DIR OUTPUT: TAPE 12(2)  
CASE 2: X-DIR OUTPUT: TAPE 12(X)  
CASE 3: Y-DIR OUTPUT: TAPE 12(Y)



TAPE 7 = TAPE 12(r)  
TAPE 9 = TAPE 12(x)  
TAPE 11 = TAPE 12(z)

AWACC

# ANALYSIS CASES


## SEISMIC SSI ANALYSIS CASES

<u>CASE</u>	<u>SSE</u>	<u>OBE</u>
Fixed-Base	Yes	Yes
B1	Yes	No
B1.5	Yes	No
B2	Yes	No
B3.5	Yes	Yes
B4	Yes	Yes
C1	Yes	No
C1.5	Yes	No
C2	Yes	No
C3	Yes	No



## SSE RESULTS

STRUCTURE	ELEV. (ft.)	NODE NO.	LOCATION	DIRECTIONS (X=0-180, Y=90-270, Z=Vert)
RB FDTN	50.00	131	Center of foundation	X, Y, Z
SCV	174.37	25	Midheight, 0-180 dir.	X, Y, Z
SCV	174.37	34	Midheight, 90-270 dir.	X, Y, Z
SCV	257.00	6	Top of SCV shell	X, Y, Z
SB	261.88	125	Top of SB shell	X, Y, Z
IS	64.73	141	Second Floor (C.M.)	X, Y, Z
IS	90.25	150	Third Floor (C.M.)	X, Y, Z
IS	91.82	155	SCV Support (C.M.)	X, Y, Z
IS	114.06	169	Fourth Floor (C.M.)	X, Y, Z
IS	142.92	183	Operating Floor (C.M.)	X, Y, Z
IS	207.48	210	Top of Crane Wall (C.M.)	X, Y, Z



CE SYSTEM 80+ SSI - SSE  
 H + V, NODE 131 X-DIR  
 DAMPING = 2 PERCENT





Figure 4.1 - Comparison of 2% Response Spectra  
 (SSE, RB Fdtn, Node 131, 0-180 Direction)



CE SYSTEM 80+ SSI - SSE  
 H + V, NODE 131 Z-DIR  
 DAMPING = 2 PERCENT





Figure 4.2 - Comparison of 2% Response Spectra  
 (SSE, RB Fdtn, Node 131, Vertical Direction)



CE SYSTEM 80+ SSI - SSE  
 H + V, NODE 210 X-DIR  
 DAMPING = 2 PERCENT





Figure 4.3 - Comparison of 2% Response Spectra  
 (SSE, IS, Node 210, 0-180 Direction)



CE SYSTEM 80+ SSI - SSE  
 H + V, NODE 210 Z-DIR  
 DAMPING = 2 PERCENT





Figure 4.4 - Comparison of 2% Response Spectra  
 (SSE, IS, Node 210, Vertical Direction)



CE SYSTEM 80+ SSI - SSE  
 H + V, NODE 125 X-DIR  
 DAMPING = 2 PERCENT





Figure 4.5 - Comparison of 2% Response Spectra  
 (SSE, SB, Node 125, 0-180 Direction)



LE SYSTEM 80+ SSI - SSE  
 H + V, NODE 125 Z-DIR  
 DAMPING = 2 PERCENT




Figure 4.6 - Comparison of 2% Response Spectra  
 (SSE, SB, Node 125, Vertical Direction)




Figure 4.7 - Comparison of 2% Response Spectra  
(SSE, SCV, Node 61, 0-180 Direction)






Figure 4.8 - Comparison of 2% Response Spectra  
 (SSE, SCV, Node 61, Vertical Direction)


## OBE RESULTS

### APPROACH USED:

- PERFORM OBE ANALYSIS FOR B3.5, B4 AND FIXED-BASE CASES
- COMPUTE RATIOS OF SPECTRA FOR B3.5, B4 AND FB
- SELECT GENERIC SCALING FACTORS TO SCALE SSE SPECTRA

### SCALING FACTORS:


Structure	Direction	Factor(s)
PGC Foundation	X, Y, Z	0.4 (all frequencies)
IS (all elevations)	X, Y, Z	0.45 (all frequencies)
SB (all elevations)	X, Y, Z	0.45 (all frequencies)
SCV (all elevations)	X, Y	0.40 for frequencies $\leq$ 5 Hz 0.45 for frequencies $>$ 5 Hz
SCV (all elevations)	Z	0.40 for frequencies $\leq$ 10 Hz 0.65 for frequencies $>$ 10 Hz




CE SYSTEM 80+ SS OBE-SSE RATIO  
 DAMPING=2 PER CENT. NODE 210 X-DIR  
 SOLLID=FIXED-BASE. DASH=1 J. 5. DOUBLE DASH=B4

Figure 4.12 - OBE/SSE Spectral Ratio for 2% damping  
 (IS, Node 210, 0-180 Direction)


# COMMON BASEMAT ANALYSIS




Schematic Representation of PGC Model with Common Basemat





CE SYSTEM 80+ SSI B35 SOIL - SSE  
 NODE 210 X-DIR, DAMP. = 2 AND 5 PERCENT  
 DASHED=COM. BSMT., SOLID=DUAL FNDTN.







CE SYSTEM 80+ SSI B35 SOIL - SSE  
 NODE 210 Z-DIR, DAMP. = 2 AND 5 PERCENT  
 DASHED=COM. BSMT., SOLID=DUAL FNDTN.






CE SYSTEM 80+ SSI B35 SOIL - SSE  
NODE 125 X-DIR. DAMP. = 2 AND 5 PERCENT  
DAS:50=COM. BSMT., SOLID=DUAL FNDTN.






CE SYSTEM 80+ SSI B35 SOIL - SSE  
NODE 61 X-DIR, DAMP. = 2 AND 5 PERCENT  
DASHED=COM. BSMT., SOLID=DUAL FNDTN.







# CORRELATION OF SHAKE WITH SASSI


## FREE FIELD RESPONSE



CE SYSTEM 80+ SSI B35 SOIL MODEL - SSE  
FOUNDATION MOTION AT ELEV 40 FT - Y DIR, 5 P.C. DAMPING  
SOLID=SASSI, DASH=SHAKE



CE SYSTEM 80+ SSI B35 SOIL MODEL - SSE  
FOUNDATION MOTION AT ELEV 40 FT - Z DIR, 5 P.C. DAMPING  
SOLID=SASSI, DASH=SHAKE



## UTILIZATION OF SSI RESULTS

- OBTAIN MAXIMUM INTERNAL FORCES OF EACH BEAM ELEMENT IN THE STICK MODEL.


APPLY MAXIMUM FORCES TO CORRESPONDING ISOLATED FLOOR SECTION OF DETAILED FINITE ELEMENT MODEL. COMPUTE INDIVIDUAL MEMBER FORCES.

- USE SPECTRA FROM EACH CASE TO DESIGN SCV AND INTERNAL REACTOR BUILDING COMPONENTS.
- NSSS ANALYSIS: OBTAIN RESPONSE ACCELERATION TIME HISTORIES AT ATTACHMENT POINTS OF NSSS ON REACTOR BUILDING.

PERFORM TIME-HISTORY ANALYSES OF DETAILED NSSS MODEL (USE THREE BOUNDING CASES FROM SSI ANALYSES).

FINAL SEISMIC SSI ANALYSIS

- **SITE RESPONSE**  
(same as in preliminary SSI analysis)
  
- **COMPUTATION OF FOUNDATION IMPEDANCES**
  - Single embedded rigid foundation with final geometrical configuration (rectangular in shape)
  - SASSI methodology
  
- **STRUCTURAL MODEL**
  - Final dynamic model of Nuclear Island and Annex Structures
  
- **COMPUTATION OF STRUCTURAL RESPONSE AND GENERATION OF RESPONSE SPECTRA**  
(same as in preliminary SSI analysis)



Ground surface

Excavated soil


Rigid foundation

Soil Layers

Bedrock

Ground surface


Rigid foundation




Impedances

Soil Layers

Bedrock







System 80+™


Steel Containment Vessel

Code Design Activities


# Containment Description


## Spherical Steel Containment Vessel (SSCV)

- Free-Standing 200 Ft. Diameter
- Welded Steel Plate Construction - 1 3/4" Thick
- Bottom of Sphere Concrete Encased
- No Structural Connection Between Steel Containment and Concrete
- ASME Section III, Division I, Subsection NE
- Enclosed In a Cylindrically Shaped Concrete Shield Building with Hemispherical Dome
- Large Lower Subsphere Area In Shield Building




SYSTEM 80+™





THREE DIMENSIONAL MODEL  
OF  
STEEL CONTAINMENT

SYSTEM 80+™



THREE DIMENSIONAL MODEL  
OF  
STEEL CONTAINMENT

SYSTEM 80+™

## Containment Technical Data

- Containment

- Containment Type	Steel Sphere
- Steel Type	SA-537 CL. 2
- Internal Diameter	200 Feet
- Wall Thickness	1.75 In.
- Free Volume	$3.34 \times 10^6$ Cu.Ft.
- Design Pressure	49 psig

- Shield Building

- Type	Concrete
- Internal Diameter	210 Feet
- Wall Thickness	3 Ft.

## Design Conditions

### 1) Normal Operating

- Temperature: 110° F
- Pressure: 0 psig

### 2) Inadvertent Spray Actuation

- Temperature: 110° F
- Pressure: 2.0 psig (vacuum)

### 3) Design Basis Accident

- Temperature: 290° F
- Pressure: 49 psig

## SA-537 Class 2 Properties

- E 28,350,000 psi
- $S_{mc}$  22,000 psi
- $S_{m1}$  26,700 psi
- $S_y$  52,480 psi
- $S_u$  80,000 psi

All values are calculated at the Design  
Temperature



## Codes and Standards

- 1989 ASME Boiler & Pressure Vessel Code  
Section III, Division I, Subsection NE  
"Class MC Vessels"
- Standard Review Plan (NUREG-0800)
- Regulatory Guide 1.57  
( Steel Containment)
- Regulatory Guide 1.61  
(Damping)
- Regulatory Guide 1.84  
(Code Cases)
- Regulatory Guide 1.92  
(Modal Combinations)
- 10 CFR50 (General Design Criteria)

## Containment Analysis

Analysis Performed for:

- Service Loads
- Stability (Buckling), Considering Vacuum Pressures
- Ultimate Capacity (Hydrogen Burn)
- ASME Code Calculation for Penetration Area Replacement
- Attachments
- Construction Loading

## Containment Design Bases

Design Conditions Consider the Effects of :

- Dead/Live Loads
- Pressure/Temperature
- Mechanical/Electrical/Attachment Loads
- Natural Phenomena Loads (earthquake, tornado, etc.)
- Pipe Whip/Jet Impingement/Missiles
- Hydrodynamic Loads
- Construction

## Design Loadings

- D - dead loads
- L - live loads
- $P_t$  - test pressure loads
- $T_t$  - test thermal loads
- $P_o$  - normal operating pressure loads
- $R_o$  - normal operating piping loads
- $T_o$  - normal operating thermal loads
- $P_e$  - vacuum pressure loads
- $R_e$  - vacuum piping loads
- $T_e$  - vacuum thermal loads
- E - operating basis earthquake loads
- E' - safe shutdown earthquake loads
- $P_a$  - accident pressure loads
- $R_a$  - accident piping loads
- $T_a$  - accident thermal loads
- $Y_r$  - pipe rupture loads
- $Y_j$  - jet impingement loads
- $Y_m$  - missile loads

## Detailed Loading Combinations:

- Testing Conditions

$$D + L + P_t + T_t$$

- Design Conditions

$$D + L + P_a + T_a + R_a$$

- Level A Service Limits

$$D + L + P_a + T_a + R_a$$

- Level B Service Limits

$$D + L + P_a + T_a + R_a + E$$

- Level C Service Limits

$$D + L + P_a + T_a + R_a + E'$$

- Level D Service Limits

$$D + L + P_a + T_a + R_a + Y_r + Y_j + Y_m + E'$$


- Stability Considerations

$$D + L + P_e + T_e + R_e + E$$


$$D + L + P_e + T_e + R_e + E'$$

## Service Load Analysis

- Finite Element Method
- Thin Shell Theory
- Linear Elastic
- Three Dimensional Analysis
- ANSYS Computer Code



**SYSTEM 80+™  
THREE DIMENSIONAL MODEL  
OF STEEL CONTAINMENT**



**SYSTEM 80+™**  
**THREE DIMENSIONAL MODEL**  
**OF STEEL CONTAINMENT**



TABLE 3.8.2-3

STRESS INTENSITY LIMITS FOR STEEL CONTAINERS

Load Categories		PRIMARY STRESSES		BENDING & LOCAL MEM. $P_d + P_L$ (4)	PRIMARY & SECONDARY $P_L + P_d + Q$	PEAK STRESSES $P_L + P_d + Q + F$	BUCKLING
		Gen. Mem. $P_m$	Local Mem. $P_L$				
Testing Condition	Pneumatic	$0.75S_y$	$1.55S_y$	$1.55S_y$	N/A (2)	Consider for (5) fatigue evaluation	See (9)
Design Condition		$1.0S_{mC}$	$1.55S_{mC}$	$1.55S_{mC}$	N/A	N/A	See (9)
Level A Service Limit (1)		$1.0S_{mC}$	$1.55S_{mC}$	$1.55S_{mC}$	$3.0S_{mL}$	Consider for fatigue evaluation	See (9)
Level B Service Limit		$1.0S_{mC}$	$1.55S_{mC}$	$1.55S_{mC}$	$3.0S_{mL}$	Consider for fatigue evaluation	See (9)
Level C Service Limit	Not integral and Continuous	$1.0S_{mC}$	$1.55S_{mC}$	$1.55S_{mC}$	$3.0S_{mL}$	N/A	See (9)
	Integral and Continuous (4) (7)	$1.25S_{mC}$ or * $1.0S_y$	$1.85S_{mC}$ or * $1.55S_y$	$1.85S_{mC}$ or * $1.55S_y$ (8)	N/A	N/A	See (9)
Level D Service Limit	Not integral and Continuous	$1.25S_{mC}$ or * $1.0S_y$	$1.85S_{mC}$ or * $1.55S_y$	$1.85S_{mC}$ or * $1.55S_y$ (8)	N/A	N/A	See (9)
	Excl. An. (3) Integ. & Cont.	$S_T$	$1.55S_T$	$1.55S_T$	N/A	N/A	See (9)
	Incl. An. (3)	$S_T$	$S_T$	$S_T$			
Post-Flooding		$1.25S_{mC}$ or * $1.0S_y$	$1.85S_{mC}$ or * $1.55S_y$	$1.85S_{mC}$ or * $1.55S_y$	$3.0S_{mL}$	N/A (2)	See (9)

NOTES:

- (1) The allowable stress intensity  $S_{mL}$  shall be the  $S_m$  listed in Tables I-1.0 and the allowable stress intensity  $S_{mC}$  shall be the  $S_m$  listed in Tables I-10.0 of Appendix I of the ASME Code.
- (2) N/A = No evaluation required.
- (3)  $S_T$  is 85% of the general primary membrane allowable permitted in Appendix I. In the application of the rules of Appendix F,  $S_{mL}$ , if applicable, shall be as specified in Tables I-1.0.
- (4) Those limits identified by the asterisk (\*) indicate a choice of the larger of the two limits.
- (5) The number of test sequences shall not exceed 10 unless a fatigue evaluation is considered.
- (6) Values shown are for a solid rectangular section. See ME-3220 for other than a solid rectangular section.
- (7) These stress intensity limits apply to the partial penetration welds also.
- (8) Values shown are applicable when  $P_L < 0.67S_y$ . When  $P_L > 0.67S_y$ , use the larger of the two limits,  $[2.5 - 1.5(P_L/S_y)]1.25S_{mC}$  or  $[2.5 - 1.5(P_L/S_y)]1.55S_y$ .
- (9) It must be demonstrated that any axisymmetric techniques proposed are applicable to a vessel having large axisymmetric openings, and that the overall margin of safety to prevent buckling is adequate.


Containment Allowable Stress Intensities for SA537 Class 2 Steel

Load Categories		Primary Stresses		Bending &	Primary &
		Gen. Mem. $P_m$	Local Mem. $P_L$	Local Mem. $P_b + P_L$	Secondary $P_L + P_b + Q$
Testing Condition	Pneumatic	44250	67850	67850	N/A
Design Condition		22000	33000	33000	N/A
Level A Service Limit		22000	33000	33000	90100
Level B Service Limit		22000	33000	33000	80100
Level C Service Limit	Not Integral and Continuous	22000	33000	33000	80100
	Integral and Continuous	52480	78720	78720	N/A
Level D Service Limit	Not Integral and Continuous	52480	78720	78720	N/A
	Integral & Elastic An.	47600	71400	71400	
	Cont. Inelastic An.	47600	47600	47600	

NOTE: All values are given in pounds per square inch.

## Stability Analysis

- ASME Code Article NE-3222
- ASME Code Case N-284
- Linear Elastic Bifurcation Analysis
- Capacity Reduction Factors
- Three Dimensional Analysis
- ANSYS Computer Code



**SYSTEM 80+™ STEEL CONTAINMENT  
STABILITY ANALYSIS**

# SYSTEM 80+ CONTAINMENT STABILITY SAFETY FACTORS

Stability Safety Factor = Capacity Reduction Factor X Load Factor

## Minimum

Normal Operating - 3.0

Design Bases Accidents - 2.0

## Actual

Normal Operating - 3.039

Design Bases Accidents - 2.385

# CONTAINMENT STABILITY SAFETY FACTORS

## ASME NE-3222

Design, Level A and B - 3.0

Level C - 2.5

Level D - 2.0

## ASME Code Case N-284 With Capacity Reduction Factor

Design, Level A and B - 2.0

Level C - 1.67

Level D - 1.34

## ASME NE-3131 And Standard Review Plan 3.8.2

Refers To NE-3200

## Regulatory Guide 1.57

All Stability Design Loads - 2.0

## Capacity Reduction Factors

- Code Case N-284
  - External Pressure: 0.124
- Funahashi, Mieda, Oyamada, Nagashima and Freiman<sup>1</sup>
  - Lateral Force: 0.47
  - Vertical Compressive Force: 0.40
  - Vertical Tensile Force: 0.52

<sup>1</sup> "Study of Spherical Steel Shell Buckling," 10th SMIRT, Los Angeles, CA, August 1989.

## CAPACITY REDUCTION FACTOR LITERATURE SEARCH

Early investigators quickly realized experimental critical buckling stress values were considerably lower than the theoretical values. "They found that the measured buckling pressure was approximately one-fourth of the theoretical value and in addition that buckling was confined to a small dimple, whereas the theory predicted that it would extend all over the shell."

Kaplan, A., "Buckling Of Spherical Shells," in Thin-Shell Structures, Theory, Experiment, and Design, Edited By Y. C. Fung and E. E. Sechler, Prentice-Hall, Inc., Englewood Cliffs, N.J., 1974, Pg. 248.

"When tests were carried out on thin shell structures in the early 1900's, the classical theory became suspect because then actual buckling loads were frequently found to be as little as one-quarter of the classical load."

Hutchison, J. W., Koiter, W. T., 1971. "Postbuckling Theory," in Applied Mechanics Reviews, 23:1354.



## Other References:

Danielson, D. A., "Theory of Shell Stability," Thin Shell Structures, Fung, Y. C. , and Sechler, E. E. (Editors), Prentice Hall, 1974.

Seide, P., "A Reexamination of Koiter's Theory of Initial Postbuckling Behavior and Imperfection Sensitivity of Structures," Thin Shell Structures, Fung, Y. C. and Sechler, E. E. (Editors), Prentice Hall, 1974.

Bushnell, D., "Bifurcation Phenomena in Spherical Shells under Concentrated and Ring Loads," AIAA J., 5:11, November 1967, pp. 2034-2040.


Sechler, E. E., "The Historical Development of Shell Research and Design," in Thin-Shell Structures, Theory, Experiment, and Design, edited by Y.C. Fung and E. E. Sechler, Prentice-Hall, Englewood Cliffs, N.J., 1974, pp. 3-25.

Seide, P., Weingarten, V., Masri, S., "Buckling Criteria and Application of Criteria To Design of Steel Containment Shell," NUREG/CR-0793

Funahashi, Naruse, Mieu. , Oyamada, Kume, Nagashima, Freiman, "Study of Spherical Steel Shell Buckling," from Transactions of the 10th International Conference on Structural Mechanics in Reactor Technology, 1989, Volume J, pp. 79-84.

## Ultimate Capacity Analysis


- Nonlinear Elastic-Plastic
- Large Displacements
- Small Strains
- Bi-Linear Stress-Strain Curve
- Axisymmetric Analysis
- ANSYS Computer Code



FOR ILLUSTRATION  
PURPOSES ONLY

ULTIMATE CAPACITY MODEL


SYSTEM 80+™




ANSYS Axisymmetric Containment Model

SYSTEM 80+™

# SA-537 Cl. 2 Stress-Strain Curve for ANSYS





ANSYS 4.2B  
MAR 15 1989  
17:06:11  
PLOT NO. 12  
POST26

ZV=1  
DIST=1.43

C-E/DOE ALWR SCV ULTIMATE CAPACITY ANALYSIS


## ASME Code Calculations for Penetration Area Replacement

- Meets requirements of Section III, Subsection NE
- 12" - 54" diameter sleeves for mechanical and electrical penetrations
- Equipment hatch and personnel airlocks

## Attachment Analysis

- S/R for piping, HVAC or cable tray
- Applied force and moment unit loads
- Stress intensity for any combination of forces and moments calculated and compared to allowable margin





FINITE ELEMENT MODEL  
ATTACHMENT ANALYSIS

SYSTEM 80+™

## Construction Loading Analysis

- Lifting / supporting pre-assembled sections of steel containment vessel
- Dead weight of vessel
- 110 MPH Wind Load on partially erected vessel
- Support of Shield Building formwork and concrete


## Considerations for Physical Testing

- Choice of Model Scale
- Construction Tolerances  
(geometric imperfections)
- Material Flaws (non-linearities)
- Loading Method and Path Affects Results
- Expensive

# SYSTEM 80+™ CONTAINMENT

MARGIN BEYOND DESIGN BASES

## COMPARISON OF CALCULATED SPECTRA (CMS2) TO R.G. 1.60



### HORIZONTAL MOTIONS AT FOUNDATION LEVEL

Spectral Acceleration @ Containment Fundamental Frequency - 5.54 Hz

0.6 R.G. 1.60 (0.3g) - 0.51g

CMS2 (0.3g) - 1.1g

Equivalent R.G. 1.60 Required to Produce 1.1g Motion at Foundation Level

$$\frac{1.1g}{0.51g} \times 0.3g = 0.65g$$

# SYSTEM 80+™ CONTAINMENT

## MARGIN BEYOND DESIGN BASES

### COMPARISON TO YIELD STRESS

#### Additional Capacity Available

$$S_y - (S_{DW} + S_{P(49)} + S_{THERMAL})$$

#### SSE Stress per g at Foundation

$$S_{SSE}$$

#### Foundation Input to Reach Yield

$$\frac{S_y - (S_{DW} + S_{P(49)} + S_{THERMAL})}{S_{SSE}} \times g @ \text{ foundation}$$

Most Highly Stressed Element Determined From CMS2 Input Value of 1.1 g

$$\frac{S_y - (S_{DW} + S_{P(49)} + S_{THERMAL})}{S_{SSE}} \times 1.1 g = 2.07 g$$

#### Rock Outcrop Input Required to Reach Yield with CMS2

$$2.07 g \times \frac{0.3 g @ \text{ rock outcrop}}{1.1 g @ \text{ foundation}} = 0.57 g$$

#### Free Field Input Required to Reach Yield with RG 1.60

$$2.07 g \times \frac{0.3 g @ \text{ free field}}{0.51 g @ \text{ foundation}} = 1.22 g$$