



3150 ALMADEN EXPRESSWAY, SUITE 145 • SAN JOSE, CALIFORNIA 95118 • (408) 978-8200 • FAX: (408) 978-8964

FOSSIL PLANT OPERATIONS • 66 SO. MILLER RD. • AKRON, OHIO 44333 • (216) 864-8886 • FAX: (216) 864-5705

9206160280 920612
PDR ADDCK 05000313
P PDR

Report No.: SIR-92-037
Revision No.: 0
Project No.: ANO-01Q
June 1992

ASME Code Case N-481
Evaluation of Arkansas Nuclear One
Unit 1 Reactor Coolant Pumps

Prepared for:
Entergy Operations

Prepared by:
Structural Integrity Associates, Inc.

Prepared by: *N. G. Cofie*
N. G. Cofie

Date: 6/8/92

Reviewed by: *J. F. Copeland*
J. F. Copeland

Date: 6-8-92

R. A. Mattson
R. A. Mattson

Date: JUNE 8, 1992

Approved by: *P. C. Riccardella*
P. C. Riccardella

Date: 6/8/92



Table of Contents

| <u>Section</u> | | <u>Page</u> |
|----------------|--|-------------|
| 1.0 | INTRODUCTION | 1-1 |
| 1.1 | Background | 1-1 |
| 1.2 | Description of Pump Casings | 1-1 |
| 1.3 | Objective and Organization | 1-2 |
| 2.0 | PREVIOUS INSPECTIONS | 2-1 |
| 2.1 | 1986 Inspection | 2-1 |
| 2.2 | 1988 Inspection | 2-2 |
| 2.3 | 1992 Inspection | 2-4 |
| 2.4 | Disposition of Flaws | 2-4 |
| 3.0 | BACKGROUND ON ASME CODE CASE N-481 | 3-1 |
| 4.0 | ASME CODE CASE N-481 EVALUATION | 4-1 |
| 4.1 | Evaluation of Material Properties, Including Fracture Toughness ... | 4-1 |
| 4.2 | Stress Analysis Results | 4-5 |
| 4.3 | Review of Operating History of the Pumps | 4-7 |
| 4.4 | Selection of Locations for Postulating Flaws | 4-7 |
| 4.5 | Postulation of Flaws | 4-9 |
| 4.6 | Determination of Stability of Postulated Flaws | 4-10 |
| 4.7 | Effect of Thermal Embrittlement and Other Degradation Mechanisms that May Degrade Properties of the Pump Casing | 4-14 |
| 5.0 | SUMMARY AND CONCLUSIONS | 5-1 |
| 6.0 | REFERENCES | 6-1 |

APPENDIX A ASME Code Case N-481

APPENDIX B pc-CRACK Output - Stress Intensity Factors

APPENDIX C pc-CRACK Output - Fatigue Crack Growth

List of Figures

| <u>Figure</u> | <u>Page</u> |
|---|-------------|
| 1-1 Typical Casing - Cross Section | 1-3 |
| 1-2 Typical Casing - Horizontal Section | 1-3 |
| 1-3 Schematic Drawing Showing Pump Casing Welds for ANO-1 Reactor Coolant Pump | 1-4 |
| 2-1 Schematic Drawing of Weld Flaws in Arkansas Nuclear One "A" and "B" Reactor Coolant Pumps, Unit 1 | 2-5 |
| 2-2 Byron-Jackson Reactor Coolant Pump Weld and Base Material Thickness with Lower Scroll Weld Flaw Indication - ANO-1 "B" RCP - 1988 UT Exam | 2-6 |
| 2-3 ANO-1 1988 UT Exam of "B" RCP Lower Scroll Weld Indication - Section View | 2-7 |
| 2-4 ANO-1 1988 UT Exam of "B" RCP Lower Scroll Weld Indication - Plan View | 2-8 |
| 2-5 Byron-Jackson Reactor Coolant Pump Weld and Base Material Thickness with Upper Scroll Weld Flaw Indication - ANO-1 "B" RCP - 1988 UT Exam | 2-9 |
| 2-6 ANO-1 1988 UT Exam of "B" RCP Upper Scroll Weld Indication - Section View | 2-10 |
| 2-7 ANO-1 1988 UT Exam of "B" RCP Upper Scroll Weld Indication - Plan View | 2-11 |
| 4-1 Effect of Thermal Aging on Room Temperature Impact Energy of CF3, CF8 and CF8M Cast Stainless Steel | 4-22 |
| 4-2 Solution Heat Treated Wrought Type 316 Stainless Steel | 4-23 |
| 4-3 Solution Heat Treated Grade CF8 Stainless Steel Casting | 4-23 |
| 4-4 Effect of Temperature on Charpy Transition Curves of CF3, CF8 and CF8M Steels Aged for 30,000 hours | 4-24 |

List of Figures
(concluded)

| <u>Figure</u> | | <u>Page</u> |
|---------------|---|-------------|
| 4-5 | Correlation Between Fracture Toughness (J_{Ic}) and Charpy Impact Energy for Unaged and Aged Cast Stainless Steels Tested at Room Temperature and 290-320°C | 4-25 |
| 4-6 | Axisymmetric Pump Case Model | 4-26 |
| 4-7 | Three-dimensional Element Map - Top | 4-27 |
| 4-8 | Three-dimensional Element Map - Bottom | 4-28 |
| 4-9 | Typical Section Cuts for Primary Plus Secondary Load Conditions | 4-29 |
| 4-10 | Pump Case Model - Top View | 4-30 |

List of Tables

| <u>Table</u> | | <u>Page</u> |
|--------------|--|-------------|
| 4-1 | Properties of ASTM A351 Grade CF8M | 4-15 |
| 4-2 | Determination of Lower Bound Fracture Toughness of ANO-1 Pump Casings Considering Thermal Embrittlement | 4-16 |
| 4-3 | Stresses at Locations No. 1 and 2 | 4-17 |
| 4-4 | Stresses at Location No. 3 | 4-17 |
| 4-5 | Stresses at Location No. 4 | 4-18 |
| 4-6 | Stresses at Location No. 5 | 4-19 |
| 4-7 | Postulated Flaw Sizes and Locations | 4-20 |
| 4-8 | Comparison of Calculated and Allowable Stress Intensity Factors for Level A and B Conditions | 4-20 |
| 4-9 | Comparison of Calculated and Allowable Stress Intensity Factors for Level C and D Conditions | 4-21 |
| 4-10 | Results of Fatigue Crack Growth Analyses | 4-21 |

1.0 INTRODUCTION

1.1 Background

During the 1992 Arkansas Nuclear One, Unit 1 (ANO-1) refueling outage (1R10), the "D" reactor coolant pump (RCP) was disassembled. The purpose of the disassembly was to inspect the RCP for damage due to a potential motor thrust bearing failure. One of the requirements in the safety evaluation performed by the Office of Nuclear Reactor Regulation (NRR) in April 1989 [1], following the 1988 refueling outage (1R8), is that single-wall radiography (RT) should be performed in the event that any RCPs are completely disassembled for maintenance, repair or examinations. The disassembly of the "D" pump was not a planned outage activity and, therefore, adequate plans had not been made to perform RT on this pump casing. Because of this, Entergy Operations submitted a letter to the NRC [2] to revise the commitment to perform single-wall RT of the pump casing, and instead conduct RCP casing structural integrity examinations and evaluations using the methodology contained in ASME Code Case N-481 [3]. Subsequently, the NRC requested the results of the VT-1 and VT-3 examinations of the "D" RCP. Prior to allowing ANO-1 to return to power operations, the NRC also requested a comparative analysis between the Code Case postulated flaw evaluation and the previous "A" and "B" RCP fracture mechanics and stress evaluations. The results of the VT-1 and VT-3 examinations and scoping evaluation of Code Case N-481 for the ANO-1 pump casing were provided to the NRC in Reference 4.

1.2 Description of Pump Casings

The four reactor coolant pumps at ANO-1 were manufactured by Byron-Jackson. All four pumps were fabricated from ASTM A351-69, Grade CF8M material. Figure 1-1 identifies the various portions of the pump casing. At the bottom of the pump casing is the suction nozzle whose axis of symmetry is an extension of the axis of rotation of the pump shaft. The lower flange occupies the upper end of the suction nozzle, and is marked by a series of

internal steps as shown in Figure 1-1. The upper end of the lower flange blends into the diffuser. The diffuser consists of upper and lower rings separated by vanes. The upper diffuser ring blends into the upper flange. The scroll section is a relatively thin-walled section connecting the upper and lower flanges outside of the diffuser. The scroll forms a spiral around the diffuser as shown in Figure 1-2, starting at the crotch area and terminating at the discharge nozzle.

As shown in Figure 1-3, there are two horizontal welds on the scroll portion of the pump casing (one on the upper end and the other on the lower end). These two welds are joined together by a circumferential or vertical weld near the crotch region.

1.3 Objective and Organization

The objective of this document is to address the safety and serviceability requirements of ASME Code Case N-481 to assure that postulated flaws in the pump casings at critical locations will be stable, considering the operating stresses and material properties of the pump casings. Section 2 of this report discusses previous inspections that have been performed on the pump casings, and the inspection results. Section 3 discusses the background of Code Case N-481, the items covered by the ASME Code Case, and the safety factors used with this Code Case. Section 4 provides the specific evaluation performed using this Code Case. Section 5 presents the conclusions of the evaluation, and Section 6 provides the references used in the evaluation.




Figure 1-1. Typical Case - Cross Section




Figure 1-2. Typical Case - Horizontal Section




Figure 1-3. Schematic Drawing Showing Pump Casing Welds for ANO-1 Reactor Coolant Pump

2.0 PREVIOUS INSPECTIONS

2.1 1986 Inspection

During the 1986 refueling outage, a volumetric examination was performed on the "A" RCP welds, as required by the first 10-year ISI program (based on the requirements of the 1974 Edition through Summer 1975 Addenda of Section XI of the ASME Code), by performing RT examination of the pump casing welds. The RT examination indicated the presence of a flaw which exceeded the ASME Section XI allowable indication standards of IWB-3500 (1980 Edition through Winter 1981 Addenda). The indication is best described as a series of slag inclusions having an effective length (per ASME Section XI criteria) of 5.66 inches. The indication is located in the vertical weld which ties together the upper and lower scroll welds of the pump casing (see Figure 2-1).

Radiographic parallax techniques indicated that the top of the flaw is 1.5 inches below the outside surface of the weld. The weld is approximately 2.6 inches thick in this area. Application of special ultrasonic testing (UT) techniques indicated that the flaw indication does not extend to the internal diameter of the pump casing. Thus, the maximum through-wall dimension of the flaw indication is less than 1.1 inches.

To determine if any flaw existed at this location prior to service, the original construction radiographs were reviewed. The review found five small inclusions that are part of the identified flaw indication of 5.66 inches in length. These inclusions on the original radiograph were determined to be acceptable per the Code during the preservice examinations. Because of the quality of the preservice radiograph in the area of the indication, equipment was brought on-site to perform computer enhancement of the area of the flaw. This process allowed characterization of the flaw on the original film more clearly, and determined conclusively that the current flaw indication and the original flaw were identical.

The original construction radiographs for the remaining three pumps were then reviewed, searching for any preservice flaw indications or weak areas in film density. Identified areas were then computer enhanced in an attempt to identify any unacceptable flaws that were previously unidentified. Portions of approximately 20% of all preservice radiographs were computer enhanced. From this review, the "C" and "D" pumps were determined to have no unacceptable preservice flaw indications. However, the computer enhancement on the "B" pump did indicate an unacceptable flaw indication in the same general weld area as the "A" pump.

The flaw indication on the "B" pump through the computer enhancement process was shown as 1.5 inches in length. The original construction radiograph of this area shows a flaw of 0.625 inches in length which was acceptable per Code requirements at that time. The wall thickness in the area of the flaw indication is 3.1 inches. UT inspection was used in an attempt to better characterize the flaw indication. Due to the material of the pump casing (coarse grained, statically cast stainless steel) and the small size of the indication, UT was not able to specifically characterize the flaw. However, from these examinations, it was determined that the flaw size was no larger than 1.5 inches long by 1.5 inches deep.

2.2 1988 Inspection

Since the 1986 inspection, AP&L, with the assistance of Babcock and Wilcox (B&W), developed a UT procedure for the examination of the pump casing welds from the outside surface. The UT examination of the flaw indication in the "A" pump casing and the entire "B" pump casing welds were performed during the 1988 refueling outage, utilizing the B&W automated ultrasonic data acquisition and imaging system (ACCUSONEX).

A robot was used to perform the ACCUSONEX automated scanning and to provide coordinated data for the transducer location. Using threshold values that just exceeded the average noise level from the pump casing material for both straight beam and angle beam measurements, minimum detectable indications of approximately 1/8 inches wide (through-

wall dimension) and 3/4 inches long through the maximum wall thickness can be detected. The fact that the previous slag indications could not be detected with UT most likely indicates that they are very small, occupy very little volume, and are below the limit of detection for present-day UT technology.

Also, during the 1988 refueling outage, a complete volumetric external surface examination of the "B" RCP casing welds, using double-wall RT and advanced ultrasonic techniques, was performed. The areas of the casing welds examined by RT showed no rejectable indications. Sections of the upper and lower scroll welds near the discharge end of the pump, which could not be successfully radiographed to meet ASME Code film density requirements, along with the remainder of the vertical weld, were examined by UT. In the lower scroll weld, several indications were detected (using ACCUSONEX) in an area bounded by a rectangle with a length of 4.1 inches and a through-wall dimension of 1.8 inches, at a depth of 0.9 inches below the outer weld surface in a region where the weld is 4.75 inches thick. These indications were considered to be slag inclusions located approximately 0.70 inches from the weld centerline. The upper scroll weld could not be examined with ACCUSONEX due to insufficient access for the robot; however, a manual scan was performed which identified three indications. The composite size was conservatively determined to be no larger than a 4.5 inch long by 1.25 inch through-wall dimension at a depth of 1.35 inches from the outside surface. The weld is also 4.75 inches thick in this region. These indications are located approximately on the weld centerline to 0.6 inches from the centerline. The composite indication is also considered to consist of slag inclusions resulting from the original construction welding process and not a service induced condition. Table IWB-3518-2 maximum allowable dimensions for an indication are 1.8 inches for the length and 0.30 inches for one-half the through-wall dimension within the weld. Figures 2-2 through 2-7 show the locations of the lower and upper scroll weld flaw indications found by the UT examinations. The "B" RCP factory radiographs for these areas and the low density radiographs of these areas taken during this outage were computer enhanced. The analysis of these enhanced radiographs showed no rejectable indications in the welds. It was thus concluded that these indications are small preservice slag inclusions.

2.3 1992 Inspection

During the 1992 refueling outage, the "D" RCP casing welds were inspected by visual means. A VT-1 examination was performed on the upper and lower scroll (horizontal) welds and torus (vertical) weld. No indications were identified. A VT-3 examination of the interior surface of the casing also identified no indications. Scratches were found during the VT-3 examination on the wear ring; however, this is not a concern since the wear ring does not function as a pressure boundary. A successful hydrostatic pressure test (and VT-2 examination) was performed on all four RCPs prior to returning the unit to power operation.

Enhanced UT examinations of the areas of interest on the "A" and "B" RCPs were also performed. No new indications were identified and there was no growth in the previously identified 1986 and 1988 flaws. In fact, due to better technology, the previously identified flaws in the "B" RCP have been sized smaller than were previously identified.

2.4 Disposition of Flaws

Conservative fracture mechanics and stress analyses were performed in 1986 and 1988 [5-9] to show that ASME Code Section XI safety margins were satisfied with the observed flaws. The evaluations were based on linear elastic fracture mechanics principles consistent with Appendix A of Section XI of the ASME Code.




Figure 2-1. Schematic Drawing of Weld Flaws in Arkansas Nuclear One "A" and "B" Reactor Coolant Pumps, Unit 1





Figure 2-2. Byron-Jackson Reactor Coolant Pump Weld and Base Material Thickness with Lower Scroll Weld Flaw Indication - ANO-1 "B" RCP - 1988 UT Exam



$l = 4.1$ "
 $2a = 1.8$ " ($a = 0.90$ ")
 $s = 0.90$ "

Figure 2-3. ANO-1 1988 UT Exam of "B" RCP Lower Scroll Weld Indication - Section View




Figure 2-4. ANO-1 1988 UT Exam of "B" RCP Lower Scroll Weld Indication - Plan View





Figure 2-5. Byron-Jackson Reactor Coolant Pump Weld and Base Material Thickness with Upper Scroll Weld Flaw Indication - ANO-1 "B" RCF - 1988 UT Exam



$l = 4.5"$
 $2a = 1.25"$ ($a = 0.625"$)
 $s = 1.35"$

Figure 2-6. ANO-1 1988 UT Exam of "B" RCP Upper Scroll Weld Indication - Section View




Figure 2-7. ANO-1 1988 UT Exam of "B" RCP Upper Scroll Weld Indication - Plan View

3.0 BACKGROUND ON ASME CODE CASE N-481

A review of data collected in EPRI's "Cast Austenitic Stainless Steel Sourcebook" [10] shows that slag inclusions and other fabrication defects, such as those identified during the inspections of the ANO-1 "A" and "B" pump casings, are not uncommon. However, whenever such flaws are identified by surface or volumetric inspection during fabrication, they are usually excavated and weld repaired. Examinations and repairs during the fabrication process are accomplished with relative ease, since they are performed in a shop environment.

Ultrasonic examination and radiography of pump casings, once in service, is very difficult and time consuming. As noted by the NRR in the 1989 Safety Evaluation [1], the disassembly of a reactor coolant pump for the sole purpose of performing a volumetric examination of the pump casing welds is not practical. There is considerable personnel exposure to radiation and significant outage time associated with removal of the pump shaft. The industry operating experience with cast stainless steel pressure components has been good, and furthermore, no detrimental service induced degradation of pump casing welds, detected with various inspection techniques, has been reported.

Because of difficulties associated with the examination of pump casing welds during service, ASME Code Case N-481, shown in Appendix A, addresses examinations and evaluations that may be performed in lieu of the volumetric examinations specified in Table IWB-2500-1 of Section XI, Division 1 of the ASME Code for Examination Category B-L-1. Examination Category B-L-1 relates to pressure retaining welds in pump casings; hence, the application of this code case is limited to the scroll welds, the vertical welds, and the adjacent base metal. Therefore, the vanes and their attachment welds, which are not pressure retaining, are excluded in this evaluation.

In addition to performing visual examinations (VT-1, VT-2 and VT-3), the code case outlines a seven-step evaluation procedure to demonstrate the safety and serviceability of the pump

casings. Key to this procedure is the demonstration that an assumed quarter-thickness flaw, with length six times its depth, will remain stable, considering the stresses and material properties of the pump casings.

The ASME Code Case N-481 evaluation procedure is very similar to that in Appendix G of Sections III and XI of the ASME Code, which provides fracture toughness criteria for protection against failure of reactor pressure vessels, in that a similar postulated flaw is assumed for the analysis in both cases. The Code Case does not provide any guidance on safety factors to be used in the evaluation. Therefore, for the evaluation presented herein, safety factors consistent with Appendix G for similar evaluations of pressure vessels have been used.

Appendix G was first introduced into Section III of the ASME Code in the 1972 Edition, and has remained virtually unchanged through the current 1989 Edition. It was introduced into Section XI of the ASME Code in the 1986 edition with addenda through 1987. Therefore, even though ANO-1 is committed to the 1980 Edition with Winter 1981 Addenda of ASME Code Section XI, the use of the 1989 Edition of the ASME Code is acceptable for this evaluation.

Although Code Case N-481 does not specify that a fatigue crack growth evaluation must be done, and such analyses are not part of an Appendix G evaluation of the stability of a quarter thickness deep flaw, such calculations are done in this study for information purposes.

4.0 ASME CODE CASE N-481 EVALUATION

In this section, the seven items listed in the Code Case, to demonstrate the safety and serviceability of pump casings, are addressed in relation to ANO-1.

4.1 Evaluation of Material Properties, Including Fracture Toughness

The material of the pump casing is ASTM A351 Grade CF8M, an austenitic stainless steel casting specification. The mechanical and physical properties of this material, obtained from the ASME Code [11] used for the Stress Report, are shown in Table 4-1.

A review of the fabrication records indicates that the scroll and the vertical welds were fabricated using either the shielded metal arc welding (SMAW) or submerged arc welding (SAW) process. The records also show that several weld repairs were made during fabrication. After welding, the casings were solution heat treated at 1900-2050°F for ten hours at temperature, followed by quenching in agitated water to below 700°F within five minutes.

The most important material property pertinent to this evaluation is the fracture toughness. The fracture toughness of the base material and the weld metal are addressed separately, since they are affected by different mechanisms. Fatigue crack growth analyses are done for information only, since they are not specifically required to evaluate the large flaws postulated by the code case.

4.1.1 Fracture Toughness of ASTM A351 Grade CF8M

The fracture toughness of cast stainless steels has been the subject of significant research in the U.S. and elsewhere in recent years. Three grades of cast stainless steel frequently used in nuclear power plant applications (CF3, CF8 and CF8M) have all been studied extensively to determine the kinetics and material parameters that control the toughness of these

materials. The major conclusion drawn from most of the work done on these castings is that initially cast, austenitic stainless steels have toughness that is relatively high; however, during service at 550°F they become embrittled with time, which results in a loss of toughness as shown in Figure 4-1.

The microstructure of stainless steel castings is significantly different from that of wrought products. Wrought products consist of a single phase, austenite (γ), as shown in Figure 4-2. Castings on the other hand exhibit a two-phase, or "duplex", microstructure of austenite (γ) and delta ferrite (δ) as shown in Figure 4-3. The ferrite phase in the duplex structure in these castings increases the tensile strength, improves the weldability and soundness of the casting, and increases the resistance to stress corrosion cracking. However, various carbide phases, intermetallic compounds such as sigma and chi phases, and a chromium rich bcc phase (α') can precipitate in the ferrite phase during service at elevated temperatures and lead to substantial degradation in toughness properties. Research performed at the Argonne National Laboratory (ANL) and elsewhere [12-23] has shown that the thermal embrittlement of cast stainless steel components will occur during the reactor lifetime of 40 years.

As a result of such thermal aging embrittlement, the Charpy transition curve shifts to higher temperatures as shown in Figure 4-4. For cast stainless steel of all grades, the extent of thermal embrittlement increases with an increase in ferrite content. The low-carbon CF3 grades are the most resistant and the molybdenum-bearing high carbon CF8M grades are the least resistant to thermal embrittlement.

The embrittlement of cast stainless steels results in brittle fracture associated with either the cleavage of the ferrite or separation of the ferrite/austenite phase boundaries. The degree of embrittlement is controlled by the amount of delta ferrite and the extent of ferrite/austenite phase boundaries. Brittle failure occurs when either the ferrite phase is continuous, such as the case with cast material with a high ferrite content, or the ferrite/austenite phase boundaries provide an easy path for crack propagation. Hence, the amount, size and distribution of the ferrite phase in the duplex microstructure and the

presence of phase boundary carbides are important parameters in controlling the extent of thermal embrittlement.

The kinetics of thermal embrittlement have been explained in detail by Chopra, et al, [12-16]. The kinetics are controlled by several mechanisms that depend on material parameters and aging temperatures. During embrittlement, additional phases are precipitated in the ferrite matrix. These include the formation of a chromium (Cr) - rich α' phase by spinodal decomposition; nucleation and growth of α' ; precipitation of nickel (Ni) - and Silicon (Si) - rich G phase, $M_{23}C_6$ carbide and γ_2 (austenite); and additional precipitation and/or growth of existing carbides at the ferrite/austenite phase boundaries.

The chemical composition of the casting and the ferrite morphology are important parameters to be considered during embrittlement. A procedure and correlations for predicting the fracture toughness of aged, cast stainless steels from known material information is provided by Chopra [24]. The only information required in these correlations is the chemical composition from the certified material test report (CMTR). A correlation for the extent of thermal embrittlement at "saturation" (the minimum impact energy that would be achieved for the material after long term aging) is given in terms of the chemical composition. The extent of thermal embrittlement as a function of time and temperature of reactor service is then estimated from the extent of embrittlement at saturation and from the correlations describing the kinetics of embrittlement, which are also given in terms of the chemical composition. In this evaluation, the fracture toughness associated with the minimum impact energy will be conservatively used.

Using the methodology of Reference 24, the chromium equivalent (Cr_{eq}) and nickel equivalent (Ni_{eq}) are determined from the chemical composition, based on Hull's equivalent factors [25]:

$$Cr_{eq} = (Cr) + 1.21 (Mo) + 0.48 (Si) - 4.99$$

$$Ni_{eq} = (Ni) + 0.11 (Mn) - 0.0086 (Mn)^2 + 18.4 (N) + 24.5 (C) + 2.77$$

where the chemical composition is in wt. %.

The ferrite content (δ_c) is then determined by the relationship:

$$\delta_c = 100.3 (Cr_{eq}/Ni_{eq})^2 - 170.72 (Cr_{eq}/Ni_{eq}) + 74.22$$

For CF8M cast stainless steel, the saturation (minimum) impact energy considering thermal embrittlement is given by:

$$\log_{10} C_{v_{sat}} = 7.28 - 0.011 (\delta_c) - 0.185 (Cr) - 0.369 (Mo) - 0.451 (Si)$$

$$- 0.007 (Ni) - 4.71 (C + 0.4N)$$

Knowing the value of $C_{v_{sat}}$, a lower bound value of J_{Ic} can be determined using the correlation shown in Figure 4-5 [14]. The lower bound value of K_{Ic} used for linear elastic fracture mechanics analysis is determined from J_{Ic} using the relationship:

$$K_{Ic} = \sqrt{\frac{E J_{Ic}}{(1-\nu^2)}}$$

where E is the elastic modulus, and ν is Poisson's ratio.

The above methodology has been used to estimate the lower bound toughness value of the heats of the ANO-1 pump casings [26]. A summary of the results is presented in Table 4-2 and shows that for these CF8M pump casings, the range of J_{Ic} (including long-term aging effects (embrittlement)) is 817-1117 in-lb/in². This minimum value of 817 in-lb/in² translates into a K_{Ic} value of 152 ksi \sqrt{in} at the operating temperature of 550°F.

4.1.2 Fracture Toughness of Pump Casing Weldments

As indicated earlier, the fabrication records indicate that the pump casing weldments were made using flux welding, either by submerged arc welding (SAW) or shielded metal arc welding (SMAW). Extensive work done on the toughness of austenitic stainless steel weldments in References 27 and 28 has shown that the toughness for SAW and SMAW weldments in the unaged condition are lower than for the base material. On the other hand, tungsten inert gas (TIG or GTAW) weldments have toughness more typical of the base metal. The lower toughness of SAW and SMAW weldments is due to nonmetallic inclusions in the weld metal that result from the flux welding process. Limited data from Reference 27 suggests that J_{Ic} values of 1168 and 973 in-lb/in² may be used for SMAW and SAW weldment fracture assessments, respectively, in the as-welded condition. Corresponding values for solution-annealed weldments are 968 and 1260 in-lb/in². Values of 990 and 650 in-lb/in² are suggested in Reference 29 for SMAW and SAW, respectively, based on the work done in Reference 28. Unlike the base cast materials, the fracture toughness of SMAW and SAW weld metals are virtually unaffected by long-term aging [30]. In the safety evaluation performed by NRR in 1989 [1], the lower bound value of 650 in-lb/in² for SAW weldments was recommended for use in any future fracture mechanics evaluations for the ANO-1 pumps. Hence, this lower bound value will be used in this evaluation.

In comparison with the fracture toughness of the ASTM A351 Grade CF8M material, it can be seen that the fracture toughness of the SAW weldment is controlling. The lower bound J_{Ic} value of 650 in-lb/in² translates into a K_{Ic} value of $135.5 \text{ ksi}\sqrt{\text{in}}$ at the operating temperature of 550°F.

4.2 Stress Analysis Results

A Stress Report [31] for the ANO Unit 1 RCPs was prepared in 1973 by the Byron-Jackson/Borg Warner Corporation to meet the requirements of the ASME Code Section III, 1968 [11]. Since the pumps are identical, this Stress Report covers all four pumps. In this

Stress Report, a significant portion of the pump casing was analyzed using a two-dimensional (2D) axisymmetric model. A small portion of the casing near the discharge nozzle was analyzed using a three-dimensional (3D) model. These models are shown in Figures 4-6 through 4-8. Stresses for various load combinations were reported at critical sections for the axisymmetric model, as shown in Figure 4-9.

A supplement to this Stress Report was provided by Babcock and Wilcox to address revised pipe loads [32]. In this analysis, a finite element model of the Byron-Jackson pump casing developed for Consumers Power Corporation's Midland plant in Reference 33 was used as shown in Figure 4-10. The ANO-1 RCPs were found to be sufficiently similar to those at Midland [34], thereby providing justification for the application of the Midland pump casing stress analysis to ANO Unit 1. This revised analysis showed that only very moderate centroidal and surface stresses are produced in the pump casing due to mechanical loadings. The most highly stressed areas for the Design Category loads are the vanes (especially the tips) and the suction and discharge nozzles. This observation suggests that the critical regions on the scroll welds are unaffected by this revised analysis and, therefore, stresses from the original Stress Report [31] are still valid for these locations.

In previous fracture mechanics analyses to disposition the flaws found in 1986 and 1988 [5-9], stress information from the Midland Stress Report was used. Conservative stresses at the flaw locations were used from this report. In the analyses presented herein, stress information contained in the original Byron-Jackson Stress Report, together with stresses at previous flaw locations provided in the Midland Stress Report, were used to perform the fracture mechanics analyses.

In addition to the applied stresses, weld residual stresses need to be addressed in this evaluation. In the evaluation of pressure vessels per ASME Code, Appendix G, residual stresses are not considered, because the vessel is postweld heat treated after welding to minimize the effect of residual stresses. Similarly, since the pump casings were solution heat

treated subsequent to welding and weld repairs, residual stresses are expected to be minimal and are, therefore, not considered in this evaluation.

4.3 Review of Operating History of the Pumps

ANO-1 has been in commercial operation since December of 1974. The plant has undergone ninety-three (93) heatups and ninety-two (92) cooldowns. At this point in time, these numbers are slightly below the expected number of heatup/cooldown cycles considering the design number of heatup/cooldown cycles (240 for a 40-year plant life).

The four RCPs at ANO Unit 1 have experienced essentially the same operating history, since the cold legs are not isolable from the reactor vessel or the steam generators. The normal operating pressure and temperature for the RCPs are 2155 psig and 550°F, respectively. There have been short periods (on the order of 2 to 3 months) of only three pumps operation. These periods involved the "C" and "D" pumps not operating, and would have caused the temperatures through the respective cold legs to be somewhat elevated, but within the operating envelope. ANO is licensed for three pump operation. All other plant transients would have affected all the pumps and all the cold legs equally.

4.4 Selection of Locations for Postulating Flaws

Three criteria were used in selecting flaw locations for this evaluation:

- 1) Fracture Toughness
- 2) Previous Inspection Results
- 3) Stresses.

Since the fracture toughness of the weld material has been shown to be smaller than the base material, even when considering embrittlement, flaw locations were chosen at the welds. Along the welds, areas where slag inclusions have previously been found during inspections

were selected. Hence, all the locations identified on the "A" and "B" RCP vertical and scroll welds in 1986 and 1988 were included in this evaluation. In addition, areas of maximum stress in the scroll welds were chosen. Considering the above criteria, five locations were chosen as described below. Stress and thickness information at these locations are also provided.

Location No. 1

This location corresponds to the location on the vertical weld of the "A" RCP where slag inclusions were identified in 1986. From Reference 5, the thickness of the pump casing at this location is 2.6 inches. The maximum tensile stresses occur for the combination of rapid cooldown, internal pressure, deadweight, preload and 15% thermal expansion load. The maximum compressive stresses occur for a load combination of heatup, internal pressure, deadweight, preload and 15% thermal expansion load. The stresses at this location are shown in Table 4-3. It should be noted that the assumed flaw would be on the inside surface since this is where the maximum tensile stress occurs.

Location No. 2

This location corresponds to the location on the vertical weld of the "B" RCP where slag inclusions were identified in 1986. From References 7 and 8, the thickness at this location is 3.1 inches. Stresses are identical to those at Location No. 1, and are shown in Table 4-3. Also, as at Location No. 1, the flaw was assumed on the inside surface. It should be noted that since stress results reported in References 5 and 6 are the same for both Locations No. 1 and 2, these will also envelope all other stresses in the vertical weld and, as such, further evaluation is not required for the vertical weld.

Location No. 3

This location corresponds to the area on the upper scroll weld on the "B" RCP where slag inclusions were identified in 1988. The thickness at this location was obtained from Reference 9 as 4.75 inches. Stresses at this location, also obtained from Reference 9, are shown in Table 4-4. The assumed flaw in this case would be on the outside surface, since the maximum tensile stress occurs at this surface.

Location No. 4

This location corresponds to the area on the lower scroll weld on the "B" RCP where slag inclusions were identified in 1988. The thickness at this location is also 4.75 inches [9]. Stresses at this location are provided in Table 4-5. Similar to Location No. 3, the assumed flaw will be on the outside surface.

Location No. 5

This location is chosen to correspond to the thickest portion of the horizontal scroll welds. From Reference 35, the maximum thickness of the scroll weld is 5.3 inches. At this location, the maximum stresses from the Stress Report [31] on the weld were used to perform a bounding evaluation. Stresses at this location, obtained from Reference 31, are shown in Table 4-6. The flaw is postulated on the inside surface for the fatigue evaluation.

4.5 Postulation of Flaws

As required by the Code Case, the postulated flaw is a quarter thickness semi-elliptical flaw with length six times the depth. A summary of the flaw dimensions at each location is provided in Table 4-7.

4.6 Determination of Stability of Postulated Flaws

To determine the stability of the postulated flaws, fracture mechanics evaluations are performed at each location to address the following:

- 1) Determination of applied stress intensity factors
- 2) Allowable stress intensity factor
- 3) Fatigue crack growth
- 4) Stress corrosion crack growth.

4.6.1 Determination of Applied Stress Intensity Factors

Even though austenitic stainless steels have been shown to be relatively ductile materials, linear elastic fracture mechanics (LEFM) techniques were conservatively used in lieu of elastic-plastic fracture mechanics (EPFM) techniques.

The stress intensity factors (K_I) associated with the applied stresses were conservatively determined using the flat plate model of ASME Code, Section XI, Appendix A [36]. The expression for K_I is given by:

$$K_I = \sigma_m M_m \sqrt{\pi} \sqrt{a/Q} + \sigma_b M_b \sqrt{\pi} \sqrt{a/Q}$$

where:

- σ_m, σ_b = membrane and bending stresses
- a = minor half-diameter of embedded flaw; flaw depth for surface flaw
- Q = flaw shape parameter
- M_m = correction factor for membrane stress
- M_b = correction factor for bending stress

The above model is contained in the library of Structural Integrity's computer software **pc-CRACK** [37]. This software was, therefore, used to determine the stress intensity factors

at the various locations, using the stress information contained in Tables 4-3 through 4-6. In order to use **pc-CRACK**, the through-thickness stresses are curve fit to a third degree polynomial to determine the membrane and the bending components. The **pc-CRACK** results for the stress intensity factor determination are provided in Appendix B.

4.6.2 Allowable Stress Intensity Factor

Stress intensity factors, for comparison to an allowable value, were calculated consistent with the safety factors provided in Appendix G of Section XI of the ASME Code. Paragraph G-2222 requires a safety factor of 2.0 on primary stresses and a safety factor of 1.0 on secondary stresses for Service Levels A and B.

The terms whose sum must be less than the allowable reference stress intensity factor (K_{IR}) for Levels A and B operating conditions (Service Levels A and B) are:

- 1) $2K_{im}$ for primary membrane stress
- 2) $2K_{ib}$ for primary bending stress
- 3) K_{im} for secondary membrane stress
- 4) K_{ib} for secondary bending stress.

No safety factors are specifically provided for Service Levels C and D, and it is recommended in Appendix G that each situation be studied on an individual case basis. In this evaluation, the safety factors used for Service Levels C and D were taken as $\sqrt{2}$ for primary stresses, and 1.0 for secondary stresses. The safety factor of $\sqrt{2}$ is conservatively taken as that used for flaw evaluations per Paragraph IWB-3610 of ASME Section XI, for ferritic materials.

Tables 4-8 and 4-9 provide the stress intensity factors with the appropriate safety factors for the various locations, and their comparison to the allowable K_{IR} value of $135.5 \text{ ksi}\sqrt{\text{in}}$. The

analysis was performed using the postulated quarter thickness flaw depth. It should be noted that for Locations No. 1 through 4, a safety factor of 2 was conservatively used regardless of whether the stress is primary or secondary. It can be seen that the stress intensity factors at all locations are below the allowable values.

4.6.3 Fatigue Crack Growth

Even though the postulated flaw bounds the maximum expected flaw during the life of the component, fatigue crack growth analyses were performed to assure that crack growth is minimal compared to the postulated flaw. For postulated flaws on the outside surface, the analyses were performed using **pc-CRACK** and the ASME Section XI, Appendix C [36] crack growth law for austenitic stainless steel in an air environment and a temperature of 550°F. A fatigue crack growth law for a water environment is not currently in the ASME Section XI; however, per the recommendation of ASME Section XI Task Group for Flaw Evaluation [38], a factor of 2 was applied to the air environment law to account for the PWR water environment. The ASME Section XI fatigue crack growth law for air is given as:

$$\frac{da}{dN} = C_o(\Delta K_I)^n$$

where n equals 3.3, and

$$C_o = C(S)$$

where C is a scaling parameter to account for temperature, and is given by

$$C = 10^{[-10.009 + 8.12 \times 10^{-4} T - 1.13 \times 10^{-6} T^2 + 1.02 \times 10^{-9} T^3]}$$

T is the metal temperature in °F ($T \leq 800^\circ\text{F}$). S is a scaling parameter to account for the R ratio (K_{min}/K_{max}), and is given by:

$$\begin{aligned}
 S &= 1.0 && \text{when } R \leq 0 \\
 &= 1.0 + 1.8R && \text{when } 0 < R \leq 0.79 \\
 &= -43.35 + 57.97R && \text{when } 0.79 < R \leq 1.0
 \end{aligned}$$

At a temperature of 550°F, and for $R \leq 0$ as in this case, C_o was calculated as 1.84×10^{-10} for an air environment. A value of C_o of 3.68×10^{-10} was, therefore, used for the PWR water environment to determine crack growth for flaws on the inside surface.

Fatigue crack growth analyses were performed for the five locations for a 40-year plant life (240 heatup and cooldown cycles) with an initial quarter thickness flaw. The **pc-CRACK** results for the fatigue crack growth analyses are presented in Appendix C and summarized in Table 4-10. The results show that in comparison to the large initial postulated flaw, fatigue crack growth is relatively small, except for Location No. 5. However, recent inspection results, documented in this report, show that initial fabrication defects in scroll welds have not grown since the start of service, indicating the very conservative nature of these fatigue predictions for large postulated defects.

4.6.4 Stress Corrosion Crack Growth

Stress corrosion cracking (SCC) in pressurized water reactors is not generally of concern, since the environment is not usually conducive to SCC. Moreover, stainless steel castings have been shown to have superior resistance to SCC when compared to wrought products. Because a wrought material consists of a single phase austenite (γ), when such a material is welded, the thermal cycle associated with the welding cause chromium carbides to be precipitated from solution and at austenite-austenite ($\gamma-\gamma$) grain boundaries. The diffusion of chromium from the austenite matrix results in a chromium depleted zone at the grain boundary, resulting in sensitization. On the other hand, when a stainless steel casting (a two-phase duplex microstructure) is exposed to the same thermal cycle, carbon and chromium also combine to form grain boundary carbides; however, these carbides form exclusively at the austenite-ferrite ($\gamma-\delta$) boundaries, with the majority of the chromium diffusing from the

delta ferrite side of the boundary (diffusion of chromium in the ferrite is approximately 1000 times faster than that in austenite at a temperature of 1100°F). Thus, the chromium content of the austenite is not reduced significantly, and corrosion resistance, even near the γ - δ grain boundary, is maintained. Crack growth due to SCC will, therefore, not be considered in this evaluation.

4.7 Effect of Thermal Embrittlement and Other Degradation Mechanisms that May Degrade Properties of the Pump Casing

Structural material degradation mechanisms for various components in light water reactors have been discussed extensively in Reference 39. Of all the degradation mechanisms addressed in this EPRI report, only thermal and irradiation embrittlement could potentially degrade the fracture toughness properties of the cast stainless steel pump casings. Thermal embrittlement effects have been included in the consideration of crack growth and fracture toughness (K_{IR}) properties in this study. Irradiation embrittlement is not of concern since the RCPs are far removed from the reactor core.

Table 4-1

Properties of ASTM A351 Grade CF8M

| Temperature (°F) | E x 10 ⁶ (psi) | σ_y x 10 ³ (psi) | S _m x 10 ³ (psi) | α x 10 ⁻⁶ (in/in/°F) |
|---------------------|------------------------------|---------------------------------------|---|---|
| 70 | 27.4 | 30.0 | 20.0 | 9.11 |
| 200 | 27.1 | 26.0 | 20.0 | 9.50 |
| 300 | 26.8 | 23.6 | 20.0 | 9.73 |
| 400 | 26.4 | 22.2 | 20.0 | 9.96 |
| 500 | 26.0 | 21.8 | 19.6 | 10.20 |
| 600 | 25.4 | 21.2 | 19.1 | 10.43 |
| 700 | 24.9 | 20.5 | 18.4 | 10.66 |

Table 4-2

Determination of Lower Bound Fracture Toughness of ANO-1 Pump Casings
Considering Thermal Embrittlement

| Material Composition | Heat Numbers | | | |
|--|----------------|----------------|----------------|----------------|
| | 6426 Pump A | 6415 Pump B | 6441 Pump C | 6395 Pump D |
| <i>Cr</i> | 18.8 | 18.8 | 18.7 | 19.1 |
| <i>Si</i> | 0.76 | 0.82 | 0.71 | 0.92 |
| <i>Mo</i> | 2.23 | 2.26 | 2.15 | 2.19 |
| <i>Ni</i> | 9.4 | 9.4 | 9.3 | 9.4 |
| <i>C</i> | 0.04 | 0.04 | 0.07 | 0.04 |
| <i>Mn</i> | 0.91 | 0.98 | 0.8 | 1 |
| <i>N</i> | 0.047 | 0.07 | 0.068 | 0.055 |
| <i>Cr_{eq}</i> | 16.9 | 16.9 | 16.7 | 17.2 |
| <i>Ni_{eq}</i> | 14.1 | 14.5 | 15.1 | 14.3 |
| Ferrite (δ_c) | 13.5 | 11.5 | 7.9 | 14.2 |
| <i>Cv_{sat}</i> (J/cm ²) | 140 | 122 | 125 | 102 |
| <i>J_{lc}</i> (in-lb/in ²) | 1117 | 975 | 1001 | 817 |

Table 4-3

Stresses at Locations No. 1 and 2

PROPRIETARY
INFORMATION

Table 4-4

Stresses at Location No. 3

PROPRIETARY
INFORMATION

Table 4-5

Stresses at Location No. 4

PROPRIETARY INFORMATION

Table 4-6

Stresses at Location No. 5¹

PROPRIETARY INFORMATION

Table 4-7

Postulated Flaw Sizes and Locations

| Location | Location of Flaw | Weld Thickness (in.) | Flaw Depth (in.) | Flaw Length (in.) |
|----------|------------------|----------------------|------------------|-------------------|
| 1 | Inside | 2.60 | 0.65 | 3.9 |
| 2 | Inside | 3.10 | 0.775 | 4.65 |
| 3 | Outside | 4.75 | 1.1875 | 7.125 |
| 4 | Outside | 4.75 | 1.1875 | 7.125 |
| 5 | Inside | 5.30 | 1.325 | 7.95 |

Table 4-8

Comparison of Calculated and Allowable Stress Intensity Factors for Level A and B Conditions for Quarter Thickness Surface Flaws

| Location | Calculated Stress Intensity Factor ($ksi\sqrt{in}$) | Allowable Stress Intensity Factor ($ksi\sqrt{in}$) |
|----------|--|---|
| 1 | 47.7 | 135.5 |
| 2 | 52.1 | 135.5 |
| 3 | 129.0 | 135.5 |
| 4 | 128.7 | 135.5 |
| 5 (2D) | 99.4 | 135.5 |
| (3D) | 128.4 | 135.5 |

Table 4-9

Comparison of Calculated and Allowable Stress Intensity Factors for Level C and D Conditions for Quarter Thickness Surface Flaws

| Location | Calculated Stress Intensity Factor ($ksi\sqrt{in}$) | Allowable Stress Intensity Factor ($ksi\sqrt{in}$) |
|----------|--|---|
| 1 | 38.9 | 135.5 |
| 2 | 42.5 | 135.5 |
| 3 | 106.3 | 135.5 |
| 4 | 106.3 | 135.5 |
| 5 (2D) | 109.0 | 135.5 |
| (3D) | 110.1 | 135.5 |

Table 4-10

Results of Fatigue Crack Growth Analyses for Quarter Thickness Surface Flaws

| Location | Initial Flaw Depth (in.) | Crack Growth (in.) |
|----------|-----------------------------|-----------------------|
| 1 | 0.65 | 0.0389 |
| 2 | 0.775 | 0.0523 |
| 3 | 1.1875 | 0.0655 |
| 4 | 1.1875 | 0.0662 |
| 5 (2D) | 1.325 | 0.5870 |
| (3D) | 1.325 | 0.2908 |




Figure 4-1. Effect of Thermal Aging on Room Temperature Impact Energy of CF3, CF8 and CF8M Cast Stainless Steel [15]




Figure 4-1. Effect of Thermal Aging on Room Temperature Impact Energy of CF3, CF8 and CF8M Cast Stainless Steel [15]



Figure 4-2. Solution Heat Treated Wrought Type 316 Stainless Steel




Figure 4-3. Solution Heat Treated Grade CF8 Stainless Steel Casting






Figure 4-4. Effect of Temperature on Charpy Transition Curves of CF3, CF8 and CF8M Steels Aged for 30,000 hours [15]





Figure 4-5. Correlation Between Fracture Toughness (J_{1c}) and Charpy Impact Energy for Unaged and Aged Cast Stainless Steels Tested at Room Temperature and 290-320°C [14]

PROPRIETARY INFORMATION

PROPRIETARY INFORMATION

Figure 4-7. Three-dimensional Element Map - Top [31]

PROPRIETARY INFORMATION

Figure 4-8. Three-dimensional Element Map - Bottom [31]

PROPRIETARY INFORMATION

Figure 4-9. Typical Section Cuts for Primary Plus Secondary Load Conditions [31]

PROPRIETARY INFORMATION

Figure 4-10. Pump Case Model - Top View [6]

5.0 SUMMARY AND CONCLUSIONS

The evaluations contained in this report have demonstrated that the ANO-1 reactor coolant pump casings meet the safety and serviceability requirements of ASME Code Case N-481.

The fracture toughness of the base metal stainless steel, A351 Grade CF8M casting, and the weld metal were addressed, including the consideration of thermal embrittlement. The lower bound fracture toughness value of these materials was used in the analysis.

Five critical flaw locations were selected for the evaluation, considering areas where fabrication defects have previously been identified. In addition, the maximum stress locations were also included in the analysis.

Consistent with similar evaluations for pressure vessels with postulated large flaws, per Appendix G of ASME Section III, safety factors of 2 for primary and 1 for secondary loads were used for Service Levels A and B conditions. Safety factors of $\sqrt{2}$ and 1 were used for primary and secondary loads, respectively, for Service Levels C and D conditions. At all locations, the applied stress intensity factors were below the allowable values.

Fatigue crack growth analyses were performed for information purposes, conservatively considering the 40-year plant life to show that crack growth for even the boundary postulated flaws are relatively small.

The analyses included a number of conservatisms as noted below:

- The lower bound toughness of the weld metal was used in all cases to determine the allowable stress intensity factor.

- Even though cast stainless steel components and their weldments are relatively brittle, a linear elastic fracture mechanics approach was used for the analysis, in lieu of elastic-plastic fracture mechanics techniques.
- A flat plate model was used to calculate the stress intensity factors, even though the pump casings, for the most part, have circular cross sections. The use of a more representative model would have reduced the stress intensity factors.
- At Locations No. 1 through 4, because available documentation provided only a combination of primary and secondary stresses, a safety factor of 2 was applied on both the primary and secondary stresses. A safety factor of 1 on the secondary stresses, as required by Appendix G of Sections III and XI of the ASME Code, would have resulted in lower applied stress intensity factors at these locations.
- At Location No. 5 the maximum stresses along the weld were applied at the thickest section, resulting in conservative stress intensity factors. Also at this location, stresses were classified as primary if they could not be conveniently separated into primary and secondary components. In addition, stresses were classified as membrane if it could not be determined whether they are membrane or bending.

6.0 REFERENCES

1. "Safety Evaluation by the Office of the Nuclear Reactor Regulation Related to the Inservice Inspection (ISI) Program, Arkansas Power and Light Company, Arkansas Nuclear One, Unit 1, Docket No. 50-313", dated April 25, 1989. Attached to letter from Mr. J. A. Calvo (NRC) to Mr. T. G. Campbell (AP&L), "Reactor Coolant Pump Casing Weld Flaw Indications - Request for Relief from ASME Section XI Inspection Requirements, Arkansas Nuclear One, Unit 1 (TAC No. 64146)", dated April 25, 1989.
2. Letter from J. J. Fisicaro (Entergy Operations) to USNRC, "Arkansas Nuclear One - Unit 1, Docket No. 50-313, License No. DRP-51, Revision to Reactor Coolant Pump Augmented Inservice Inspection Commitment", dated March 26, 1992.
3. ASME Boiler and Pressure Vessel Code, Code Case N-481, "Alternate Examination Requirements for Cast Austenitic Pump Casings, Section XI, Division 1", March 5, 1990.
4. Letter from J. J. Fisicaro (Entergy Operations) to USNRC, "Arkansas Nuclear One - Unit 1, Docket No. 50-313, License No. DRP-51, Comparative Analysis of the Reactor Coolant Pumps", dated April 13, 1992.
5. Babcock & Wilcox Document No. 32-1165797-00, "Fracture Mechanics Analysis of ANO-1 "A" Pump Case Indication", dated November 7, 1986.
6. Babcock & Wilcox Document No. 32-1165802-01, "ANO-1 Pump Case Stresses", dated November 7, 1986.
7. Babcock & Wilcox Document No. 32-1165899-00, "Fracture Mechanics Analysis of ANO-1 "B" Pump Case Indication", dated November 7, 1986.
8. Babcock & Wilcox Document No. 32-1167147-00, "Fracture Mechanics Analysis of ANO-1 "B" Pump Case Surface Flaw", dated November 24, 1986.
9. Babcock & Wilcox Document No. 32-1173431-01, "RCP-B Pump Case Flaw Evaluation", dated October 26, 1988.
10. EPRI Report TR-100034, "Cast Austenitic Stainless Steel Sourcebook", prepared by EPRI and Structural Integrity Associates, October 1991.
11. ASME Boiler and Pressure Vessel Code, Section III, 1968 Edition with no addenda.
12. O. K. Chopra and H. M. Chung, Long-Term Embrittlement of Cast Duplex Stainless Steels in LWR Systems: Semiannual Report, April-September 1987, NUREG/CR-4744 Vol. 2, No. 2, ANL-89/6 (August 1989).

13. O. K. Chopra and H. M. Chung, Long-Term Embrittlement of Cast Duplex Stainless Steels in LWR Systems: Semiannual Report, October 1987-March 1988, NUREG/CR-4744 Vol. 3, No. 1, ANL-89/22 (February 1990).
14. O. K. Chopra and H. M. Chung, Long-Term Embrittlement of Cast Duplex Stainless Steels in LWR Systems: Semiannual Report, April-September 1988, NUREG/CR-4744 Vol. 3, No. 2, ANL-90/5 (August 1990).
15. O. K. Chopra and H. M. Chung, Long-Term Embrittlement of Cast Duplex Stainless Steels in LWR Systems: Semiannual Report October 1988-March 1989, NUREG/CR-4744, Vol. 4, No. 1, ANL-90/44 (May 1991).
16. O. K. Chopra, A. Sather, and L. Y. Bush, Long-Term Embrittlement of Cast Duplex Stainless Steels in LWR Systems: Semiannual Report April-September 1989, NUREG/CR-4744, Vol. 4, No. 2, ANL-90/49 (June 1991).
17. A. L. Hiser, Tensile and J-R Curve Characterization of Thermally Aged Cast Stainless Steels, NUREG/CR-5024, MEA-2229, Materials Engineering Associates, Inc., (September 1988).
18. E. I. Landerman and W. H. Bamford, "Fracture Toughness and Fatigue Characteristics of Centrifugally Cast Type 316 Stainless Steel Pipe after Simulated Thermal Service Conditions", in Ductility and Toughness Considerations in Elevated Temperature Service, MPC 8, ASME, New York, pp. 99-127 (1978).
19. S. Bonnet, J. Bourgoïn, J. Champredonde, D. Guttman, and M. Guttman, "Relationship Between Evolution of Mechanical Properties of Various Cast Duplex Stainless Steels and Metallurgical and Aging Parameters: An Outline of Current EDF Programmes", Mater. Sci. and Technol., 6, 221-229 (1990).
20. P. H. Pumphrey and K. N. Akharst, "Aging Kinetics of CF3 Cast Stainless Steel in Temperature Range 300-400°C," Mater. Sci. Technol., 6, 211-219 (1990).
21. G. Slama, P. Petrequin, and T. Mager, "Effect of Aging on Mechanical Properties of Austenitic Stainless Steel Castings and Welds," presented at SMiRT Post-Conference Seminar 6, Assuring Structural Integrity of Steel Reactor Pressure Boundary Components, August 29-30, 1983, Monterey, CA.
22. Y. Meyzaud, P. Ould, P. Balladon, M. Bethmont, and P. Soulat, "Tearing Resistance of Aged Cast Austenitic Stainless Steel", presented at Intl. Conf. on Thermal Reactor Safety (NUCSAFE 88), October 1988, Avignon, France.
23. P. McConnell and J. W. Sheckherd, Fracture Toughness Characterization of Thermally Embrittled Cast Duplex Stainless Steel, Report NP-5439, September 1987, Electric Power Research Institute, Palo Alto, CA.

24. O. K. Chopra, "Estimation of Mechanical Properties of Cast Stainless Steels During Thermal Aging in LWR Systems", NUREG/CP-0119, Vol. 2, pp. 151-178, Proceedings of the U.S. Nuclear Regulatory Commission, 19th Water Reactor Safety Information Meeting held at Bethesda, MD, October 28-30, 1991, published April 1992.
25. L. S. Ambrey, P. F. Wieser, W. J. Pollard, and E. A. Schoefer, "Ferrite Measurement and Control in Cast Duplex Stainless Steel", in Stainless Steel Castings, V. G. Behal and A. S. Melilli, editors, ASTM STP 756, pp. 126-164 (1982).
26. Babcock & Wilcox P. O. No. 805502, Contract No. 620-0008, Byron-Jackson Pumps.
27. EPRI Report NP-4668, "Evaluation of the Toughness of Austenitic Stainless Steel Pipe Weldments", June 1986.
28. EPRI Report NP-4768, "Toughness of Austenitic Stainless Steel Pipe Welds", October 1986.
29. EPRI Report NP-4690-SR, "Evaluation of Flaws in Austenitic Steel Piping", July 1986.
30. Private Communication between Nathaniel G. Cofie (Structural Integrity Associates) and O. K. Chopra (Argonne National Laboratory), April 24, 1992.
31. Byron-Jackson Report TCF-1014-STR, Vol. 1, Rev. 0, "33 x 33 x 38 DFSS Primary Coolant Pump Arkansas Power & Light Co.", dated 12/21/73, (B&W Document 32-0232-00) NSS-8 (AP&L - Calc. #83-S-00020-05).
32. B&W Document No. 32-1169053-00, "Stress Analysis of Revised Nozzle Loads", dated November 16, 1987.
33. Byron-Jackson Report TCF-1023-STR, Vol. 2, Rev. C, "Pump Case Analysis for Consumers Power Midland Plant Unit I and Unit II", dated June 19, 1980 (B&W Document 33-0210-03, dated July 29, 1980) NSS-12/13.
34. Telecopy from F. Marrujo (Byron-Jackson) to Bill Jones (B&W) dated October 21, 1986.
35. Duke Power Company, Radiographic Inspection Report/Technique, ANO Unit 1, Item Number B12-10-1, ID Number 43-001-UPPER, dated October 20, 1986.
36. ASME Boiler and Pressure Vessel Code, Section XI, 1989 Edition.
37. **pc-CRACK** Computer Software, Version 2.1, Structural Integrity Associates, May 1992.

38. Section XI Task Group for Piping Flaw Evaluation, ASME Code, "Evaluation of Flaws in Austenitic Steel Piping", Journal of Pressure Vessel Technology, Vol. 108, August 1986.
39. EPRI Report No. NP-5461, "Component Life Estimation: LWR Structural Material Degradation Mechanisms", September 1987, prepared by Structural Integrity Associates.

APPENDIX A

ASME Code Case N-481

CASES OF ASME BOILER AND PRESSURE VESSEL CODE

Approval Date: March 5, 1990

See Numerical Index for expiration
and any reaffirmation dates.

Case N-481
Alternate Examination Requirements for Cast
Austenitic Pump Casings
Section XI, Division 1

Inquiry: When conducting examination of cast austenitic pump casings in accordance with Section XI, Division 1, what examinations may be performed in lieu of the volumetric examinations specified in Table IWB-2500-1, Examination Category B-L-1, Item B12.10?

Reply: It is the opinion of the Committee that the following requirements shall be met in lieu of performing the volumetric examination specified in Table IWB-2500-1, Examination Category B-L-1, Item B12.10:

(a) Perform a VT-2 visual examination of the exterior of all pumps during the hydrostatic pressure test required by Table IWB-2500-1, Category B-P.

(b) Perform a VT-1 visual examination of the external surfaces of the weld of one pump casing.

ternal surfaces of the weld of one pump casing.

(c) Perform a VT-3 visual examination of the internal surfaces whenever a pump is disassembled for maintenance.

(d) Perform an evaluation to demonstrate the safety and serviceability of the pump casing. The evaluation shall include the following:

(1) evaluating material properties, including fracture toughness values;

(2) performing a stress analysis of the pump casing;

(3) reviewing the operating history of the pump;

(4) selecting locations for postulating flaws;

(5) postulating one-quarter thickness reference flaw with a length six times its depth;

(6) establishing the stability of the selected flaw under the governing stress conditions;

(7) considering thermal aging embrittlement and any other processes that may degrade the properties of the pump casing during service.

(e) A report of this evaluation shall be submitted to the regulatory and enforcement authorities having jurisdiction at the plant site for review.

APPENDIX B

pc-CRACK Output - Stress Intensity Factors

pc-CRACK
 (C) COPYRIGHT 1984, 1990
 STRUCTURAL INTEGRITY ASSOCIATES, INC.
 SAN JOSE, CA (408)978-8200
 VERSION 2.1

Date: 27-May-1992
 Time: 10:51:31.57

LINEAR ELASTIC FRACTURE MECHANICS EVALUATION

AND-1 CODE CASE N-481 EVALUATION - LOCATION NO. 1

crack model: ELLIPTICAL SURFACE CRACK PLATE UNDER MEMBRANE & BENDING STRESSES

WALL THICKNESS (t) = 2.6000
 YIELD STRESS = 21.5000
 CRACK ASPECT RATIO (a/L) = 0.1667

| STRESS COEFFICIENTS: | | |
|----------------------|----------|---------|
| CASE ID | C0 | C1 |
| COOLDOWN | 15.8833 | -2.5000 |
| HEATUP | -19.0167 | 3.8077 |
| EMERGENCY | 19.6833 | -6.9615 |

| CRACK SIZE | STRESS INTENSITY FACTOR | | |
|---------------|-------------------------|----------------|-------------------|
| | CASE COOLDOWN | CASE HEATUP | CASE EMERGENCY |
| 0.0260 | 4.663 | -5.302 | 5.861 |
| 0.0520 | 6.587 | -7.485 | 8.254 |
| 0.0780 | 8.059 | -9.151 | 10.067 |
| 0.1040 | 9.295 | -10.548 | 11.576 |
| 0.1300 | 10.380 | -11.771 | 12.888 |
| 0.1560 | 11.357 | -12.871 | 14.058 |
| 0.1820 | 12.253 | -13.877 | 15.120 |
| 0.2080 | 13.084 | -14.808 | 16.095 |
| 0.2340 | 13.861 | -15.678 | 16.998 |
| 0.2600 | 14.594 | -16.496 | 17.841 |
| 0.2860 | 15.340 | -17.324 | 18.673 |
| 0.3120 | 16.058 | -18.118 | 19.464 |
| 0.3380 | 16.750 | -18.882 | 20.217 |
| 0.3640 | 17.420 | -19.620 | 20.927 |
| 0.3900 | 18.071 | -20.335 | 21.627 |
| 0.4160 | 18.705 | -21.029 | 22.290 |
| 0.4420 | 19.322 | -21.705 | 22.929 |
| 0.4680 | 19.926 | -22.363 | 23.545 |
| 0.4940 | 20.516 | -23.005 | 24.139 |
| 0.5200 | 21.094 | -23.633 | 24.715 |
| 0.5460 | 21.665 | -24.257 | 25.302 |

| | | | |
|--------|--------|---------|--------|
| 0.5720 | 22.226 | -24.868 | 25.873 |
| 0.5980 | 22.777 | -25.468 | 26.430 |
| 0.6240 | 23.320 | -26.058 | 26.973 |
| 0.6500 | 23.855 | -26.639 | 27.503 |
| 0.6760 | 24.382 | -27.210 | 28.021 |
| 0.7020 | 24.903 | -27.774 | 28.528 |
| 0.7280 | 25.417 | -28.329 | 29.024 |
| 0.7540 | 25.926 | -28.877 | 29.510 |
| 0.7800 | 26.428 | -29.418 | 29.986 |
| 0.8060 | 27.069 | -30.106 | 30.567 |
| 0.8320 | 27.709 | -30.793 | 31.183 |
| 0.8580 | 28.349 | -31.479 | 31.774 |
| 0.8840 | 28.989 | -32.164 | 32.362 |
| 0.9100 | 29.628 | -32.848 | 32.946 |
| 0.9360 | 30.268 | -33.532 | 33.526 |
| 0.9620 | 30.908 | -34.216 | 34.103 |
| 0.9880 | 31.549 | -34.899 | 34.677 |
| 1.0140 | 32.190 | -35.581 | 35.247 |
| 1.0400 | 32.832 | -36.264 | 35.815 |
| 1.0660 | 33.578 | -37.070 | 36.534 |
| 1.0920 | 34.328 | -37.879 | 37.254 |
| 1.1180 | 35.081 | -38.691 | 37.973 |
| 1.1440 | 35.837 | -39.506 | 38.697 |
| 1.1700 | 36.597 | -40.325 | 39.421 |
| 1.1960 | 37.360 | -41.147 | 40.146 |
| 1.2220 | 38.126 | -41.972 | 40.873 |
| 1.2480 | 38.896 | -42.800 | 41.601 |
| 1.2740 | 39.669 | -43.632 | 42.332 |
| 1.3000 | 40.446 | -44.467 | 43.063 |

END OF pc-CRACK

tm
 pc-CRACK
 (C) COPYRIGHT 1984, 1990
 STRUCTURAL INTEGRITY ASSOCIATES, INC.
 SAN JOSE, CA (408)978-8200
 VERSION 2.1

Date: 23-May-1992
 Time: 11: 5:10.18

LINEAR ELASTIC FRACTURE MECHANICS EVALUATION

AND-1 CODE CASE N-461 EVALUATION - LOCATION NO. 2

crack model: ELLIPTICAL SURFACE CRACK PLATE UNDER MEMBRANE & BENDING STRESSES

WALL THICKNESS (t)= 3.1000
 YIELD STRESS= 21.5000
 CRACK ASPECT RATIO (a/L)= 0.1667

| CASE ID | STRESS COEFFICIENTS: | |
|-----------|----------------------|---------|
| | CO | C1 |
| COOLDOWN | 15.8833 | -2.0968 |
| HEATUP | -19.0167 | 3.1935 |
| EMERGENCY | 19.6833 | -5.8387 |

| CRACK SIZE | STRESS INTENSITY FACTOR----- | | |
|---------------|------------------------------|----------------|-------------------|
| | CASE COOLDOWN | CASE HEATUP | CASE EMERGENCY |
| 0.0310 | 5.092 | -5.790 | 6.400 |
| 0.0620 | 7.193 | -8.173 | 9.013 |
| 0.0930 | 8.800 | -9.992 | 10.993 |
| 0.1240 | 10.149 | -11.517 | 12.640 |
| 0.1550 | 11.334 | -12.853 | 14.072 |
| 0.1860 | 12.401 | -14.055 | 15.330 |
| 0.2170 | 13.379 | -15.153 | 16.510 |
| 0.2480 | 14.287 | -16.170 | 17.575 |
| 0.2790 | 15.136 | -17.119 | 18.561 |
| 0.3100 | 15.936 | -18.012 | 19.481 |
| 0.3410 | 16.750 | -18.916 | 20.390 |
| 0.3720 | 17.534 | -19.783 | 21.253 |
| 0.4030 | 18.290 | -20.618 | 22.075 |
| 0.4340 | 19.022 | -21.424 | 22.861 |
| 0.4650 | 19.732 | -22.205 | 23.615 |
| 0.4960 | 20.424 | -22.963 | 24.339 |
| 0.5270 | 21.098 | -23.700 | 25.036 |
| 0.5580 | 21.757 | -24.419 | 25.709 |
| 0.5890 | 22.402 | -25.120 | 26.359 |
| 0.6200 | 23.034 | -25.806 | 26.987 |
| 0.6510 | 23.657 | -26.487 | 27.628 |

| | | | |
|--------|--------|---------|--------|
| 0.6820 | 24.269 | -27.154 | 28.251 |
| 0.7130 | 24.871 | -27.810 | 28.859 |
| 0.7440 | 25.464 | -28.454 | 29.452 |
| 0.7750 | 26.048 | -29.088 | 30.031 |
| 0.8060 | 26.624 | -29.712 | 30.597 |
| 0.8370 | 27.193 | -30.327 | 31.151 |
| 0.8680 | 27.754 | -30.933 | 31.692 |
| 0.8990 | 28.309 | -31.531 | 32.223 |
| 0.9300 | 28.858 | -32.122 | 32.743 |
| 0.9610 | 29.557 | -32.874 | 33.399 |
| 0.9920 | 30.256 | -33.624 | 34.049 |
| 1.0230 | 30.955 | -34.373 | 34.695 |
| 1.0540 | 31.654 | -35.121 | 35.337 |
| 1.0850 | 32.352 | -35.868 | 35.974 |
| 1.1160 | 33.051 | -36.615 | 36.608 |
| 1.1470 | 33.750 | -37.361 | 37.238 |
| 1.1780 | 34.449 | -38.107 | 37.864 |
| 1.2090 | 35.149 | -38.852 | 38.488 |
| 1.2400 | 35.850 | -39.598 | 39.108 |
| 1.2710 | 36.665 | -40.478 | 39.892 |
| 1.3020 | 37.483 | -41.361 | 40.678 |
| 1.3330 | 38.306 | -42.248 | 41.463 |
| 1.3640 | 39.131 | -43.138 | 42.254 |
| 1.3950 | 39.961 | -44.032 | 43.045 |
| 1.4260 | 40.794 | -44.929 | 43.837 |
| 1.4570 | 41.631 | -45.830 | 44.630 |
| 1.4880 | 42.472 | -46.735 | 45.426 |
| 1.5190 | 43.316 | -47.643 | 46.223 |
| 1.5500 | 44.164 | -48.555 | 47.022 |

END OF pc-CRACK

tm
 dc-CRACK
 (C) COPYRIGHT 1984, 1990
 STRUCTURAL INTEGRITY ASSOCIATES, INC.
 SAN JOSE, CA (408)978-8200
 VERSION 2.1

Date: 73-M.. 992
 Time: 11:36..2.10

LINEAR ELASTIC FRACTURE MECHANICS EVALUATION

AND-1 CODE CASE N-481 EVALUATION - LOCATION NO.3

crack model: ELLIPTICAL SURFACE CRACK PLATE UNDER MEMBRANE & BENDING STRESSES

WALL THICKNESS (t)= 4.7500
 YIELD STRESS= 21.5000
 CRACK ASPECT RATIO (a/L)= 0.1467

| CASE ID | STRESS COEFFICIENTS: | |
|-----------|----------------------|----------|
| | C0 | C1 |
| TRANS-A | 37.0000 | -10.6526 |
| TRANS-B | -8.8000 | 5.5579 |
| EMERGENCY | 38.3000 | -6.4000 |

| CRACK SIZE | STRESS INTENSITY FACTOR----- | | |
|------------|------------------------------|--------------|----------------|
| | CASE TRANS-A | CASE TRANS-B | CASE EMERGENCY |
| 0.0475 | 14.946 | -3.143 | 15.642 |
| 0.0950 | 20.993 | -4.369 | 22.074 |
| 0.1425 | 25.533 | -5.257 | 26.943 |
| 0.1900 | 29.279 | -5.963 | 31.004 |
| 0.2375 | 32.505 | -6.547 | 34.544 |
| 0.2850 | 35.357 | -7.040 | 37.711 |
| 0.3325 | 37.919 | -7.462 | 40.591 |
| 0.3800 | 40.248 | -7.825 | 43.242 |
| 0.4275 | 42.382 | -8.138 | 45.705 |
| 0.4750 | 44.351 | -8.408 | 48.009 |
| 0.5225 | 46.234 | -8.611 | 50.303 |
| 0.5700 | 47.995 | -8.778 | 52.489 |
| 0.6175 | 49.649 | -8.911 | 54.580 |
| 0.6650 | 51.205 | -9.014 | 56.585 |
| 0.7125 | 52.673 | -9.089 | 58.515 |
| 0.7600 | 54.061 | -9.137 | 60.375 |
| 0.8075 | 55.374 | -9.161 | 62.173 |
| 0.8550 | 56.619 | -9.162 | 63.913 |
| 0.9025 | 57.801 | -9.141 | 65.601 |
| 0.9500 | 58.922 | -9.099 | 67.240 |
| 0.9975 | 60.120 | -9.112 | 68.894 |

| | | | |
|--------|--------|--------|---------|
| 1.0450 | 61.272 | -9.110 | 70.509 |
| 1.0925 | 62.380 | -9.093 | 72.087 |
| 1.1400 | 63.447 | -9.063 | 73.631 |
| 1.1875 | 64.473 | -9.019 | 75.143 |
| 1.2350 | 65.466 | -8.962 | 76.624 |
| 1.2825 | 66.422 | -8.893 | 78.076 |
| 1.3300 | 67.344 | -8.812 | 79.502 |
| 1.3775 | 68.234 | -8.719 | 80.902 |
| 1.4250 | 69.093 | -8.615 | 82.278 |
| 1.4725 | 70.157 | -8.464 | 84.018 |
| 1.5200 | 71.199 | -8.300 | 85.749 |
| 1.5675 | 72.222 | -8.126 | 87.471 |
| 1.6150 | 73.226 | -7.940 | 89.185 |
| 1.6625 | 74.211 | -7.744 | 90.892 |
| 1.7100 | 75.179 | -7.537 | 92.591 |
| 1.7575 | 76.130 | -7.320 | 94.284 |
| 1.8050 | 77.065 | -7.093 | 95.971 |
| 1.8525 | 77.984 | -6.856 | 97.652 |
| 1.9000 | 78.888 | -6.610 | 99.328 |
| 1.9475 | 80.218 | -6.487 | 101.394 |
| 1.9950 | 81.545 | -6.359 | 103.465 |
| 2.0425 | 82.869 | -6.224 | 105.542 |
| 2.0900 | 84.190 | -6.084 | 107.624 |
| 2.1375 | 85.508 | -5.938 | 109.711 |
| 2.1850 | 86.824 | -5.787 | 111.805 |
| 2.2325 | 88.138 | -5.630 | 113.904 |
| 2.2800 | 89.449 | -5.468 | 116.010 |
| 2.3275 | 90.759 | -5.301 | 118.122 |
| 2.3750 | 92.068 | -5.129 | 120.240 |

END OF pc-CRACK

Date: 23-May-1992
 Time: 12:17:44.78

LINEAR ELASTIC FRACTURE MECHANICS EVALUATION

AUT-1 CODE CASE N-481 EVALUATION - LOCATION NO.4

crack model: ELLIPTICAL SURFACE CRACK PLATE UNDER MEMBRANE & BENDING STRESSES

WALL THICKNESS (t)= 4.7500
 YIELD STRESS= 21.5000
 CRACK ASPECT RATIO (a/L)= 0.1667

| CASE ID | STRESS COEFFICIENTS: | |
|-----------|----------------------|----------|
| | C0 | C1 |
| TRANS-A | 36.9000 | -10.6105 |
| TRANS-B | -9.3000 | 5.9368 |
| EMERGENCY | 38.3000 | -6.4000 |

| CRACK SIZE | STRESS INTENSITY FACTOR | | |
|------------|-------------------------|--------------|----------------|
| | CASE TRANS-A | CASE TRANS-B | CASE EMERGENCY |
| 0.0475 | 14.907 | -3.319 | 15.662 |
| 0.0950 | 20.937 | -4.613 | 22.074 |
| 0.1425 | 25.466 | -5.550 | 26.943 |
| 0.1900 | 29.201 | -6.293 | 31.004 |
| 0.2375 | 32.420 | -7.907 | 34.544 |
| 0.2850 | 35.265 | -7.426 | 37.711 |
| 0.3325 | 37.821 | -7.869 | 40.591 |
| 0.3800 | 40.144 | -8.249 | 43.242 |
| 0.4275 | 42.273 | -8.577 | 45.705 |
| 0.4750 | 44.237 | -8.859 | 48.009 |
| 0.5225 | 46.116 | -9.070 | 50.303 |
| 0.5700 | 47.874 | -9.242 | 52.489 |
| 0.6175 | 49.524 | -9.378 | 54.580 |
| 0.6650 | 51.077 | -9.482 | 56.585 |
| 0.7125 | 52.542 | -9.555 | 58.515 |
| 0.7600 | 53.927 | -9.601 | 60.375 |
| 0.8075 | 55.230 | -9.621 | 62.173 |
| 0.8550 | 56.482 | -9.616 | 63.913 |
| 0.9025 | 57.661 | -9.588 | 65.601 |
| 0.9500 | 58.781 | -9.538 | 67.240 |
| 0.9975 | 59.977 | -9.547 | 68.894 |

| | | | |
|--------|--------|--------|---------|
| 1.0450 | 61.127 | -9.539 | 70.509 |
| 1.0925 | 62.233 | -9.516 | 72.087 |
| 1.1400 | 63.299 | -9.478 | 73.631 |
| 1.1875 | 64.325 | -9.426 | 75.143 |
| 1.2350 | 65.315 | -9.360 | 76.624 |
| 1.2825 | 66.269 | -9.281 | 78.076 |
| 1.3300 | 67.190 | -9.190 | 79.502 |
| 1.3775 | 68.079 | -9.086 | 80.902 |
| 1.4250 | 68.937 | -8.970 | 82.278 |
| 1.4725 | 70.000 | -8.802 | 84.018 |
| 1.5200 | 71.041 | -8.621 | 85.749 |
| 1.5675 | 72.063 | -8.429 | 87.471 |
| 1.6150 | 73.066 | -8.224 | 89.185 |
| 1.6625 | 74.051 | -8.008 | 90.892 |
| 1.7100 | 75.018 | -7.781 | 92.591 |
| 1.7575 | 75.969 | -7.542 | 94.284 |
| 1.8050 | 76.903 | -7.293 | 95.971 |
| 1.8525 | 77.822 | -7.034 | 97.652 |
| 1.9000 | 78.725 | -6.764 | 99.328 |
| 1.9475 | 80.054 | -6.626 | 101.394 |
| 1.9950 | 81.379 | -6.481 | 103.65 |
| 2.0425 | 82.702 | -6.331 | 105.542 |
| 2.0900 | 84.021 | -6.174 | 107.624 |
| 2.1375 | 85.338 | -6.010 | 109.711 |
| 2.1850 | 86.652 | -5.841 | 111.805 |
| 2.2325 | 87.965 | -5.667 | 113.904 |
| 2.2800 | 89.275 | -5.486 | 116.010 |
| 2.3275 | 90.584 | -5.300 | 118.122 |
| 2.3750 | 91.891 | -5.108 | 120.240 |

END OF pc-CRACK

tm
 Wc-CRACK
 (C) COPYRIGHT 1984, 1990
 STRUCTURAL INTEGRITY ASSOCIATES, INC.
 SAN JOSE, CA (408)978-8200
 VERSION 2.1

Date: 5-Jun-1992
 Time: 13:10:30.25

LINEAR ELASTIC FRACTURE MECHANICS EVALUATION

ANO-1 CODE CASE N-481 EVALUATION - LOCATION NO. 5 (2-D MODEL)

crack model: ELLIPTICAL SURFACE CRACK PLATE UNDER MEMBRANE & BENDING STRESSES

WALL THICKNESS (t)= 5.3000
 YIELD STRESS= 21.5000
 CRACK ASPECT RATIO (a/L)= 0.1667

| CASE ID | STRESS COEFFICIENTS: | |
|------------|----------------------|----------|
| | C0 | C1 |
| NORMAL-PRI | 11.0000 | 0.0000 |
| NORMAL-SEC | 27.0000 | -6.7925 |
| EMER-PRI | 14.0000 | -0.0000 |
| EMER-SEC | 34.4000 | -8.6415 |
| NORMAL-RNG | 58.0000 | -14.3396 |

| CRACK SIZE | STRESS INTENSITY FACTOR | | | | |
|------------|-------------------------|-----------------|---------------|---------------|-----------------|
| | CASE NORMAL-PRI | CASE NORMAL-SEC | CASE EMER-PRI | CASE EMER-SEC | CASE NORMAL-RNG |
| 0.0530 | 4.531 | 11.529 | 5.859 | 14.690 | 24.779 |
| 0.1060 | 6.416 | 16.197 | 8.296 | 20.637 | 34.815 |
| 0.1590 | 7.867 | 19.704 | 10.173 | 25.106 | 42.361 |
| 0.2120 | 9.095 | 22.599 | 11.761 | 28.796 | 48.592 |
| 0.2650 | 10.181 | 25.096 | 13.165 | 31.977 | 53.967 |
| 0.3180 | 11.166 | 27.303 | 14.439 | 34.790 | 58.723 |
| 0.3710 | 12.075 | 29.288 | 15.614 | 37.320 | 63.002 |
| 0.4240 | 12.924 | 31.094 | 16.712 | 39.621 | 66.896 |
| 0.4770 | 13.725 | 32.750 | 17.747 | 41.732 | 70.470 |
| 0.5300 | 14.484 | 34.280 | 18.730 | 43.682 | 73.773 |
| 0.5830 | 15.273 | 35.747 | 19.750 | 45.552 | 76.946 |
| 0.6360 | 16.038 | 37.121 | 20.739 | 47.303 | 79.920 |
| 0.6890 | 16.782 | 38.412 | 21.700 | 48.950 | 82.719 |
| 0.7420 | 17.508 | 39.629 | 22.639 | 50.507 | 85.359 |
| 0.7950 | 18.218 | 40.779 | 23.557 | 51.968 | 87.855 |
| 0.8480 | 18.914 | 41.867 | 24.457 | 53.356 | 90.220 |
| 0.9010 | 19.598 | 42.899 | 25.342 | 54.672 | 92.465 |
| 0.9540 | 20.271 | 43.879 | 26.212 | 55.922 | 94.599 |
| 1.0070 | 20.934 | 44.810 | 27.069 | 57.110 | 96.629 |

| | | | | | |
|--------|--------|--------|--------|--------|---------|
| 1.0600 | 21.588 | 45.696 | 27.915 | 58.240 | 98.562 |
| 1.1130 | 22.221 | 46.638 | 28.735 | 59.441 | 100.612 |
| 1.1660 | 22.847 | 47.544 | 29.544 | 60.598 | 102.586 |
| 1.2190 | 23.466 | 48.418 | 30.344 | 61.712 | 104.490 |
| 1.2720 | 24.078 | 49.260 | 31.135 | 62.786 | 106.327 |
| 1.3250 | 24.684 | 50.072 | 31.919 | 63.822 | 108.100 |
| 1.3780 | 25.285 | 50.856 | 32.696 | 64.823 | 109.814 |
| 1.4310 | 25.880 | 51.613 | 33.466 | 65.789 | 111.470 |
| 1.4840 | 26.471 | 52.345 | 34.230 | 66.723 | 113.072 |
| 1.5370 | 27.058 | 53.052 | 34.989 | 67.626 | 114.622 |
| 1.5900 | 27.641 | 53.736 | 35.742 | 68.499 | 116.123 |
| 1.6430 | 28.388 | 54.584 | 36.708 | 69.581 | 117.986 |
| 1.6960 | 29.137 | 55.417 | 37.676 | 70.644 | 119.816 |
| 1.7490 | 29.888 | 56.235 | 38.648 | 71.688 | 121.615 |
| 1.8020 | 30.641 | 57.038 | 39.622 | 72.714 | 123.385 |
| 1.8550 | 31.396 | 57.829 | 40.599 | 73.723 | 125.126 |
| 1.9080 | 32.154 | 58.606 | 41.579 | 74.715 | 126.840 |
| 1.9610 | 32.915 | 59.370 | 42.562 | 75.692 | 128.528 |
| 2.0140 | 33.678 | 60.123 | 43.549 | 76.653 | 130.190 |
| 2.0670 | 34.443 | 60.864 | 44.539 | 77.599 | 131.829 |
| 2.1200 | 35.212 | 61.593 | 45.532 | 78.531 | 133.444 |
| 2.1730 | 36.070 | 62.649 | 46.643 | 79.879 | 135.756 |
| 2.2260 | 36.934 | 63.703 | 47.759 | 81.224 | 138.065 |
| 2.2790 | 37.803 | 64.755 | 48.883 | 82.566 | 140.369 |
| 2.3320 | 38.676 | 65.805 | 50.012 | 83.506 | 142.671 |
| 2.3850 | 39.555 | 66.853 | 51.148 | 85.244 | 144.969 |
| 2.4380 | 40.438 | 67.900 | 52.290 | 86.580 | 147.265 |
| 2.4910 | 41.326 | 68.945 | 53.439 | 87.914 | 149.558 |
| 2.5440 | 42.220 | 69.990 | 54.594 | 89.247 | 151.849 |
| 2.5970 | 43.118 | 71.033 | 55.756 | 90.579 | 154.139 |
| 2.6500 | 44.021 | 72.075 | 56.923 | 91.909 | 156.427 |

END OF pc-CRACK

Date: 5-Jun-1992
 Time: 12:32:51.43

LINEAR ELASTIC FRACTURE MECHANICS EVALUATION

AND-1 CODE CASE N-481 EVALUATION - LOCATION NO. 5 (3-D MODEL)

crack model: ELLIPTICAL SURFACE CRACK PLATE UNDER MEMBRANE & BENDING STRESSES

WALL THICKNESS (t)= 5.3000
 YIELD STRESS= 21.5000
 CRACK ASPECT RATIO (a/L)= 0.1667

| STRESS COEFFICIENTS: | | |
|----------------------|---------|----------|
| CASE ID | C0 | C1 |
| NORMAL-PRI | 18.0000 | 0.0000 |
| NORMAL-SEC | 28.0000 | -10.5660 |
| EMER-PRI | 19.0000 | 0.0000 |
| EMER-SEC | 29.6000 | -11.1700 |
| NORMAL-RNG | 48.0000 | -11.3208 |

| CRACK SIZE | STRESS INTENSITY FACTOR | | | | |
|------------|-------------------------|-----------------|---------------|---------------|-----------------|
| | CASE NORMAL-PRI | CASE NORMAL-SEC | CASE EMER-PRI | CASE EMER-SEC | CASE NORMAL-RNG |
| 0.0530 | 7.709 | 11.785 | 8.195 | 12.459 | 20.534 |
| 0.1060 | 10.916 | 16.488 | 11.604 | 17.430 | 28.861 |
| 0.1590 | 13.385 | 19.974 | 14.229 | 21.116 | 35.129 |
| 0.2120 | 15.474 | 22.811 | 16.450 | 24.114 | 40.311 |
| 0.2650 | 17.322 | 25.221 | 18.414 | 26.662 | 44.787 |
| 0.3180 | 18.998 | 27.318 | 20.196 | 28.879 | 48.753 |
| 0.3710 | 20.545 | 29.172 | 21.840 | 30.838 | 52.326 |
| 0.4240 | 21.990 | 30.828 | 23.377 | 32.589 | 55.582 |
| 0.4770 | 23.352 | 32.318 | 24.824 | 34.165 | 58.576 |
| 0.5300 | 24.644 | 33.666 | 26.198 | 35.590 | 61.346 |
| 0.5830 | 25.986 | 34.877 | 27.625 | 36.870 | 64.020 |
| 0.6360 | 27.287 | 35.976 | 29.008 | 38.032 | 66.532 |
| 0.6890 | 28.553 | 36.976 | 30.354 | 39.088 | 68.900 |
| 0.7420 | 29.788 | 37.884 | 31.667 | 40.048 | 71.140 |
| 0.7950 | 30.996 | 38.709 | 32.951 | 40.921 | 73.263 |
| 0.8480 | 32.181 | 39.457 | 34.210 | 41.712 | 75.280 |
| 0.9010 | 33.344 | 40.134 | 35.447 | 42.427 | 77.198 |
| 0.9540 | 34.489 | 40.745 | 36.664 | 43.073 | 79.027 |
| 1.0070 | 35.617 | 41.294 | 37.863 | 43.653 | 80.772 |

| | | | | | |
|--------|--------|--------|--------|--------|---------|
| 1.0600 | 36.730 | 41.784 | 39.047 | 44.171 | 82.438 |
| 1.1130 | 37.808 | 42.389 | 40.193 | 44.811 | 84.192 |
| 1.1660 | 38.873 | 42.950 | 41.325 | 45.404 | 85.885 |
| 1.2190 | 39.926 | 43.469 | 42.444 | 45.952 | 87.521 |
| 1.2720 | 40.967 | 43.948 | 43.551 | 46.458 | 89.102 |
| 1.3250 | 41.998 | 44.388 | 44.647 | 46.924 | 90.632 |
| 1.3780 | 43.020 | 44.793 | 45.733 | 47.352 | 92.114 |
| 1.4310 | 44.034 | 45.163 | 46.811 | 47.743 | 93.549 |
| 1.4840 | 45.039 | 45.499 | 47.880 | 48.098 | 94.940 |
| 1.5370 | 46.037 | 45.803 | 48.941 | 48.420 | 96.290 |
| 1.5900 | 47.029 | 46.076 | 49.995 | 48.708 | 97.599 |
| 1.6430 | 48.000 | 46.382 | 51.046 | 49.031 | 99.230 |
| 1.6960 | 49.574 | 46.660 | 52.700 | 49.326 | 100.836 |
| 1.7490 | 50.852 | 46.913 | 54.059 | 49.593 | 102.417 |
| 1.8020 | 52.133 | 47.141 | 55.421 | 49.834 | 103.975 |
| 1.8550 | 53.419 | 47.345 | 56.788 | 50.049 | 105.512 |
| 1.9080 | 54.708 | 47.525 | 58.159 | 50.239 | 107.027 |
| 1.9610 | 56.002 | 47.682 | 59.534 | 50.406 | 108.523 |
| 2.0140 | 57.300 | 47.817 | 60.914 | 50.548 | 109.999 |
| 2.0670 | 58.603 | 47.930 | 62.299 | 50.668 | 111.456 |
| 2.1200 | 59.910 | 48.023 | 63.688 | 50.766 | 112.896 |
| 2.1730 | 61.371 | 48.500 | 65.242 | 51.270 | 114.906 |
| 2.2260 | 62.841 | 48.967 | 66.804 | 51.764 | 116.913 |
| 2.2790 | 64.319 | 49.424 | 68.375 | 52.247 | 118.919 |
| 2.3320 | 65.805 | 49.872 | 69.955 | 52.721 | 120.923 |
| 2.3850 | 67.300 | 50.310 | 71.544 | 53.184 | 122.926 |
| 2.4380 | 68.803 | 50.740 | 73.142 | 53.638 | 124.927 |
| 2.4910 | 70.314 | 51.160 | 74.749 | 54.083 | 126.928 |
| 2.5440 | 71.834 | 51.573 | 76.364 | 54.518 | 128.928 |
| 2.5970 | 73.362 | 51.977 | 77.989 | 54.945 | 130.928 |
| 2.6500 | 74.899 | 52.372 | 79.622 | 55.364 | 132.928 |

END OF pc-CRACK

APPENDIX C

pc-CRACK Output - Fatigue Crack Growth

tm
 pc-CRACK
 (C) COPYRIGHT 1984, 1990
 STRUCTURAL INTEGRITY ASSOCIATES, INC.
 SAN JOSE, CA (408)978-8200
 VERSION 2.1

Date: 5-Jun-1992
 Time: 13:28:47.16

FATIGUE CRACK GROWTH ANALYSIS

ANO-1 CODE CASE N-481 EVALUATION - LOCATION NO. 1

INITIAL CRACK SIZE= 0.6500
 WALL THICKNESS= 2.6000
 MAX CRACK SIZE FOR FCG= 1.3000

PARIS CRACK GROWTH LAW:

$$da/dN = C * (dK)^n$$

where

$$dK = K_{max} - K_{min}$$

$$dK > dK_{thres}$$

$$K_{max} < K_{Ic}$$

CURRENT

| LAW ID | C | n | dKthres | KIc |
|-----------|-----------|-------|---------|---------|
| PWR WATER | 3.680E-10 | 3.300 | 0.000 | 135.500 |

STRESS COEFFICIENTS

| CASE ID | C0 | C1 | C2 | C3 |
|-----------|----------|---------|--------|--------|
| COOLDOWN | 15.8833 | -2.5000 | 0.0000 | 0.0000 |
| HEATUP | -19.0167 | 3.8077 | 0.0000 | 0.0000 |
| EMERGENCY | 19.6833 | -6.9615 | 0.0000 | 0.0000 |

NUMBER OF CYCLE BLOCKS= 240

PRINT INCREMENT OF CYCLE BLOCK= 6

| SUBBLOCK | NUMBER OF CYCLES | CALCULATION INCREMENT | PRINT INCREMENT | FCG LAW ID |
|----------|------------------|-----------------------|-----------------|------------|
| 1 | 1 | 1 | 1 | PWR WATER |

| SUBBLOCK | Kmax | | Kmin | |
|----------|----------|--------------|---------|--------------|
| | CASE ID | SCALE FACTOR | CASE ID | SCALE FACTOR |
| 1 | COOLDOWN | 1.0000 | HEATUP | 1.0000 |

crack model: ELLIPTICAL SURFACE CRACK PLATE UNDER MEMBRANE & BENDING STRESSES

| CRACK SIZE | CASE | CASE | CASE |
|------------|----------|--------|-----------|
| | COOLDOWN | HEATUP | EMERGENCY |

| | | | |
|--------|--------|---------|--------|
| 0.0260 | 4.663 | -5.302 | 5.861 |
| 0.0520 | 6.597 | -7.485 | 8.254 |
| 0.0780 | 8.059 | -9.151 | 10.067 |
| 0.1040 | 9.295 | -10.548 | 11.576 |
| 0.1300 | 10.380 | -11.771 | 12.888 |
| 0.1560 | 11.357 | -12.871 | 14.058 |
| 0.1820 | 12.253 | -13.877 | 15.120 |
| 0.2080 | 13.084 | -14.808 | 16.095 |
| 0.2340 | 13.861 | -15.678 | 16.998 |
| 0.2600 | 14.594 | -16.496 | 17.841 |
| 0.2860 | 15.340 | -17.324 | 18.673 |
| 0.3120 | 16.058 | -18.118 | 19.464 |
| 0.3380 | 16.750 | -18.882 | 20.217 |
| 0.3640 | 17.420 | -19.620 | 20.937 |
| 0.3900 | 18.071 | -20.335 | 21.627 |
| 0.4160 | 18.705 | -21.029 | 22.290 |
| 0.4420 | 19.322 | -21.705 | 22.929 |
| 0.4680 | 19.926 | -22.363 | 23.545 |
| 0.4940 | 20.516 | -23.005 | 24.139 |
| 0.5200 | 21.094 | -23.633 | 24.715 |
| 0.5460 | 21.665 | -24.257 | 25.302 |
| 0.5720 | 22.226 | -24.868 | 25.873 |
| 0.5980 | 22.777 | -25.468 | 26.430 |
| 0.6240 | 23.320 | -26.058 | 26.973 |
| 0.6500 | 23.855 | -26.639 | 27.503 |
| 0.6760 | 24.382 | -27.210 | 28.021 |
| 0.7020 | 24.903 | -27.774 | 28.528 |
| 0.7280 | 25.417 | -28.329 | 29.024 |
| 0.7540 | 25.926 | -28.877 | 29.510 |
| 0.7800 | 26.428 | -29.418 | 29.986 |
| 0.8060 | 27.069 | -30.106 | 30.587 |
| 0.8320 | 27.709 | -30.793 | 31.183 |
| 0.8580 | 28.349 | -31.479 | 31.774 |
| 0.8840 | 28.989 | -32.164 | 32.362 |
| 0.9100 | 29.628 | -32.848 | 32.946 |
| 0.9360 | 30.268 | -33.532 | 33.526 |
| 0.9620 | 30.908 | -34.216 | 34.103 |
| 0.9880 | 31.549 | -34.899 | 34.677 |
| 1.0140 | 32.190 | -35.581 | 35.247 |
| 1.0400 | 32.832 | -36.264 | 35.815 |
| 1.0660 | 33.578 | -37.070 | 36.534 |
| 1.0920 | 34.328 | -37.879 | 37.254 |
| 1.1180 | 35.081 | -38.691 | 37.975 |
| 1.1440 | 35.837 | -39.506 | 38.697 |
| 1.1700 | 36.597 | -40.325 | 39.421 |
| 1.1960 | 37.360 | -41.147 | 40.146 |
| 1.2220 | 38.126 | -41.972 | 40.873 |
| 1.2480 | 38.896 | -42.800 | 41.601 |
| 1.2740 | 39.669 | -43.632 | 42.332 |
| 1.3000 | 40.446 | -44.467 | 43.063 |

| TOTAL CYCLE | SUBBLOCK CYCLE | KMAX | KMIN | DELTAK | R | DADN | DA | A/T |
|----------------|-------------------|-------|--------|--------|-------|---------|--------|-------------|
| BLOCK 6 6 | 1 | 23.87 | -26.66 | 50.53 | -1.12 | 1.5E-04 | 0.0002 | 0.6509 0.25 |
| BLOCK 12 12 | 1 | 23.89 | -26.68 | 50.57 | -1.12 | 1.5E-04 | 0.0002 | 0.6518 0.25 |
| BLOCK 18 18 | 1 | 23.91 | -26.70 | 50.60 | -1.12 | 1.5E-04 | 0.0002 | 0.6528 0.25 |
| BLOCK 24 24 | 1 | 23.93 | -26.72 | 50.64 | -1.12 | 1.6E-04 | 0.0002 | 0.6537 0.25 |
| BLOCK 30 30 | 1 | 23.95 | -26.74 | 50.68 | -1.12 | 1.6E-04 | 0.0002 | 0.6546 0.25 |
| BLOCK 36 36 | 1 | 23.96 | -26.76 | 50.72 | -1.12 | 1.6E-04 | 0.0002 | 0.6556 0.25 |
| BLOCK 42 42 | 1 | 23.98 | -26.78 | 50.76 | -1.12 | 1.6E-04 | 0.0002 | 0.6565 0.25 |
| BLOCK 48 48 | 1 | 24.00 | -26.80 | 50.80 | -1.12 | 1.6E-04 | 0.0002 | 0.6574 0.25 |
| BLOCK 54 54 | 1 | 24.02 | -26.82 | 50.84 | -1.12 | 1.6E-04 | 0.0002 | 0.6584 0.25 |
| BLOCK 60 60 | 1 | 24.04 | -26.84 | 50.88 | -1.12 | 1.6E-04 | 0.0002 | 0.6593 0.25 |
| BLOCK 66 66 | 1 | 24.06 | -26.86 | 50.92 | -1.12 | 1.6E-04 | 0.0002 | 0.6603 0.25 |
| BLOCK 72 72 | 1 | 24.08 | -26.88 | 50.96 | -1.12 | 1.6E-04 | 0.0002 | 0.6612 0.25 |
| BLOCK 78 | | | | | | | | |

| | | | | | | | | | |
|------------------|---|-------|--------|-------|-------|---------|--------|--------|------|
| 78 | 1 | 24.10 | -26.90 | 51.00 | -1.12 | 1.6E-04 | 0.0002 | 0.6622 | 0.26 |
| BLOCK 84 84 | 1 | 24.12 | -26.92 | 51.04 | -1.12 | 1.6E-04 | 0.0002 | 0.6631 | 0.26 |
| BLOCK 90 90 | 1 | 24.14 | -26.95 | 51.08 | -1.12 | 1.6E-04 | 0.0002 | 0.6641 | 0.26 |
| BLOCK 96 96 | 1 | 24.16 | -26.97 | 51.12 | -1.12 | 1.6E-04 | 0.0002 | 0.6651 | 0.26 |
| BLOCK 102 102 | 1 | 24.18 | -26.99 | 51.16 | -1.12 | 1.6E-04 | 0.0002 | 0.6660 | 0.26 |
| BLOCK 108 108 | 1 | 24.20 | -27.01 | 51.20 | -1.12 | 1.6E-04 | 0.0002 | 0.6670 | 0.26 |
| BLOCK 114 114 | 1 | 24.22 | -27.03 | 51.25 | -1.12 | 1.6E-04 | 0.0002 | 0.6679 | 0.26 |
| BLOCK 120 120 | 1 | 24.24 | -27.05 | 51.29 | -1.12 | 1.6E-04 | 0.0002 | 0.6689 | 0.26 |
| BLOCK 126 126 | 1 | 24.26 | -27.07 | 51.33 | -1.12 | 1.6E-04 | 0.0002 | 0.6699 | 0.26 |
| BLOCK 132 132 | 1 | 24.27 | -27.09 | 51.37 | -1.12 | 1.6E-04 | 0.0002 | 0.6709 | 0.26 |
| BLOCK 138 138 | 1 | 24.29 | -27.12 | 51.41 | -1.12 | 1.6E-04 | 0.0002 | 0.6718 | 0.26 |
| BLOCK 144 144 | 1 | 24.31 | -27.14 | 51.45 | -1.12 | 1.6E-04 | 0.0002 | 0.6728 | 0.26 |
| BLOCK 150 150 | 1 | 24.33 | -27.16 | 51.49 | -1.12 | 1.6E-04 | 0.0002 | 0.6738 | 0.26 |
| BLOCK 156 156 | 1 | 24.35 | -27.18 | 51.53 | -1.12 | 1.6E-04 | 0.0002 | 0.6748 | 0.26 |

| | | | | | | | | | |
|------------------|---|-------|--------|-------|-------|---------|--------|--------|------|
| BLOCK 162 162 | 1 | 24.37 | -27.20 | 51.58 | -1.12 | 1.6E-04 | 0.0002 | 0.6758 | 0.26 |
| BLOCK 168 168 | 1 | 24.39 | -27.22 | 51.62 | -1.12 | 1.7E-04 | 0.0002 | 0.6768 | 0.26 |
| BLOCK 174 174 | 1 | 24.41 | -27.24 | 51.66 | -1.12 | 1.7E-04 | 0.0002 | 0.6773 | 0.26 |
| BLOCK 180 180 | 1 | 24.43 | -27.27 | 51.70 | -1.12 | 1.7E-04 | 0.0002 | 0.6788 | 0.26 |
| BLOCK 186 186 | 1 | 24.45 | -27.29 | 51.74 | -1.12 | 1.7E-04 | 0.0002 | 0.6798 | 0.26 |
| BLOCK 192 192 | 1 | 24.47 | -27.31 | 51.78 | -1.12 | 1.7E-04 | 0.0002 | 0.6808 | 0.26 |
| BLOCK 198 198 | 1 | 24.49 | -27.33 | 51.83 | -1.12 | 1.7E-04 | 0.0002 | 0.6818 | 0.26 |
| BLOCK 204 204 | 1 | 24.51 | -27.35 | 51.87 | -1.12 | 1.7E-04 | 0.0002 | 0.6828 | 0.26 |
| BLOCK 210 210 | 1 | 24.53 | -27.38 | 51.91 | -1.12 | 1.7E-04 | 0.0002 | 0.6838 | 0.26 |
| BLOCK 216 216 | 1 | 24.56 | -27.40 | 51.95 | -1.12 | 1.7E-04 | 0.0002 | 0.6848 | 0.26 |
| BLOCK 222 222 | 1 | 24.58 | -27.42 | 51.99 | -1.12 | 1.7E-04 | 0.0002 | 0.6858 | 0.26 |
| BLOCK 228 228 | 1 | 24.60 | -27.44 | 52.04 | -1.12 | 1.7E-04 | 0.0002 | 0.6868 | 0.26 |
| BLOCK 234 234 | 1 | 24.62 | -27.46 | 52.08 | -1.12 | 1.7E-04 | 0.0002 | 0.6878 | 0.26 |
| BLOCK 240 | | | | | | | | | |

pc-CRACK VERSION 2.1

PAGE 6

240 1 24.64 -27.49 52.12 -1.12 1.7E-04 0.0002 0.6889 0.25

END OF pc-CRACK

tm
 pc-CRACK
 (C) COPYRIGHT 1984, 1990
 STRUCTURAL INTEGRITY ASSOCIATES, INC.
 SAN JOSE, CA (408)978-8200
 VERSION 2.1

Date: 5-Jun-1992
 Time: 13:37:31.76

FATIGUE CRACK GROWTH ANALYSIS

AND-1 CODE CASE N-481 EVALUATION - LOCATION NO. 2

INITIAL CRACK SIZE= 0.7750
 WALL THICKNESS= 3.1000
 MAX CRACK SIZE FOR FCG= 1.5500

PARIS CRACK GROWTH LAW:

$$da/dN = C * (dK)^n$$

where

$$dK = K_{max} - K_{min}$$

$$dK > dK_{thres}$$

$$K_{max} < K_{Ic}$$

CURRENT

| LAWS: | LAW ID | C | n | dkthres | KIc |
|-------|-----------|-----------|-------|---------|---------|
| | PWR WATER | 3.680E-10 | 3.300 | 0.000 | 135.500 |

STRESS COEFFICIENTS

| CASE ID | C0 | C1 | C2 | C3 |
|-----------|----------|---------|--------|--------|
| COOLDOWN | 15.8833 | -2.0968 | 0.0000 | 0.0000 |
| HEATUP | -19.0167 | 3.1935 | 0.0000 | 0.0000 |
| EMERGENCY | 19.6833 | -5.8387 | 0.0000 | 0.0000 |

NUMBER OF CYCLE BLOCKS= 240
 PRINT INCREMENT OF CYCLE BLOCK= 6

| SUBBLOCK | NUMBER OF CYCLES | CALCULATION INCREMENT | PRINT INCREMENT | FCG LAW ID |
|----------|------------------|-----------------------|-----------------|------------|
| 1 | 1 | 1 | 1 | PWR WATER |

| SUBBLOCK | CASE ID | Kmax | | Kmin | |
|----------|----------|--------------|---------|--------------|---------|
| | | SCALE FACTOR | CASE ID | SCALE FACTOR | CASE ID |
| 1 | COOLDOWN | 1.0000 | HEATUP | 1.0000 | |

crack model: ELLIPTICAL SURFACE CRACK PLATE UNDER MEMBRANE & BENDING STRESSES

| CRACK SIZE | CASE COOLDOWN | STRESS INTENSITY FACTOR CASE HEATUP | STRESS INTENSITY FACTOR CASE EMERGENCY |
|------------|---------------|-------------------------------------|--|
| ----- | ----- | ----- | ----- |

| | | | |
|--------|--------|---------|--------|
| 0.0310 | 5.092 | -5.790 | 6.400 |
| 0.0620 | 7.193 | -8.173 | 9.013 |
| 0.0930 | 8.800 | -9.992 | 10.993 |
| 0.1240 | 10.149 | -11.517 | 12.640 |
| 0.1550 | 11.334 | -12.853 | 14.072 |
| 0.1860 | 12.401 | -14.055 | 15.350 |
| 0.2170 | 13.379 | -15.153 | 16.510 |
| 0.2480 | 14.287 | -16.170 | 17.575 |
| 0.2790 | 15.136 | -17.119 | 18.561 |
| 0.3100 | 15.936 | -18.012 | 19.481 |
| 0.3410 | 16.750 | -18.916 | 20.390 |
| 0.3720 | 17.534 | -19.783 | 21.253 |
| 0.4030 | 18.290 | -20.618 | 22.075 |
| 0.4340 | 19.022 | -21.424 | 22.861 |
| 0.4650 | 19.732 | -22.205 | 23.615 |
| 0.4960 | 20.424 | -22.963 | 24.339 |
| 0.5270 | 21.098 | -23.700 | 25.036 |
| 0.5580 | 21.757 | -24.419 | 25.709 |
| 0.5890 | 22.402 | -25.120 | 26.359 |
| 0.6200 | 23.034 | -25.806 | 26.987 |
| 0.6510 | 23.657 | -26.487 | 27.628 |
| 0.6820 | 24.269 | -27.154 | 28.251 |
| 0.7130 | 24.871 | -27.810 | 28.859 |
| 0.7440 | 25.464 | -28.454 | 29.452 |
| 0.7750 | 26.048 | -29.088 | 30.031 |
| 0.8060 | 26.624 | -29.712 | 30.597 |
| 0.8370 | 27.193 | -30.327 | 31.151 |
| 0.8680 | 27.754 | -30.933 | 31.692 |
| 0.8990 | 28.309 | -31.531 | 32.223 |
| 0.9300 | 28.858 | -32.122 | 32.743 |
| 0.9610 | 29.557 | -32.874 | 33.399 |
| 0.9920 | 30.256 | -33.624 | 34.049 |
| 1.0230 | 30.955 | -34.373 | 34.695 |
| 1.0540 | 31.654 | -35.121 | 35.337 |
| 1.0850 | 32.352 | -35.868 | 35.974 |
| 1.1160 | 33.051 | -36.615 | 36.608 |
| 1.1470 | 33.750 | -37.361 | 37.238 |
| 1.1780 | 34.449 | -38.107 | 37.864 |
| 1.2090 | 35.149 | -38.852 | 38.488 |
| 1.2400 | 35.850 | -39.598 | 39.108 |
| 1.2710 | 36.665 | -40.478 | 39.892 |
| 1.3020 | 37.483 | -41.361 | 40.678 |
| 1.3330 | 38.306 | -42.248 | 41.465 |
| 1.3640 | 39.131 | -43.138 | 42.254 |
| 1.3950 | 39.961 | -44.032 | 43.045 |
| 1.4260 | 40.794 | -44.929 | 43.837 |
| 1.4570 | 41.631 | -45.830 | 44.630 |
| 1.4880 | 42.472 | -46.735 | 45.426 |
| 1.5190 | 43.316 | -47.643 | 46.223 |
| 1.5500 | 44.164 | -48.555 | 47.022 |

| TOTAL CYCLE | SUBBLOCK CYCLE | KMAX | KMIN | DELTAK | R | DADN | DA | A | A ² |
|----------------|-------------------|-------|--------|--------|-------|---------|--------|--------|----------------|
| BLOCK 6 6 | 1 | 26.07 | -29.11 | 55.18 | -1.12 | 2.1E-04 | 0.0002 | 0.7762 | 0.25 |
| BLOCK 12 12 | 1 | 26.09 | -29.13 | 55.22 | -1.12 | 2.1E-04 | 0.0002 | 0.7773 | 0.25 |
| BLOCK 18 18 | 1 | 26.11 | -29.16 | 55.27 | -1.12 | 2.1E-04 | 0.0002 | 0.7787 | 0.25 |
| BLOCK 24 24 | 1 | 26.14 | -29.18 | 55.32 | -1.12 | 2.1E-04 | 0.0002 | 0.7800 | 0.25 |
| BLOCK 30 30 | 1 | 26.16 | -29.21 | 55.37 | -1.12 | 2.1E-04 | 0.0002 | 0.7812 | 0.25 |
| BLOCK 36 36 | 1 | 26.18 | -29.23 | 55.42 | -1.12 | 2.1E-04 | 0.0002 | 0.7825 | 0.25 |
| BLOCK 42 42 | 1 | 26.21 | -29.26 | 55.46 | -1.12 | 2.1E-04 | 0.0002 | 0.7837 | 0.25 |
| BLOCK 48 48 | 1 | 26.23 | -29.28 | 55.51 | -1.12 | 2.1E-04 | 0.0002 | 0.7850 | 0.25 |
| BLOCK 54 54 | 1 | 26.25 | -29.31 | 55.56 | -1.12 | 2.1E-04 | 0.0002 | 0.7862 | 0.25 |
| BLOCK 60 60 | 1 | 26.28 | -29.34 | 55.61 | -1.12 | 2.1E-04 | 0.0002 | 0.7875 | 0.25 |
| BLOCK 66 66 | 1 | 26.30 | -29.36 | 55.66 | -1.12 | 2.1E-04 | 0.0002 | 0.7888 | 0.25 |
| BLOCK 72 72 | 1 | 26.32 | -29.39 | 55.71 | -1.12 | 2.1E-04 | 0.0002 | 0.7900 | 0.25 |
| BLOCK 78 | | | | | | | | | |

| | | | | | | | | | |
|------------------|---|-------|--------|-------|-------|---------|--------|--------|------|
| 78 | 1 | 26.35 | -29.41 | 55.76 | -1.12 | 2.1E-04 | 0.0002 | 0.7913 | 0.26 |
| BLOCK 84 84 | 1 | 26.37 | -29.44 | 55.81 | -1.12 | 2.1E-04 | 0.0002 | 0.7926 | 0.26 |
| BLOCK 90 90 | 1 | 26.39 | -29.46 | 55.86 | -1.12 | 2.1E-04 | 0.0002 | 0.7939 | 0.26 |
| BLOCK 96 96 | 1 | 26.42 | -29.49 | 55.91 | -1.12 | 2.2E-04 | 0.0002 | 0.7952 | 0.26 |
| BLOCK 102 102 | 1 | 26.44 | -29.52 | 55.96 | -1.12 | 2.2E-04 | 0.0002 | 0.7965 | 0.26 |
| BLOCK 108 108 | 1 | 26.47 | -29.54 | 56.01 | -1.12 | 2.2E-04 | 0.0002 | 0.7978 | 0.26 |
| BLOCK 114 114 | 1 | 26.49 | -29.57 | 56.06 | -1.12 | 2.2E-04 | 0.0002 | 0.7991 | 0.26 |
| BLOCK 120 120 | 1 | 26.52 | -29.59 | 56.11 | -1.12 | 2.2E-04 | 0.0002 | 0.8004 | 0.26 |
| BLOCK 126 126 | 1 | 26.54 | -29.62 | 56.16 | -1.12 | 2.2E-04 | 0.0002 | 0.8017 | 0.26 |
| BLOCK 132 132 | 1 | 26.56 | -29.65 | 56.21 | -1.12 | 2.2E-04 | 0.0002 | 0.8030 | 0.26 |
| BLOCK 138 138 | 1 | 26.59 | -29.67 | 56.26 | -1.12 | 2.2E-04 | 0.0002 | 0.8043 | 0.26 |
| BLOCK 144 144 | 1 | 26.61 | -29.70 | 56.31 | -1.12 | 2.2E-04 | 0.0002 | 0.8056 | 0.26 |
| BLOCK 150 150 | 1 | 26.64 | -29.73 | 56.36 | -1.12 | 2.2E-04 | 0.0002 | 0.8069 | 0.26 |
| BLOCK 156 156 | 1 | 26.66 | -29.75 | 56.41 | -1.12 | 2.2E-04 | 0.0002 | 0.8083 | 0.26 |

| | | | | | | | | | |
|-----------|---|-------|--------|-------|-------|---------|--------|--------|------|
| BLOCK 162 | | | | | | | | | |
| 162 | 1 | 26.69 | -29.78 | 56.46 | -1.12 | 2.2E-04 | 0.0002 | 0.8098 | 0.26 |
| BLOCK 168 | | | | | | | | | |
| 168 | 1 | 26.71 | -29.81 | 56.52 | -1.12 | 2.2E-04 | 0.0002 | 0.8109 | 0.26 |
| BLOCK 174 | | | | | | | | | |
| 174 | 1 | 26.74 | -29.83 | 56.57 | -1.12 | 2.2E-04 | 0.0002 | 0.8123 | 0.26 |
| BLOCK 180 | | | | | | | | | |
| 180 | 1 | 26.76 | -29.86 | 56.62 | -1.12 | 2.2E-04 | 0.0002 | 0.8136 | 0.26 |
| BLOCK 186 | | | | | | | | | |
| 186 | 1 | 26.78 | -29.89 | 56.67 | -1.12 | 2.2E-04 | 0.0002 | 0.8150 | 0.26 |
| BLOCK 192 | | | | | | | | | |
| 192 | 1 | 26.81 | -29.91 | 56.72 | -1.12 | 2.3E-04 | 0.0002 | 0.8163 | 0.26 |
| BLOCK 198 | | | | | | | | | |
| 198 | 1 | 26.83 | -29.94 | 56.77 | -1.12 | 2.3E-04 | 0.0002 | 0.8177 | 0.26 |
| BLOCK 204 | | | | | | | | | |
| 204 | 1 | 26.86 | -29.97 | 56.82 | -1.12 | 2.3E-04 | 0.0002 | 0.8190 | 0.26 |
| BLOCK 210 | | | | | | | | | |
| 210 | 1 | 26.88 | -29.99 | 56.88 | -1.12 | 2.3E-04 | 0.0002 | 0.8204 | 0.26 |
| BLOCK 216 | | | | | | | | | |
| 216 | 1 | 26.91 | -30.02 | 56.93 | -1.12 | 2.3E-04 | 0.0002 | 0.8218 | 0.27 |
| BLOCK 222 | | | | | | | | | |
| 222 | 1 | 26.93 | -30.05 | 56.98 | -1.12 | 2.3E-04 | 0.0002 | 0.8231 | 0.27 |
| BLOCK 228 | | | | | | | | | |
| 228 | 1 | 26.96 | -30.07 | 57.03 | -1.12 | 2.3E-04 | 0.0002 | 0.8245 | 0.27 |
| BLOCK 234 | | | | | | | | | |
| 234 | 1 | 26.98 | -30.10 | 57.09 | -1.12 | 2.3E-04 | 0.0002 | 0.8259 | 0.27 |
| BLOCK 240 | | | | | | | | | |

pc-CRACK VERSION 2.1

PAGE 5

240 1 27.01 -30.13 57.14 -1.12 2.3E-04 0.0002 0.8273 0.27

END OF pc-CRACK

tm
 pc-CRACK
 (C) COPYRIGHT 1984, 1990
 STRUCTURAL INTEGRITY ASSOCIATES, INC.
 SAN JOSE, CA (408)978-8200
 VERSION 2.1

Date: 23-May-1992
 Time: 11:50:18.99

FATIGUE CRACK GROWTH ANALYSIS

AND-1 CODE CASE N-481 EVALUATION - LOCATION NO.3

INITIAL CRACK SIZE= 1.1875
 WALL THICKNESS= 4.7500
 MAX CRACK SIZE FOR FCG= 2.3750
 TEMPERATURE= 550.0

ASME SECTION XI: AUSTENITIC STEEL WITH AIR ENVIRONMENT

$$da/dN = C * 10^F * S * dK^{3.3}$$

where

$$S = \begin{cases} 1.0 & \text{for } R < 0 \\ 1.0 + 1.8 * R & \text{for } 0 < R < 0.79 \\ -43.35 + 57.97 * R & \text{for } 0.79 < R < 1 \end{cases}$$

F = code specified function of temperature
 dK = Kmax - Kmin
 R = Kmin / Kmax

WHERE:

C * 10^F = 1.84033E-10
 IS FOR THE CURRENTLY ASSUMED UNITS OF:
 FORCE: kips LENGTH: inches TEMPERATURE: Fahrenheit

| CASE ID | STRESS COEFFICIENTS | | | |
|-----------|---------------------|----------|--------|--------|
| | C0 | C1 | C2 | C3 |
| TRANS-A | 37.0000 | -10.6526 | 0.0000 | 0.0000 |
| TRANS-B | -8.8000 | 5.5579 | 0.0000 | 0.0000 |
| EMERGENCY | 38.3000 | -6.4000 | 0.0000 | 0.0000 |

NUMBER OF CYCLE BLOCKS= 240
 PRINT INCREMENT OF CYCLE BLOCK= 6

| SUBBLOCK | NUMBER OF CYCLES | CALCULATION INCREMENT | PRINT INCREMENT | FCG |
|----------|------------------|-----------------------|-----------------|------------------------|
| | | | | LAW ID |
| 1 | 1 | 1 | 1 | SECT XI AUSTENITIC/AIR |

| SUBBLOCK | CASE ID | Kmax | CASE ID | Kmin |
|----------|---------|--------------|---------|--------------|
| | | SCALE FACTOR | | SCALE FACTOR |
| 1 | TRANS-A | 1.0000 | TRANS-B | 1.0000 |

crack model: ELLIPTICAL SURFACE CRACK PLATE UNDER MEMBRANE & BENDING STRESSES

| CRACK SIZE | STRESS INTENSITY FACTOR | | |
|---------------|-------------------------|-----------------|-------------------|
| | CASE TRANS-A | CASE TRANS-B | CASE EMERGENCY |
| 0.0475 | 14.946 | -3.143 | 15.662 |
| 0.0950 | 20.993 | -4.369 | 22.074 |
| 0.1425 | 25.533 | -5.257 | 26.943 |
| 0.1900 | 29.279 | -5.963 | 31.004 |
| 0.2375 | 32.505 | -6.547 | 34.544 |
| 0.2850 | 35.357 | -7.040 | 37.711 |
| 0.3325 | 37.919 | -7.462 | 40.591 |
| 0.3800 | 40.248 | -7.825 | 43.242 |
| 0.4275 | 42.382 | -8.138 | 45.705 |
| 0.4750 | 44.351 | -8.408 | 48.009 |
| 0.5225 | 46.234 | -8.611 | 50.303 |
| 0.5700 | 47.995 | -8.778 | 52.489 |
| 0.6175 | 49.649 | -8.911 | 54.580 |
| 0.6650 | 51.205 | -9.014 | 56.585 |
| 0.7125 | 52.673 | -9.089 | 58.515 |
| 0.7600 | 54.061 | -9.137 | 60.375 |
| 0.8075 | 55.374 | -9.161 | 62.173 |
| 0.8550 | 56.619 | -9.162 | 63.913 |
| 0.9025 | 57.801 | -9.141 | 65.601 |
| 0.9500 | 58.922 | -9.099 | 67.240 |
| 0.9975 | 60.120 | -9.112 | 68.894 |
| 1.0450 | 61.272 | -9.110 | 70.509 |
| 1.0925 | 62.380 | -9.093 | 72.087 |
| 1.1400 | 63.447 | -9.063 | 73.631 |
| 1.1875 | 64.475 | -9.019 | 75.143 |
| 1.2350 | 65.466 | -8.962 | 76.624 |
| 1.2825 | 66.422 | -8.893 | 78.076 |
| 1.3300 | 67.344 | -8.812 | 79.502 |
| 1.3775 | 68.234 | -8.719 | 80.902 |
| 1.4250 | 69.093 | -8.615 | 82.278 |
| 1.4725 | 70.157 | -8.464 | 84.018 |
| 1.5200 | 71.199 | -8.300 | 85.749 |
| 1.5675 | 72.222 | -8.126 | 87.471 |
| 1.6150 | 73.226 | -7.940 | 89.185 |
| 1.6625 | 74.211 | -7.744 | 90.892 |
| 1.7100 | 75.179 | -7.537 | 92.591 |
| 1.7575 | 76.130 | -7.320 | 94.284 |
| 1.8050 | 77.065 | -7.093 | 95.971 |
| 1.8525 | 77.984 | -6.856 | 97.652 |
| 1.9000 | 78.888 | -6.610 | 99.328 |
| 1.9475 | 80.218 | -6.487 | 101.394 |
| 1.9950 | 81.545 | -6.359 | 103.465 |
| 2.0425 | 82.869 | -6.224 | 105.542 |
| 2.0900 | 84.190 | -6.084 | 107.624 |
| 2.1375 | 85.508 | -5.938 | 109.711 |
| 2.1850 | 86.824 | -5.787 | 111.805 |
| 2.2325 | 88.138 | -5.630 | 113.904 |

| | | | |
|--------|--------|--------|---------|
| 2.2800 | 89.449 | -5.468 | 116.010 |
| 2.3275 | 90.759 | -5.301 | 118.122 |
| 2.3750 | 92.068 | -5.129 | 120.240 |

| TOTAL CYCLE | SUBBLOCK CYCLE | KMAX | KMIN | DELTAK | R | DADN | DA | A | A/T |
|----------------|-------------------|-------|-------|--------|-------|---------|--------|--------|------|
| BLOCK 6 6 | 1 | 64.50 | -9.02 | 73.52 | -0.14 | 2.7E-04 | 0.0003 | 1.1891 | 0.25 |
| BLOCK 12 12 | 1 | 64.54 | -9.02 | 73.55 | -0.14 | 2.7E-04 | 0.0003 | 1.1907 | 0.25 |
| BLOCK 18 18 | 1 | 64.57 | -9.01 | 73.58 | -0.14 | 2.7E-04 | 0.0003 | 1.1923 | 0.25 |
| BLOCK 24 24 | 1 | 64.60 | -9.01 | 73.61 | -0.14 | 2.7E-04 | 0.0003 | 1.1939 | 0.25 |
| BLOCK 30 30 | 1 | 64.64 | -9.01 | 73.65 | -0.14 | 2.7E-04 | 0.0003 | 1.1955 | 0.25 |
| BLOCK 36 36 | 1 | 64.67 | -9.01 | 73.68 | -0.14 | 2.7E-04 | 0.0003 | 1.1971 | 0.25 |
| BLOCK 42 42 | 1 | 64.70 | -9.01 | 73.71 | -0.14 | 2.7E-04 | 0.0003 | 1.1987 | 0.25 |
| BLOCK 48 48 | 1 | 64.74 | -9.00 | 73.74 | -0.14 | 2.7E-04 | 0.0003 | 1.2003 | 0.25 |
| BLOCK 54 54 | 1 | 64.77 | -9.00 | 73.77 | -0.14 | 2.7E-04 | 0.0003 | 1.2019 | 0.25 |
| BLOCK 60 60 | 1 | 64.80 | -9.00 | 73.80 | -0.14 | 2.7E-04 | 0.0003 | 1.2035 | 0.25 |
| BLOCK 66 66 | 1 | 64.84 | -9.00 | 73.84 | -0.14 | 2.7E-04 | 0.0003 | 1.2051 | 0.25 |

| | | | | | | | | | |
|-----------|---|-------|-------|-------|-------|---------|--------|--------|------|
| BLOCK 72 | 1 | 64.87 | -9.00 | 73.87 | -0.14 | 2.7E-04 | 0.0003 | 1.2068 | 0.25 |
| BLOCK 78 | 1 | 64.90 | -8.99 | 73.90 | -0.14 | 2.7E-04 | 0.0003 | 1.2084 | 0.25 |
| BLOCK 84 | 1 | 64.94 | -8.99 | 73.93 | -0.14 | 2.7E-04 | 0.0003 | 1.2100 | 0.25 |
| BLOCK 90 | 1 | 64.97 | -8.99 | 73.96 | -0.14 | 2.7E-04 | 0.0003 | 1.2116 | 0.26 |
| BLOCK 96 | 1 | 65.01 | -8.99 | 73.99 | -0.14 | 2.7E-04 | 0.0003 | 1.2132 | 0.26 |
| BLOCK 102 | 1 | 65.04 | -8.99 | 74.03 | -0.14 | 2.7E-04 | 0.0003 | 1.2149 | 0.26 |
| BLOCK 108 | 1 | 65.07 | -8.98 | 74.06 | -0.14 | 2.7E-04 | 0.0003 | 1.2165 | 0.26 |
| BLOCK 114 | 1 | 65.11 | -8.98 | 74.09 | -0.14 | 2.7E-04 | 0.0003 | 1.2181 | 0.26 |
| BLOCK 120 | 1 | 65.14 | -8.98 | 74.12 | -0.14 | 2.7E-04 | 0.0003 | 1.2198 | 0.26 |
| BLOCK 126 | 1 | 65.18 | -8.98 | 74.16 | -0.14 | 2.7E-04 | 0.0003 | 1.2214 | 0.26 |
| BLOCK 132 | 1 | 65.21 | -8.98 | 74.19 | -0.14 | 2.7E-04 | 0.0003 | 1.2230 | 0.26 |
| BLOCK 138 | 1 | 65.25 | -8.97 | 74.22 | -0.14 | 2.7E-04 | 0.0003 | 1.2247 | 0.26 |
| BLOCK 144 | 1 | 65.28 | -8.97 | 74.25 | -0.14 | 2.7E-04 | 0.0003 | 1.2263 | 0.26 |
| BLOCK 150 | | | | | | | | | |

| | | | | | | | | | |
|-----------|---|-------|-------|-------|-------|---------|--------|--------|------|
| 150 | 1 | 65.31 | -8.97 | 74.28 | -0.14 | 2.7E-04 | 0.0003 | 1.2280 | 0.26 |
| BLOCK 156 | | | | | | | | | |
| 156 | 1 | 65.35 | -8.97 | 74.32 | -0.14 | 2.8E-04 | 0.0003 | 1.2296 | 0.26 |
| BLOCK 162 | | | | | | | | | |
| 162 | 1 | 65.38 | -8.97 | 74.35 | -0.14 | 2.8E-04 | 0.0003 | 1.2313 | 0.26 |
| BLOCK 168 | | | | | | | | | |
| 168 | 1 | 65.42 | -8.96 | 74.38 | -0.14 | 2.8E-04 | 0.0003 | 1.2329 | 0.26 |
| BLOCK 174 | | | | | | | | | |
| 174 | 1 | 65.45 | -8.96 | 74.41 | -0.14 | 2.8E-04 | 0.0003 | 1.2346 | 0.26 |
| BLOCK 180 | | | | | | | | | |
| 180 | 1 | 65.49 | -8.96 | 74.45 | -0.14 | 2.8E-04 | 0.0003 | 1.2363 | 0.26 |
| BLOCK 186 | | | | | | | | | |
| 186 | 1 | 65.52 | -8.96 | 74.48 | -0.14 | 2.8E-04 | 0.0003 | 1.2379 | 0.26 |
| BLOCK 192 | | | | | | | | | |
| 192 | 1 | 65.55 | -8.96 | 74.51 | -0.14 | 2.8E-04 | 0.0003 | 1.2396 | 0.26 |
| BLOCK 198 | | | | | | | | | |
| 198 | 1 | 65.59 | -8.95 | 74.54 | -0.14 | 2.8E-04 | 0.0003 | 1.2412 | 0.26 |
| BLOCK 204 | | | | | | | | | |
| 204 | 1 | 65.62 | -8.95 | 74.57 | -0.14 | 2.8E-04 | 0.0003 | 1.2429 | 0.26 |
| BLOCK 210 | | | | | | | | | |
| 210 | 1 | 65.65 | -8.95 | 74.60 | -0.14 | 2.8E-04 | 0.0003 | 1.2446 | 0.26 |
| BLOCK 216 | | | | | | | | | |
| 216 | 1 | 65.69 | -8.95 | 74.63 | -0.14 | 2.8E-04 | 0.0003 | 1.2463 | 0.26 |
| BLOCK 222 | | | | | | | | | |
| 222 | 1 | 65.72 | -8.94 | 74.66 | -0.14 | 2.8E-04 | 0.0003 | 1.2479 | 0.26 |
| BLOCK 228 | | | | | | | | | |
| 228 | 1 | 65.75 | -8.94 | 74.70 | -0.14 | 2.8E-04 | 0.0003 | 1.2496 | 0.26 |

BLOCK 234
234 1 65.79 -8.94 74.73 -0.14 2.8E-04 0.0003 1.2513 0.26

BLOCK 240
240 1 65.82 -8.94 74.76 -0.14 2.8E-04 0.0003 1.2530 0.26

END OF pc-CRACK

Date: 23-May-1992
 Time: 12:20: 9.40

FATIGUE CRACK GROWTH ANALYSIS

AND-1 CODE CASE N-481 EVALUATION - LOCATION NO. 4

INITIAL CRACK SIZE= 1.1875
 WALL THICKNESS= 4.7500
 MAX CRACK SIZE FOR FCG= 2.3750
 TEMPERATURE= 150.0

ASME SECTION XI: AUSTENITIC STEEL WITH AIR ENVIRONMENT

$$da/dN = C \cdot 10^{\frac{1}{3}} \cdot S \cdot \Delta K^{3.3}$$

where

$$S = \begin{cases} 1.0 & \text{for } R < 0 \\ 1.0 + 1.8 \cdot R & \text{for } 0 < R < 0.79 \\ -43.35 + 57.97 \cdot R & \text{for } 0.79 < R < 1 \end{cases}$$

F = code specified function of temperature
 $\Delta K = K_{max} - K_{min}$
 $R = K_{min} / K_{max}$

WHERE:

$C \cdot 10^{\frac{1}{3}}$ = 1.84033E-10
 IS FOR THE CURRENTLY ASSUMED UNITS OF:
 FORCE: kips LENGTH: inches TEMPERATURE: Fahrenheit

| CASE ID | STRESS COEFFICIENTS | | | |
|-----------|---------------------|----------|--------|--------|
| | C0 | C1 | C2 | C3 |
| TRANS-A | 36.9000 | -10.6105 | 0.0000 | 0.0000 |
| TRANS-B | -9.3000 | 5.9368 | 0.0000 | 0.0000 |
| EMERGENCY | 38.3000 | -6.4000 | 0.0000 | 0.0000 |

NUMBER OF CYCLE BLOCKS= 240
 PRINT INCREMENT OF CYCLE BLOCK= 6

| SUBBLOCK | NUMBER OF CYCLES | CALCULATION INCREMENT | PRINT INCREMENT | FCG LAW ID | |
|----------|------------------|-----------------------|-----------------|------------|------------------------|
| | | | | 1 | 2 |
| 1 | 1 | 1 | 1 | 1 | SECT XI AUSTENITIC/AIR |

| SUBBLOCK | CASE ID | Kmax | | Kmin | |
|----------|---------|--------------|--------------|---------|--------------|
| | | SCALE FACTOR | SCALE FACTOR | CASE ID | SCALE FACTOR |
| 1 | TRANS-A | 1.0000 | | TRANS-B | 1.0000 |

crack model: ELLIPTICAL SURFACE CRACK PLATE UNDER MEMBRANE & BENDING STRESSES

| CRACK SIZE | -----STRESS INTENSITY FACTOR----- | | |
|---------------|-----------------------------------|-----------------|-------------------|
| | CASE TRANS-A | CASE TRANS-B | CASE EMERGENCY |
| 0.0475 | 14.907 | -3.319 | 15.602 |
| 0.0950 | 20.937 | -4.613 | 22.074 |
| 0.1425 | 25.466 | -5.550 | 26.943 |
| 0.1900 | 29.201 | -6.293 | 31.004 |
| 0.2375 | 32.420 | -6.907 | 34.544 |
| 0.2850 | 35.265 | -7.426 | 37.711 |
| 0.3325 | 37.821 | -7.869 | 40.591 |
| 0.3800 | 40.144 | -8.249 | 43.242 |
| 0.4275 | 42.273 | -8.577 | 45.705 |
| 0.4750 | 44.237 | -8.859 | 48.009 |
| 0.5225 | 46.116 | -9.070 | 50.303 |
| 0.5700 | 47.874 | -9.242 | 52.489 |
| 0.6175 | 49.524 | -9.378 | 54.580 |
| 0.6650 | 51.077 | -9.482 | 56.585 |
| 0.7125 | 52.542 | -9.555 | 58.515 |
| 0.7600 | 53.927 | -9.601 | 60.375 |
| 0.8075 | 55.239 | -9.621 | 62.173 |
| 0.8550 | 56.482 | -9.616 | 63.913 |
| 0.9025 | 57.661 | -9.588 | 65.601 |
| 0.9500 | 58.761 | -9.538 | 67.240 |
| 0.9975 | 59.977 | -9.547 | 68.894 |
| 1.0450 | 61.127 | -9.539 | 70.509 |
| 1.0925 | 62.233 | -9.516 | 72.087 |
| 1.1400 | 63.299 | -9.478 | 73.631 |
| 1.1875 | 64.325 | -9.426 | 75.143 |
| 1.2350 | 65.315 | -9.360 | 76.624 |
| 1.2825 | 66.269 | -9.281 | 78.076 |
| 1.3300 | 67.190 | -9.190 | 79.502 |
| 1.3775 | 68.079 | -9.086 | 80.902 |
| 1.4250 | 68.937 | -8.970 | 82.278 |
| 1.4725 | 70.000 | -8.802 | 84.018 |
| 1.5200 | 71.041 | -8.621 | 85.749 |
| 1.5675 | 72.063 | -8.429 | 87.471 |
| 1.6150 | 73.066 | -8.224 | 89.185 |
| 1.6625 | 74.051 | -8.008 | 90.892 |
| 1.7100 | 75.018 | -7.781 | 92.591 |
| 1.7575 | 75.969 | -7.542 | 94.284 |
| 1.8050 | 76.903 | -7.293 | 95.971 |
| 1.8525 | 77.822 | -7.034 | 97.652 |
| 1.9000 | 78.725 | -6.764 | 99.328 |
| 1.9475 | 80.054 | -6.526 | 101.394 |
| 1.9950 | 81.379 | -6.481 | 103.465 |
| 2.0425 | 82.702 | -6.331 | 105.542 |
| 2.0900 | 84.021 | -6.174 | 107.624 |
| 2.1375 | 85.338 | -6.010 | 109.711 |
| 2.1850 | 86.652 | -5.841 | 111.805 |
| 2.2325 | 87.965 | -5.667 | 113.904 |

| | | | |
|--------|--------|--------|---------|
| 2.2800 | 89.275 | -5.486 | 116.010 |
| 2.3275 | 90.584 | -5.300 | 118.122 |
| 2.3750 | 91.891 | -5.108 | 120.240 |

| TOTAL CYCLE | SUBBLOCK CYCLE | KMAX | KMIN | DELTAK | R | DADN | DA | A | A/T |
|-------------|----------------|------|-------|--------|-------|-------|---------|--------|-------------|
| BLOCK 6 | 6 | 1 | 64.35 | -9.42 | 73.78 | -0.15 | 2.7E-04 | 0.0003 | 1.1871 0.25 |
| BLOCK 12 | 12 | 1 | 64.39 | -9.42 | 73.81 | -0.15 | 2.7E-04 | 0.0003 | 1.1907 0.25 |
| BLOCK 18 | 18 | 1 | 64.42 | -9.42 | 73.84 | -0.15 | 2.7E-04 | 0.0003 | 1.1923 0.25 |
| BLOCK 24 | 24 | 1 | 64.45 | -9.42 | 73.87 | -0.15 | 2.7E-04 | 0.0003 | 1.1940 0.25 |
| BLOCK 30 | 30 | 1 | 64.49 | -9.42 | 73.90 | -0.15 | 2.7E-04 | 0.0003 | 1.1956 0.25 |
| BLOCK 36 | 36 | 1 | 64.52 | -9.41 | 73.93 | -0.15 | 2.7E-04 | 0.0003 | 1.1972 0.25 |
| BLOCK 42 | 42 | 1 | 64.56 | -9.41 | 73.97 | -0.15 | 2.7E-04 | 0.0003 | 1.1988 0.25 |
| BLOCK 48 | 48 | 1 | 64.59 | -9.41 | 74.00 | -0.15 | 2.7E-04 | 0.0003 | 1.2004 0.25 |
| BLOCK 54 | 54 | 1 | 64.62 | -9.41 | 74.03 | -0.15 | 2.7E-04 | 0.0003 | 1.2021 0.25 |
| BLOCK 60 | 60 | 1 | 64.66 | -9.40 | 74.06 | -0.15 | 2.7E-04 | 0.0003 | 1.2037 0.25 |
| BLOCK 66 | 66 | 1 | 64.69 | -9.40 | 74.09 | -0.15 | 2.7E-04 | 0.0003 | 1.2053 0.25 |

| | | | | | | | | | |
|-----------|---|-------|-------|-------|-------|---------|--------|--------|------|
| BLOCK 72 | 1 | 64.73 | -9.40 | 74.12 | -0.15 | 2.7E-04 | 0.0003 | 1.2070 | 0.25 |
| BLOCK 78 | 1 | 64.76 | -9.40 | 74.16 | -0.15 | 2.7E-04 | 0.0003 | 1.2086 | 0.25 |
| BLOCK 84 | 1 | 64.79 | -9.40 | 74.19 | -0.14 | 2.7E-04 | 0.0003 | 1.2103 | 0.25 |
| BLOCK 90 | 1 | 64.83 | -9.39 | 74.22 | -0.14 | 2.7E-04 | 0.0003 | 1.2119 | 0.26 |
| BLOCK 96 | 1 | 64.86 | -9.39 | 74.25 | -0.14 | 2.7E-04 | 0.0003 | 1.2135 | 0.26 |
| BLOCK 102 | 1 | 64.90 | -9.39 | 74.28 | -0.14 | 2.7E-04 | 0.0003 | 1.2152 | 0.26 |
| BLOCK 108 | 1 | 64.93 | -9.39 | 74.32 | -0.14 | 2.8E-04 | 0.0003 | 1.2168 | 0.26 |
| BLOCK 114 | 1 | 64.96 | -9.38 | 74.35 | -0.14 | 2.8E-04 | 0.0003 | 1.2185 | 0.26 |
| BLOCK 120 | 1 | 65.00 | -9.38 | 74.38 | -0.14 | 2.8E-04 | 0.0003 | 1.2201 | 0.26 |
| BLOCK 126 | 1 | 65.03 | -9.38 | 74.41 | -0.14 | 2.8E-04 | 0.0003 | 1.2218 | 0.26 |
| BLOCK 132 | 1 | 65.07 | -9.38 | 74.45 | -0.14 | 2.8E-04 | 0.0003 | 1.2233 | 0.26 |
| BLOCK 138 | 1 | 65.10 | -9.37 | 74.48 | -0.14 | 2.8E-04 | 0.0003 | 1.2251 | 0.26 |
| BLOCK 144 | 1 | 65.14 | -9.37 | 74.51 | -0.14 | 2.8E-04 | 0.0003 | 1.2268 | 0.26 |
| BLOCK 150 | | | | | | | | | |

| | | | | | | | | | |
|-----------|---|-------|-------|-------|-------|---------|--------|--------|------|
| 150 | 1 | 65.17 | -9.37 | 74.54 | -0.14 | 2.8E-04 | 0.0003 | 1.2285 | 0.26 |
| BLOCK 156 | | | | | | | | | |
| 156 | 1 | 65.21 | -9.37 | 74.57 | -0.14 | 2.8E-04 | 0.0003 | 1.2301 | 0.26 |
| BLOCK 162 | | | | | | | | | |
| 162 | 1 | 65.24 | -9.37 | 74.61 | -0.14 | 2.8E-04 | 0.0003 | 1.2318 | 0.26 |
| BLOCK 168 | | | | | | | | | |
| 168 | 1 | 65.28 | -9.36 | 74.64 | -0.14 | 2.8E-04 | 0.0003 | 1.2335 | 0.26 |
| BLOCK 174 | | | | | | | | | |
| 174 | 1 | 65.31 | -9.36 | 74.67 | -0.14 | 2.8E-04 | 0.0003 | 1.2351 | 0.26 |
| BLOCK 180 | | | | | | | | | |
| 180 | 1 | 65.35 | -9.36 | 74.70 | -0.14 | 2.8E-04 | 0.0003 | 1.2368 | 0.26 |
| BLOCK 186 | | | | | | | | | |
| 186 | 1 | 65.38 | -9.36 | 74.73 | -0.14 | 2.8E-04 | 0.0003 | 1.2385 | 0.26 |
| BLOCK 192 | | | | | | | | | |
| 192 | 1 | 65.41 | -9.35 | 74.77 | -0.14 | 2.8E-04 | 0.0003 | 1.2402 | 0.26 |
| BLOCK 198 | | | | | | | | | |
| 198 | 1 | 65.45 | -9.35 | 74.80 | -0.14 | 2.8E-04 | 0.0003 | 1.2419 | 0.26 |
| BLOCK 204 | | | | | | | | | |
| 204 | 1 | 65.48 | -9.35 | 74.83 | -0.14 | 2.8E-04 | 0.0003 | 1.2436 | 0.26 |
| BLOCK 210 | | | | | | | | | |
| 210 | 1 | 65.51 | -9.34 | 74.86 | -0.14 | 2.8E-04 | 0.0003 | 1.2452 | 0.26 |
| BLOCK 216 | | | | | | | | | |
| 216 | 1 | 65.55 | -9.34 | 74.89 | -0.14 | 2.8E-04 | 0.0003 | 1.2469 | 0.26 |
| BLOCK 222 | | | | | | | | | |
| 222 | 1 | 65.58 | -9.34 | 74.92 | -0.14 | 2.8E-04 | 0.0003 | 1.2486 | 0.26 |
| BLOCK 228 | | | | | | | | | |
| 228 | 1 | 65.62 | -9.34 | 74.95 | -0.14 | 2.8E-04 | 0.0003 | 1.2503 | 0.26 |

| | | | | | | | | | |
|-----------|---|-------|-------|-------|-------|---------|--------|--------|------|
| BLOCK 234 | | | | | | | | | |
| 234 | 1 | 65.65 | -9.33 | 74.98 | -0.14 | 2.8E-04 | 0.0003 | 1.2520 | 0.26 |
| BLOCK 240 | | | | | | | | | |
| 240 | 1 | 65.69 | -9.33 | 75.01 | -0.14 | 2.8E-04 | 0.0003 | 1.2537 | 0.26 |

END OF pc-CRACK

TR
 DC-CRACK
 (C) COPYRIGHT 1984, 1990
 STRUCTURAL INTEGRITY ASSOCIATES, INC.
 SAN JOSE, CA (408)978-8200
 VERSION 2.1

Date: 5-Jun-1992
 Time: 13:14:52.95

FATIGUE CRACK GROWTH ANALYSIS

AND-1 CODE CASE N-481 EVALUATION - LOCAT.ON NO. 5 (2-D MODEL)

INITIAL CRACK SIZE= 1.3250
 WALL THICKNESS= 5.3000
 MAX CRACK SIZE FOR FCG= 2.6500

PARIS CRACK GROWTH LAW:
 $da/dN = C * (dK)^n$
 where
 $dK = K_{max} - K_{min}$
 $dK > dK_{thres}$
 $K_{max} < K_{Ic}$

CURRENT LAWS:

| LAW ID | C | n | dkthres | KIc |
|-----------|-----------|-------|---------|---------|
| PWR WATER | 3.680E-10 | 3.300 | 0.000 | 135.500 |

STRESS COEFFICIENTS

| CASE ID | C0 | C1 | C2 | C3 |
|------------|---------|----------|--------|--------|
| NORMAL-PRI | 11.0000 | 0.0000 | 0.0000 | 0.0000 |
| NORMAL-SEC | 27.0000 | -6.7925 | 0.0000 | 0.0000 |
| EMER-PRI | 14.0000 | -0.0000 | 0.0000 | 0.0000 |
| EMER-SEC | 34.4000 | -8.6415 | 0.0000 | 0.0000 |
| NORMAL-RNG | 58.0000 | -14.3396 | 0.0000 | 0.0000 |

NUMBER OF CYCLE BLOCKS= 240
 PRINT INCREMENT OF CYCLE BLOCK= 6

| SUBBLOCK | NUMBER OF CYCLES | CALCULATION INCREMENT | PRINT INCREMENT | FCG LAW ID |
|----------|------------------|-----------------------|-----------------|------------|
| 1 | 1 | 1 | 1 | PWR WATER |

| SUBBLOCK | CASE ID | Kmax SCALE FACTOR | CASE ID | Kmin SCALE FACTOR |
|----------|------------|-------------------|------------|-------------------|
| 1 | NORMAL-RNG | 1.0000 | NORMAL-RNG | 0.0000 |

crack model: ELLIPTICAL SURFACE CRACK PLATE UNDER MEMBRANE & BENDING STRESSES
 CRACK -----STRESS INTENSITY FACTOR-----

| SIZE | CASE NORMAL-PRI | CASE NORMAL-SEC | CASE EMER-PRI | CASE EMER-SEC | CASE NORMAL-RNG |
|--------|--------------------|--------------------|------------------|------------------|--------------------|
| 0.0530 | 4.531 | 11.529 | 5.859 | 14.690 | 24.779 |
| 0.1060 | 6.416 | 16.197 | 8.296 | 20.637 | 34.815 |
| 0.1590 | 7.867 | 19.704 | 10.173 | 25.106 | 42.361 |
| 0.2120 | 9.095 | 22.599 | 11.761 | 28.796 | 48.592 |
| 0.2650 | 10.181 | 25.096 | 13.165 | 31.977 | 53.967 |
| 0.3180 | 11.166 | 27.303 | 14.439 | 34.790 | 58.723 |
| 0.3710 | 12.075 | 29.288 | 15.614 | 37.320 | 63.002 |
| 0.4240 | 12.924 | 31.094 | 16.712 | 39.621 | 66.896 |
| 0.4770 | 13.725 | 32.750 | 17.747 | 41.732 | 70.470 |
| 0.5300 | 14.484 | 34.280 | 18.730 | 43.682 | 73.773 |
| 0.5830 | 15.273 | 35.747 | 19.750 | 45.552 | 76.946 |
| 0.6360 | 16.038 | 37.121 | 20.739 | 47.303 | 79.920 |
| 0.6890 | 16.782 | 38.412 | 21.700 | 48.950 | 82.719 |
| 0.7420 | 17.508 | 39.629 | 22.639 | 50.502 | 85.359 |
| 0.7950 | 18.218 | 40.779 | 23.557 | 51.968 | 87.853 |
| 0.8480 | 18.914 | 41.867 | 24.457 | 53.356 | 90.220 |
| 0.9010 | 19.598 | 42.899 | 25.342 | 54.672 | 92.465 |
| 0.9540 | 20.271 | 43.879 | 26.212 | 55.922 | 94.599 |
| 1.0070 | 20.934 | 44.810 | 27.069 | 57.110 | 96.629 |
| 1.0600 | 21.588 | 45.696 | 27.915 | 58.240 | 98.562 |
| 1.1130 | 22.221 | 46.638 | 28.735 | 59.441 | 100.612 |
| 1.1660 | 22.847 | 47.544 | 29.544 | 60.598 | 102.586 |
| 1.2190 | 23.466 | 48.418 | 30.344 | 61.712 | 104.490 |
| 1.2720 | 24.078 | 49.260 | 31.135 | 62.786 | 106.327 |
| 1.3250 | 24.684 | 50.072 | 31.919 | 63.822 | 108.100 |
| 1.3780 | 25.285 | 50.856 | 32.696 | 64.823 | 109.814 |
| 1.4310 | 25.880 | 51.613 | 33.466 | 65.789 | 111.470 |
| 1.4840 | 26.471 | 52.345 | 34.230 | 66.723 | 113.072 |
| 1.5370 | 27.058 | 53.052 | 34.989 | 67.626 | 114.622 |
| 1.5900 | 27.641 | 53.736 | 35.742 | 68.499 | 116.123 |
| 1.6430 | 28.388 | 54.584 | 36.708 | 69.581 | 117.986 |
| 1.6960 | 29.137 | 55.417 | 37.676 | 70.644 | 119.816 |
| 1.7490 | 29.888 | 56.235 | 38.648 | 71.688 | 121.615 |
| 1.8020 | 30.641 | 57.038 | 39.622 | 72.714 | 123.385 |
| 1.8550 | 31.396 | 57.829 | 40.599 | 73.723 | 125.126 |
| 1.9080 | 32.154 | 58.606 | 41.579 | 74.715 | 126.840 |
| 1.9610 | 32.915 | 59.370 | 42.562 | 75.692 | 128.528 |
| 2.0140 | 33.678 | 60.123 | 43.549 | 76.653 | 130.190 |
| 2.0670 | 34.443 | 60.864 | 44.539 | 77.599 | 131.829 |
| 2.1200 | 35.212 | 61.593 | 45.532 | 78.531 | 133.444 |
| 2.1730 | 36.070 | 62.649 | 46.643 | 79.879 | 135.756 |
| 2.2260 | 36.934 | 63.703 | 47.759 | 81.274 | 138.065 |
| 2.2790 | 37.803 | 64.755 | 48.883 | 82.566 | 140.369 |
| 2.3320 | 38.676 | 65.805 | 50.012 | 83.906 | 142.671 |
| 2.3850 | 39.555 | 66.853 | 51.148 | 85.244 | 144.969 |
| 2.4380 | 40.438 | 67.900 | 52.290 | 86.580 | 147.265 |
| 2.4910 | 41.326 | 68.945 | 53.439 | 87.914 | 149.558 |
| 2.5440 | 42.220 | 69.990 | 54.594 | 89.247 | 151.849 |
| 2.5970 | 43.118 | 71.037 | 55.756 | 90.579 | 154.139 |
| 2.6500 | 44.021 | 72.075 | 56.923 | 91.909 | 156.427 |

| TOTAL CYCLE | SUBBLOCK CYCLE | KMAX | KMIN | DELTAK | R | DADN | DA | A | A/T |
|-------------|----------------|------|--------|--------|--------|------|---------|--------|-------------|
| BLOCK 6 | 6 | 1 | 108.41 | 0.00 | 108.41 | 0.00 | 1.9E-03 | 0.0019 | 1.3364 0.25 |
| BLOCK 12 | 12 | 1 | 108.78 | 0.00 | 108.78 | 0.00 | 1.9E-03 | 0.0019 | 1.3480 0.25 |
| BLOCK 18 | 18 | 1 | 109.16 | 0.00 | 109.16 | 0.00 | 2.0E-03 | 0.0020 | 1.3597 0.26 |
| BLOCK 24 | 24 | 1 | 109.54 | 0.00 | 109.54 | 0.00 | 2.0E-03 | 0.0020 | 1.3715 0.26 |
| BLOCK 30 | 30 | 1 | 109.92 | 0.00 | 109.92 | 0.00 | 2.0E-03 | 0.0020 | 1.3834 0.26 |
| BLOCK 36 | 36 | 1 | 110.30 | 0.00 | 110.30 | 0.00 | 2.0E-03 | 0.0020 | 1.3955 0.26 |
| BLOCK 42 | 42 | 1 | 110.68 | 0.00 | 110.68 | 0.00 | 2.0E-03 | 0.0020 | 1.4077 0.27 |
| BLOCK 48 | 48 | 1 | 111.07 | 0.00 | 111.07 | 0.00 | 2.1E-03 | 0.0021 | 1.4201 0.27 |
| BLOCK 54 | 54 | 1 | 111.46 | 0.00 | 111.46 | 0.00 | 2.1E-03 | 0.0021 | 1.4326 0.27 |
| BLOCK 60 | 60 | 1 | 111.84 | 0.00 | 111.84 | 0.00 | 2.1E-03 | 0.0021 | 1.4453 0.27 |
| BLOCK 66 | 66 | 1 | 112.22 | 0.00 | 112.22 | 0.00 | 2.1E-03 | 0.0021 | 1.4581 0.28 |
| BLOCK 72 | 72 | 1 | 112.61 | 0.00 | 112.61 | 0.00 | 2.2E-03 | 0.0022 | 1.4710 0.28 |

| | | | | | | | | | | |
|-----------|---|--------|------|--------|------|---------|--------|--------|------|--|
| BLOCK 78 | | | | | | | | | | |
| 78 | 1 | 113.01 | 0.00 | 113.01 | 0.00 | 2.2E-03 | 0.0022 | 1.4841 | 0.28 | |
| BLOCK 84 | | | | | | | | | | |
| 84 | 1 | 113.40 | 0.00 | 113.40 | 0.00 | 2.2E-03 | 0.0022 | 1.4974 | 0.28 | |
| BLOCK 90 | | | | | | | | | | |
| 90 | 1 | 113.79 | 0.00 | 113.79 | 0.00 | 2.2E-03 | 0.0022 | 1.5108 | 0.29 | |
| BLOCK 96 | | | | | | | | | | |
| 96 | 1 | 114.19 | 0.00 | 114.19 | 0.00 | 2.3E-03 | 0.0023 | 1.5243 | 0.29 | |
| BLOCK 102 | | | | | | | | | | |
| 102 | 1 | 114.59 | 0.00 | 114.59 | 0.00 | 2.3E-03 | 0.0023 | 1.5380 | 0.29 | |
| BLOCK 108 | | | | | | | | | | |
| 108 | 1 | 114.98 | 0.00 | 114.98 | 0.00 | 2.3E-03 | 0.0023 | 1.5519 | 0.29 | |
| BLOCK 114 | | | | | | | | | | |
| 114 | 1 | 115.37 | 0.00 | 115.37 | 0.00 | 2.3E-03 | 0.0023 | 1.5659 | 0.30 | |
| BLOCK 120 | | | | | | | | | | |
| 120 | 1 | 115.78 | 0.00 | 115.78 | 0.00 | 2.4E-03 | 0.0024 | 1.5801 | 0.30 | |
| BLOCK 126 | | | | | | | | | | |
| 126 | 1 | 116.20 | 0.00 | 116.20 | 0.00 | 2.4E-03 | 0.0024 | 1.5945 | 0.30 | |
| BLOCK 132 | | | | | | | | | | |
| 132 | 1 | 116.71 | 0.00 | 116.71 | 0.00 | 2.4E-03 | 0.0024 | 1.6090 | 0.30 | |
| BLOCK 138 | | | | | | | | | | |
| 138 | 1 | 117.22 | 0.00 | 117.22 | 0.00 | 2.5E-03 | 0.0025 | 1.6238 | 0.31 | |
| BLOCK 144 | | | | | | | | | | |
| 144 | 1 | 117.75 | 0.00 | 117.75 | 0.00 | 2.5E-03 | 0.0025 | 1.6387 | 0.31 | |
| BLOCK 150 | | | | | | | | | | |
| 150 | 1 | 118.28 | 0.00 | 118.28 | 0.00 | 2.5E-03 | 0.0025 | 1.6540 | 0.31 | |
| BLOCK 156 | | | | | | | | | | |

| | | | | | | | | | |
|-----------|---|--------|------|--------|------|---------|--------|--------|------|
| 156 | 1 | 118.81 | 0.00 | 118.81 | 0.00 | 2.6E-03 | 0.0026 | 1.6694 | 0.31 |
| BLOCK 162 | | | | | | | | | |
| 162 | 1 | 119.35 | 0.00 | 119.35 | 0.00 | 2.6E-03 | 0.0026 | 1.6850 | 0.32 |
| BLOCK 168 | | | | | | | | | |
| 168 | 1 | 119.89 | 0.00 | 119.89 | 0.00 | 2.7E-03 | 0.0027 | 1.7009 | 0.32 |
| BLOCK 174 | | | | | | | | | |
| 174 | 1 | 120.44 | 0.00 | 120.44 | 0.00 | 2.7E-03 | 0.0027 | 1.7171 | 0.32 |
| BLOCK 180 | | | | | | | | | |
| 180 | 1 | 120.99 | 0.00 | 120.99 | 0.00 | 2.7E-03 | 0.0027 | 1.7335 | 0.33 |
| BLOCK 186 | | | | | | | | | |
| 186 | 1 | 121.56 | 0.00 | 121.56 | 0.00 | 2.8E-03 | 0.0028 | 1.7501 | 0.33 |
| BLOCK 192 | | | | | | | | | |
| 192 | 1 | 122.12 | 0.00 | 122.12 | 0.00 | 2.8E-03 | 0.0028 | 1.7670 | 0.33 |
| BLOCK 198 | | | | | | | | | |
| 198 | 1 | 122.69 | 0.00 | 122.69 | 0.00 | 2.9E-03 | 0.0029 | 1.7841 | 0.34 |
| BLOCK 204 | | | | | | | | | |
| 204 | 1 | 123.27 | 0.00 | 123.27 | 0.00 | 2.9E-03 | 0.0029 | 1.8016 | 0.34 |
| BLOCK 210 | | | | | | | | | |
| 210 | 1 | 123.85 | 0.00 | 123.85 | 0.00 | 3.0E-03 | 0.0030 | 1.8192 | 0.34 |
| BLOCK 216 | | | | | | | | | |
| 216 | 1 | 124.44 | 0.00 | 124.44 | 0.00 | 3.0E-03 | 0.0030 | 1.8372 | 0.35 |
| BLOCK 222 | | | | | | | | | |
| 222 | 1 | 125.04 | 0.00 | 125.04 | 0.00 | 3.1E-03 | 0.0031 | 1.8555 | 0.35 |
| BLOCK 228 | | | | | | | | | |
| 228 | 1 | 125.64 | 0.00 | 125.64 | 0.00 | 3.1E-03 | 0.0031 | 1.8740 | 0.35 |
| BLOCK 234 | | | | | | | | | |
| 234 | 1 | 126.25 | 0.00 | 126.25 | 0.00 | 3.2E-03 | 0.0032 | 1.8929 | 0.36 |

| | | | | | | | | | | |
|-------|-----|--------|------|--------|------|---------|--------|--------|------|--|
| BLOCK | 240 | | | | | | | | | |
| 240 | 1 | 126.87 | 0.00 | 126.87 | 0.00 | 3.2E-03 | 0.0032 | 1.9125 | 0.7e | |

END OF pc-CRACK

Date: 5-Jun-1992
 Time: 12:52:10.75

FATIGUE CRACK GROWTH ANALYSIS

ANO-1 CODE CASE N-481 EVALUATION - LOCATION NO.5 (3-D MODEL)

INITIAL CRACK SIZE= 1.3250
 WALL THICKNESS= 5.3000
 MAX CRACK SIZE FOR FCG= 2.6500

PARIS CRACK GROWTH LAW:
 $da/dN = C * (dK)^n$
 where
 $dK = K_{max} - K_{min}$
 $dK > dK_{thres}$
 $K_{max} < K_{Ic}$

| | | | | | |
|---------------|-----------|-----------|-------|---------|---------|
| CURRENT LAWS: | LAW ID | C | n | dKthres | KIc |
| | PWR WATER | 3.680E-10 | 3.300 | 0.000 | 135.500 |

| CASE ID | STRESS COEFFICIENTS | | | |
|------------|---------------------|----------|--------|--------|
| | C0 | C1 | C2 | C3 |
| NORMAL-PRI | 18.0000 | 0.0000 | 0.0000 | 0.0000 |
| NORMAL-SEC | 28.0000 | -10.5660 | 0.0000 | 0.0000 |
| EMER-PRI | 19.0000 | 0.0000 | 0.0000 | 0.0000 |
| EMER-SEC | 29.6000 | -11.1700 | 0.0000 | 0.0000 |
| NORMAL-RNG | 48.0000 | -11.3208 | 0.0000 | 0.0000 |

NUMBER OF CYCLE BLOCKS= 240
 PRINT INCREMENT OF CYCLE BLOCK= 6

| SUBBLOCK | NUMBER OF CYCLES | CALCULATION INCREMENT | PRINT INCREMENT | FCG LAW ID |
|----------|------------------|-----------------------|-----------------|------------|
| 1 | 1 | 1 | 1 | PWR WATER |

| SUBBLOCK | CASE ID | Kmax SCALE FACTOR | CASE ID | Kmin SCALE FACTOR |
|----------|------------|-------------------|------------|-------------------|
| 1 | NORMAL-RNG | 1.0000 | NORMAL-RNG | 0.0000 |

crack model:ELLIPTICAL SURFACE CRACK PLATE UNDER MEMBRANE & BENDING STRESSES
 CRACK -----STRESS INTENSITY FACTOR-----

| SIZE | CASE NORMAL-PRI | CASE NORMAL-SEC | CASE EMER-PRI | CASE EMER-SEC | CASE NORMAL-RNG |
|--------|--------------------|--------------------|------------------|------------------|--------------------|
| 0.0530 | 7.709 | 11.785 | 8.195 | 12.459 | 20.534 |
| 0.1060 | 10.916 | 16.488 | 11.604 | 17.430 | 28.861 |
| 0.1590 | 13.385 | 19.974 | 14.229 | 21.116 | 35.129 |
| 0.2120 | 15.474 | 22.811 | 16.450 | 24.114 | 40.311 |
| 0.2650 | 17.322 | 25.221 | 18.414 | 26.662 | 44.787 |
| 0.3180 | 18.998 | 27.318 | 20.196 | 28.879 | 48.753 |
| 0.3710 | 20.545 | 29.172 | 21.840 | 30.838 | 52.326 |
| 0.4240 | 21.990 | 30.828 | 23.377 | 32.589 | 55.582 |
| 0.4770 | 23.352 | 32.318 | 24.824 | 34.165 | 58.576 |
| 0.5300 | 24.644 | 33.566 | 26.198 | 35.590 | 61.346 |
| 0.5830 | 25.986 | 34.877 | 27.625 | 36.870 | 64.020 |
| 0.6360 | 27.287 | 35.976 | 29.008 | 38.032 | 66.532 |
| 0.6890 | 28.553 | 36.976 | 30.354 | 39.088 | 68.900 |
| 0.7420 | 29.788 | 37.884 | 31.667 | 40.048 | 71.140 |
| 0.7950 | 30.996 | 38.709 | 32.951 | 40.921 | 73.263 |
| 0.8480 | 32.181 | 39.457 | 34.210 | 41.712 | 75.280 |
| 0.9010 | 33.344 | 40.134 | 35.447 | 42.427 | 77.198 |
| 0.9540 | 34.489 | 40.745 | 36.664 | 43.073 | 79.027 |
| 1.0070 | 35.617 | 41.294 | 37.863 | 43.653 | 80.772 |
| 1.0600 | 36.730 | 41.784 | 39.047 | 44.171 | 82.438 |
| 1.1130 | 37.808 | 42.389 | 40.193 | 44.811 | 84.192 |
| 1.1660 | 38.873 | 42.950 | 41.325 | 45.404 | 85.885 |
| 1.2190 | 39.926 | 43.469 | 42.444 | 45.952 | 87.521 |
| 1.2720 | 40.967 | 43.948 | 43.551 | 46.458 | 89.102 |
| 1.3250 | 41.998 | 44.388 | 44.647 | 46.924 | 90.632 |
| 1.3780 | 43.020 | 44.793 | 45.733 | 47.352 | 92.114 |
| 1.4310 | 44.034 | 45.163 | 46.811 | 47.743 | 93.549 |
| 1.4840 | 45.039 | 45.499 | 47.880 | 48.098 | 94.940 |
| 1.5370 | 46.037 | 45.803 | 48.941 | 48.420 | 96.290 |
| 1.5900 | 47.029 | 46.076 | 49.995 | 48.708 | 97.599 |
| 1.6430 | 48.000 | 46.382 | 51.046 | 49.031 | 99.230 |
| 1.6960 | 49.574 | 46.660 | 52.000 | 49.326 | 100.836 |
| 1.7490 | 50.852 | 46.913 | 54.059 | 49.593 | 102.417 |
| 1.8020 | 52.133 | 47.141 | 55.421 | 49.834 | 103.975 |
| 1.8550 | 53.419 | 47.345 | 56.788 | 50.049 | 105.512 |
| 1.9080 | 54.708 | 47.525 | 58.159 | 50.239 | 107.027 |
| 1.9610 | 56.002 | 47.682 | 59.534 | 50.406 | 108.523 |
| 2.0140 | 57.300 | 47.817 | 60.914 | 50.548 | 109.999 |
| 2.0670 | 58.603 | 47.930 | 62.299 | 50.668 | 111.456 |
| 2.1200 | 59.910 | 48.023 | 63.688 | 50.766 | 112.896 |
| 2.1730 | 61.371 | 48.500 | 65.242 | 51.270 | 114.906 |
| 2.2260 | 62.841 | 48.967 | 66.804 | 51.764 | 116.913 |
| 2.2790 | 64.319 | 49.424 | 68.375 | 52.247 | 118.919 |
| 2.3320 | 65.805 | 49.872 | 69.955 | 52.721 | 120.923 |
| 2.3850 | 67.300 | 50.310 | 71.544 | 53.184 | 122.926 |
| 2.4380 | 68.803 | 50.740 | 73.142 | 53.638 | 124.927 |
| 2.4910 | 70.314 | 51.160 | 74.749 | 54.083 | 126.928 |
| 2.5440 | 71.834 | 51.573 | 76.364 | 54.518 | 128.928 |
| 2.5970 | 73.362 | 51.977 | 77.989 | 54.945 | 130.929 |
| 2.6500 | 74.899 | 52.372 | 79.622 | 55.364 | 132.929 |

| TOTAL CYCLE | SUBBLOCK CYCLE | KMAX | KMIN | DELTAK | R | DADN | DA | A | A/T | |
|-------------|----------------|------|-------|--------|-------|------|---------|--------|--------|------|
| BLOCK 6 | 6 | 1 | 90.78 | 0.00 | 90.78 | 0.00 | 1.1E-03 | 0.0011 | 1.3314 | 0.25 |
| BLOCK 12 | 12 | 1 | 90.96 | 0.00 | 90.96 | 0.00 | 1.1E-03 | 0.0011 | 1.3373 | 0.25 |
| BLOCK 18 | 18 | 1 | 91.14 | 0.00 | 91.14 | 0.00 | 1.1E-03 | 0.0011 | 1.3442 | 0.25 |
| BLOCK 24 | 24 | 1 | 91.32 | 0.00 | 91.32 | 0.00 | 1.1E-03 | 0.0011 | 1.3507 | 0.25 |
| BLOCK 30 | 30 | 1 | 91.50 | 0.00 | 91.50 | 0.00 | 1.1E-03 | 0.0011 | 1.3573 | 0.26 |
| BLOCK 36 | 36 | 1 | 91.69 | 0.00 | 91.69 | 0.00 | 1.1E-03 | 0.0011 | 1.3639 | 0.26 |
| BLOCK 42 | 42 | 1 | 91.87 | 0.00 | 91.87 | 0.00 | 1.1E-03 | 0.0011 | 1.3705 | 0.26 |
| BLOCK 48 | 48 | 1 | 92.06 | 0.00 | 92.06 | 0.00 | 1.1E-03 | 0.0011 | 1.3772 | 0.26 |
| BLOCK 54 | 54 | 1 | 92.24 | 0.00 | 92.24 | 0.00 | 1.1E-03 | 0.0011 | 1.3839 | 0.26 |
| BLOCK 60 | 60 | 1 | 92.43 | 0.00 | 92.43 | 0.00 | 1.1E-03 | 0.0011 | 1.3906 | 0.26 |
| BLOCK 66 | 66 | 1 | 92.61 | 0.00 | 92.61 | 0.00 | 1.1E-03 | 0.0011 | 1.3974 | 0.26 |
| BLOCK 72 | 72 | 1 | 92.79 | 0.00 | 92.79 | 0.00 | 1.1E-03 | 0.0011 | 1.4043 | 0.26 |

| | | | | | | | | | |
|-----------|---|-------|------|-------|------|---------|--------|--------|------|
| BLOCK 78 | 1 | 92.98 | 0.00 | 92.98 | 0.00 | 1.2E-03 | 0.0012 | 1.4112 | 0.27 |
| BLOCK 84 | 1 | 93.17 | 0.00 | 93.17 | 0.00 | 1.2E-03 | 0.0012 | 1.4181 | 0.27 |
| BLOCK 90 | 1 | 93.36 | 0.00 | 93.36 | 0.00 | 1.2E-03 | 0.0012 | 1.4231 | 0.27 |
| BLOCK 96 | 1 | 93.55 | 0.00 | 93.55 | 0.00 | 1.2E-03 | 0.0012 | 1.4321 | 0.27 |
| BLOCK 102 | 1 | 93.73 | 0.00 | 93.73 | 0.00 | 1.2E-03 | 0.0012 | 1.4392 | 0.27 |
| BLOCK 108 | 1 | 93.92 | 0.00 | 93.92 | 0.00 | 1.2E-03 | 0.0012 | 1.4463 | 0.27 |
| BLOCK 114 | 1 | 94.11 | 0.00 | 94.1 | 0.00 | 1.2E-03 | 0.0012 | 1.4535 | 0.27 |
| BLOCK 120 | 1 | 94.30 | 0.00 | 94.30 | 0.00 | 1.2E-03 | 0.0012 | 1.4607 | 0.28 |
| BLOCK 126 | 1 | 94.49 | 0.00 | 94.49 | 0.00 | 1.2E-03 | 0.0012 | 1.4680 | 0.28 |
| BLOCK 132 | 1 | 94.68 | 0.00 | 94.68 | 0.00 | 1.2E-03 | 0.0012 | 1.4753 | 0.28 |
| BLOCK 138 | 1 | 94.87 | 0.00 | 94.87 | 0.00 | 1.2E-03 | 0.0012 | 1.4827 | 0.28 |
| BLOCK 144 | 1 | 95.06 | 0.00 | 95.06 | 0.00 | 1.2E-03 | 0.0012 | 1.4901 | 0.28 |
| BLOCK 150 | 1 | 95.25 | 0.00 | 95.25 | 0.00 | 1.2E-03 | 0.0012 | 1.4976 | 0.28 |
| BLOCK 156 | | | | | | | | | |

| | | | | | | | | | |
|-----------|---|-------|------|-------|------|---------|--------|--------|------|
| 156 | 1 | 95.45 | 0.00 | 95.45 | 0.00 | 1.3E-03 | 0.0013 | 1.5051 | 0.26 |
| BLOCK 162 | | | | | | | | | |
| 162 | 1 | 95.64 | 0.00 | 95.64 | 0.00 | 1.3E-03 | 0.0013 | 1.5127 | 0.29 |
| BLOCK 168 | | | | | | | | | |
| 168 | 1 | 95.83 | 0.00 | 95.83 | 0.00 | 1.3E-03 | 0.0013 | 1.5203 | 0.29 |
| BLOCK 174 | | | | | | | | | |
| 174 | 1 | 96.03 | 0.00 | 96.03 | 0.00 | 1.3E-03 | 0.0013 | 1.5280 | 0.29 |
| BLOCK 180 | | | | | | | | | |
| 180 | 1 | 96.22 | 0.00 | 96.22 | 0.00 | 1.3E-03 | 0.0013 | 1.5357 | 0.29 |
| BLOCK 186 | | | | | | | | | |
| 186 | 1 | 96.42 | 0.00 | 96.42 | 0.00 | 1.3E-03 | 0.0013 | 1.5434 | 0.29 |
| BLOCK 192 | | | | | | | | | |
| 192 | 1 | 96.61 | 0.00 | 96.61 | 0.00 | 1.3E-03 | 0.0013 | 1.5513 | 0.29 |
| BLOCK 198 | | | | | | | | | |
| 198 | 1 | 96.80 | 0.00 | 96.80 | 0.00 | 1.3E-03 | 0.0013 | 1.5591 | 0.29 |
| BLOCK 204 | | | | | | | | | |
| 204 | 1 | 97.00 | 0.00 | 97.00 | 0.00 | 1.3E-03 | 0.0013 | 1.5671 | 0.30 |
| BLOCK 210 | | | | | | | | | |
| 210 | 1 | 97.20 | 0.00 | 97.20 | 0.00 | 1.3E-03 | 0.0013 | 1.5750 | 0.30 |
| BLOCK 216 | | | | | | | | | |
| 216 | 1 | 97.40 | 0.00 | 97.40 | 0.00 | 1.3E-03 | 0.0013 | 1.5831 | 0.30 |
| BLOCK 222 | | | | | | | | | |
| 222 | 1 | 97.59 | 0.00 | 97.59 | 0.00 | 1.4E-03 | 0.0014 | 1.5912 | 0.30 |
| BLOCK 228 | | | | | | | | | |
| 228 | 1 | 97.84 | 0.00 | 97.84 | 0.00 | 1.4E-03 | 0.0014 | 1.5993 | 0.30 |
| BLOCK 234 | | | | | | | | | |
| 234 | 1 | 98.10 | 0.00 | 98.10 | 0.00 | 1.4E-03 | 0.0014 | 1.6075 | 0.30 |

| | | | | | | | | | | |
|-----------|---|-------|------|-------|------|---------|--------|--------|------|--|
| BLOCK 240 | | | | | | | | | | |
| 240 | 1 | 98.35 | 0.00 | 98.35 | 0.00 | 1.4E-03 | 0.0014 | 1.6158 | 0.30 | |

END OF pc-CRACK