



UNITED STATES
NUCLEAR REGULATORY COMMISSION

WASHINGTON, D.C. 20555

June 11, 1992

Docket No. 50-302

Mr. Percy M. Beard, Jr.
Senior Vice President,
Nuclear Operations
Florida Power Corporation
ATTN: Manager, Nuclear Operations
Licensing
P.O. Box 219-NA-21
Crystal River, Florida 32629

Dear Mr. Beard:

SUBJECT: CRYSTAL RIVER UNIT 3 - REFUEL 8 SCOPE (TAC NO. M83163)

We have reviewed your response dated June 4, 1992 to our letter of May 11, 1992 on the same subject, in which we identified certain information necessary for our acceptance of your schedule for completion of reactor building (RB) flood level and equipment qualification (EQ) modifications as outlined in your letter of March 24, 1992.

Your June 4, 1992 letter satisfactorily addresses our concerns, as discussed below.

RB Equipment Relocation

Letdown Cooler Isolation Valves. You state that these valves will not change position after being submerged, and that steps will be taken to assure that position indication for other valves will not be lost as a result of submergence of position indication circuitry for the letdown cooler isolation valves. No changes to procedures or operator training are necessary.

Other RB Equipment Relocation

You specifically state that all interim corrective actions required by our letter of June 21, 1990 will remain in effect until the Cycle 9 mid-cycle outage (9M) when all relocations will be completed. You also state that reexamination of DHV-3 determined that relocation of the DHV-3 junction box, previously scheduled for Cycle 9 refueling (9R), is no longer necessary.

Your letter also confirms that it will not be feasible to accelerate the remaining relocations to a time earlier than 9M.

100064

9
P
170018 920611
ADOCK 05000302
PDR

DF01
1/0
NRC FILE CENTER COPY

EQ List Modifications

You confirm that the only components not likely to be qualified prior to restart from 8R are the makeup pump lube oil pumps. The DHV-3 and 4 motors have been determined to be qualified. In addition, all equipment on the EQ Master List not qualified "will be addressed in a manner consistent with Generic Letter 88-07." Thus, all EQ work is anticipated to be completed by 9M.

Based on the above and on our letter of May 11, 1992, we accept your schedule for completion of the RB flood level and EQ modifications as described in your letter of March 24, 1992 and modified in your letter of June 4, 1992.

This completes our efforts on TAC No. M83163.

Sincerely,

(Original Signed By)

Harley Silver, Project Manager
Project Directorate II-2
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

cc: See next page

DISTRIBUTION

Docket File
NRC & Local PDRs
PDII-2 RF
S. Varga
G. Lainas
H. Berkow
D. Miller
H. Silver
OGC
ACRS (10)
C. McCracken
C. Julian, RII
M. Sinkule, RII

LA:PDII-2
DMilver
6/10/92

PM:PDII-2
HSilver:kj
6/10/92

D:PDII-2
HBerkow
6/11/92

DOCUMENT NAME - CR3.MEM

Mr. Percy M. Beard
Florida Power Corporation

Crystal River Unit No.3
Generating Plant

cc:

Mr. A. H. Stephens
General Counsel
Florida Power Corporation
MAC-A5D
P. O. Box 14042
St. Petersburg, Florida 33733

Mr. Robert G. Nave, Director
Emergency Management
Department of Community Affairs
2740 Centerview Drive
Tallahassee, Florida 32399-2100

Mr. P. F. McKee, Director
Nuclear Plant Operations
Florida Power Corporation
P. O. Box 219-NA-2C
Crystal River, Florida 32629

Chairman
Board of County Commissioners
Citrus County
110 North Apopka Avenue
Inverness, Florida 32650

Mr. Robert B. Borsum
B&W Nuclear Technologies
1700 Rockville Pike, Suite 525
Rockville, Maryland 20852

Mr. Rolf C. Widell, Director
Nuclear Operations Site Support
Florida Power Corporation
P. O. Box 219-NA-2I
Crystal River, Florida 32629

Regional Administrator, Region II
U. S. Nuclear Regulatory Commission
101 Marietta Street N.W., Suite 2900
Atlanta, Georgia 30323

Senior Resident Inspector
Crystal River Unit 3
U.S. Nuclear Regulatory
Commission
6745 N. Tallahassee Road
Crystal River, Florida 32629

Mr. Jacob Daniel Nash
Office of Radiation Control
Department of Health and
Rehabilitative Services
1317 Winewood Blvd.
Tallahassee, Florida 32399-0700

Mr. Gary Boldt
Vice President - Nuclear
Production
Florida Power Corporation
P.O. Box 219-SA-2C
Crystal River, Florida 32629

Administrator
Department of Environmental Regulation
Power Plant Siting Section
State of Florida
2600 Blair Stone Road
Tallahassee, Florida 32301

Attorney General
Department of Legal Affairs
The Capitol
Tallahassee, Florida 32304