

NUCLEAR REGULATORY COMMISSION

WASHINGTON, D.C. 20665

June 9, 1992

Docket Nos. 50-424 and 50-425

> Mr. W. G Hairston, III Executive Vice President -Nuclear Operations Georgia Power Company P. O. Box 1295 Birmingham, Alabama 35201

Dear Mr. Hairston:

SUBJECT .

REQUEST FOR ADDITIONAL INFORMATION REGARDING TURBINE OVERSPEED PROTECTION, VOGTLE NUCLEAR GENERATING PLANT, UNITS 1 AND 2 (TACS M83229/M83230)

The NRC staff is reviewing your application of April 28, 1992, for amendments to change the surveillance interval specified in the Vogtle technical specifications for periodic disassembly and inspection of the valves associated with the turbine overspeed protection system. We find that additional information, identified below, is required for continuation of this review.

- 1. Valve reliability is a significant factor for the evaluation of your proposed change. Please discuss in greater detail the consideration you have given to valve reliability as part of your proposed change. Specifically, what is the current reliability of these valves and to what extent and in what manner do you expect this reliability to change if the requested amendments are granted? Provide data (both plant specific and vendor) supporting the reliability of the relevant valves.
- 2. You note that under the existing surveillance requirement. assuming an 18-month fuel cycle, one valve of each type is disassembled and inspected every other refueling outage; whereas under the proposed surveillance requirement, all four valves of a given type would be disassembled and inspected every third refueling outage. Although your proposal would appear to increase the probability of detecting an impending individual valve failure, we are concerned that the likelihood of early detection of a generic failure of a given type of valve may be decreased, particularly for valves of equivalent age and valves exposed to similar operating conditions. Please discuss the effect of the proposed change in this respect and justify that it would not significantly increase the risk of destructive turbine overspeed. This justification should be based on valve reliability data if appropriate.

MRG FILE CENTER COP

Mr. W. G. Hairston, III Georgia Power Company

cc: Mr. J. A. Bailey Manager - Licensing Georgia Power Company P. O. Box 1295 Birmingham, Alabama 35201

Mr. W. B. Shipman General Manager, Vogtle Electric Generating Plant P. O. Box 1600 Waynesboro, Georgia 30830

Regional Administrator, Region II U. S. Nuclear Regulatory Commission 101 Marietta Street NW., Suite 2900 Atlanta, Georgia 30323

Office of Planning and Budget Room 615B 270 Washington Street, SW. Atlanta, Georgia 30334

Mr. C. K. McCoy Vice President - Nuclear Vogtle Project Georgia Power Company P. O. Box 1295 Birmingham, Alabama 35201

Mr. R. P. McDonald Executive Vice President -Nuclear Operations Georgia Power Company P. O. Box 1295 Birmingham, Alabama 35201

Office of the County Commissioner Burke County Commission Waynesboro, Georgia 30830 Vogtle Electric Generating Plant

Harold Reheis, Director Department of Natural Resources 205 Butler Street, SE. Suite 1252 Atlanta, Georgia 30334

Attorney General Law Department 132 Judicial Building Atlanta, Georgia 30334

Mr. Alan R. Herdt Project Branch #3 U. S. Nuclear Regulatory Commission 101 Marietta Street, NW. Suite 2900 Atlanta, Georgia 30323

Mr. Ernie Toupin
Program Director of Power
Production
Oglethorpe Power Corporation
2100 East Exchange Place
Tucker, Georgia 30085-1349

Charles A. Patrizia, Esquire Paul, Hastings, Janofsky & Walker 12th Floor 1050 Connecticut Avenue, NW. Washington, DC 20036

Art Domby, Esquire Troutman, Sanders, Lockerman and Ashmore 127 Peachtree Street Atlanta, Georgia 30303-1810

Resident Inspector
U. S. Nuclear Regulatory Commission
P. O. Box 572
Waynesboro, Georgia 30830

- 2 -June 9,1992 Mr. W. G. Hairston, III Your written response to the above items is requested within 45 days of this letter. If you have questions regarding these items or are unable to meet this response date, call me at (301) 504-3049. This requirement affects fewer than ten respondents, and therefore, is not subject to Office of Management and Budget review under P. L. 96-511. Sincerely, Darl S. Hood, Senior Project Manager Project Directorate II-3 Division of Reactor Projects - I/II Office of Nuclear Reactor Regulation cc: See next page Distribution: Docket File NRC/Local PDRs PDII-3 R/F Vogtle R/F S. Varga 14-E-1 G. Lainas 14-H-1 D. Matthews 14-H-25 L. Berry 14-H-25 14-H-25 D. Hood OGC-WF 15-B-18 E. Jordan MNBB-3302 ACRS (10) P-315 S. Jones 8-D-1 G. Hubbard 8-D-1 C. McCracken 8-D-1 LA: PDII-PM:PDII-3 DHOOD DSH DMatthews LBerry & CMcCracken 6/9/92 6/9/92 6/6 /92 OFFICIAL RECORD COPY PC Document Name: TVALVE.RAI