

LICENSEE EVENT REPORT (LER)

FACILITY NAME (1)
Washington Nuclear Plant - Unit 2

DOCKET NUMBER (2)
0 5 0 0 0 3 9 7 1 OF 0 2

PAGE (3)
1 OF 0 2

TITLE (4)
Technical Specification Violation

EVENT DATE (5)			LER NUMBER (6)			REPORT DATE (7)			OTHER FACILITIES INVOLVED (8)					
MONTH	DAY	YEAR	YEAR	SEQUENTIAL NUMBER	REVISION NUMBER	MONTH	DAY	YEAR	FACILITY NAMES		DOCKET NUMBER(S)			
*				08	5	0	0	9	0	6	8	4		0 5 0 0 0
														0 5 0 0 0

THIS REPORT IS SUBMITTED PURSUANT TO THE REQUIREMENTS OF 10 CFR 5: (Check one or more of the following) (11)

OPERATING MODE (9)	*	20.402(b)	20.406(e)	80.73(a)(2)(iv)	73.71(b)
POWER LEVEL (10)	*	20.406(a)(1)(i)	50.38(a)(1)	80.73(a)(2)(v)	73.71(c)
		20.406(a)(1)(ii)	50.38(a)(2)	80.73(a)(2)(vi)	OTHER (Specify in Abstract below and in Text, NRC Form 366A)
		20.406(a)(1)(iii)	X 50.73(a)(2)(i)	80.73(a)(2)(vii)(A)	
		20.406(a)(1)(iv)	80.73(a)(2)(ii)	80.73(a)(2)(vii)(B)	
		20.406(a)(1)(v)	80.73(a)(2)(iii)	80.73(a)(2)(ix)	

LICENSEE CONTACT FOR THIS LER (12)

NAME: R. L. Koenigs, Compliance Engineer

TELEPHONE NUMBER: 510 931 771 - 2501

AREA CODE: 510

COMPLETE ONE LINE FOR EACH COMPONENT FAILURE DESCRIBED IN THIS REPORT (13) Ext. 2279

CAUSE	SYSTEM	COMPONENT	MANUFACTURER	REPORTABLE TO NRRDS	CAUSE	SYSTEM	COMPONENT	MANUFACTURER	REPORTABLE TO NRRDS
A	BBDIG		G11QO	N					

SUPPLEMENTAL REPORT EXPECTED (14)

YES (if yes, complete EXPECTED SUBMISSION DATE) NO

EXPECTED SUBMISSION DATE (15)

ABSTRACT (Limited to 400 spaces, i.e., approximately fifteen single-space typewritten lines) (16)

Event 1 08/11/84 Performed surveillance on #2 Standby Diesel Generator (DG1B) without prelube/warmup in violation of Technical Specification 4.8.1.1.2.a.4.

Event 2 08/17/84 Performed surveillance on #1 Standby Diesel Generator (DG1A) without prelube/warmup in violation of Technical Specification 4.8.1.1.2.a.4.

Events are the result of previous changes to Technical Specification requiring action that the component design currently does not allow.

* Event 1 (08/11/84) Operating Mode - 1, Power Level - 037
Event 2 (08/17/84) Operating Mode - 2, Power Level - 002

8409200006 840906
PDR AD0CK 05000397
S PDR

JEZZ
1/1

LICENSEE EVENT REPORT (LER) TEXT CONTINUATION

FACILITY NAME (1) Washington Nuclear Plant - Unit 2	DOCKET NUMBER (2) 0 5 0 0 0 3 9 7 8 4	LER NUMBER (8)			PAGE (3)		
		YEAR	SEQUENTIAL NUMBER	REVISION NUMBER			
			- 0 8 5	- 0 0 0	2	OF	0

TEXT (If more space is required, use additional NRC Form 388A's) (17)

Plant Operating Conditions

	<u>08/11/84</u>	<u>08/17/84</u>
a) Power Level	37%	2%
b) Mode Switch Position	1	2

Event

The final Technical Specification issued upon receipt of the Plant Operating License contained a change requiring a prelube/warmup of the Diesel engines per the manufacturer's recommendation. This would involve running the engines at idle speed. The installed Standby Diesel engines were designed and tested to the requirements of Reg. Guide 1.108 and 1.9 and associated IEEE standards and do not have the capability to run at idle speed. The NRC Project Manager was notified by telephone and a Technical Specification change request initiated prior to the violation.

Corrective Action

The substance of this violation was discussed at length by telephone with Mr. Don Hoffman at 1100 hrs. on February 21, 1984. Mr. Hoffman agreed with the Supply System that our present design would not allow us to perform Surveillance Testing as required by the Technical Specifications. It was also agreed that, if possible, Mr. Hoffman would issue a memo outlining the understanding reached and providing interim relief from the Technical Specifications until the SCN was approved. See LER's 84-009, -023, -029, -041, -059 & -070 for previous reports on this subject.

Since these events, the Technical Specification change has been received with an effective date of August 1984. It is therefore anticipated that no future LER's will be required for events of this nature.

Safety Significance

There are no safety consequences from these events. All systems operated as designed.

Washington Public Power Supply System

P.O. Box 968 3000 George Washington Way Richland, Washington 99352 (509) 372-5000

Docket No. 50-397

September 6, 1984


Document Control Desk
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

Subject: NUCLEAR PLANT NO. 2
LICENSEE EVENT REPORT NO. 84-085

Dear Sir:

Transmitted herewith is Licensee Event Report No. 84-085 for WNP-2 Plant. This report is submitted in response to the report requirements of Technical Specification Section 6.9.1.7 and discusses the item of noncompliance, corrective action taken, and action taken to preclude recurrence.

Very truly yours,



J. D. Martin (M/D 927M)
WNP-2 Plant Manager

JDM:mm

Enclosure:

Licensee Event Report No. 84-085

cc: Mr. John B. Martin, NRC - Region V
Mr. A. D. Toth, NRC - Site (901A)
Ms. Dottie Sherman, ANI
INPO Records Center - Atlanta, GA

IE22
1/1