

LICENSEE EVENT REPORT (LER)

FACILITY NAME (1): Washington Nuclear Plant - Unit 2  
DOCKET NUMBER (2): 0 5 0 0 0 3 9 7 1  
PAGE (3): 1 OF 0 2

TITLE (4): Failure to Conduct Fire Tour

EVENT DATE (5)			LER NUMBER (6)			REPORT DATE (7)			OTHER FACILITIES INVOLVED (8)												
MONTH	DAY	YEAR	YEAR	SEQUENTIAL NUMBER	REVISION NUMBER	MONTH	DAY	YEAR	FACILITY NAMES		DOCKET NUMBER(S)										
0	8	1	4	8	4	0	8	6	0	0	0	0	5	0	0	0					
0	8	1	4	8	4	0	8	6	0	0	0	9	0	6	8	4	0	5	0	0	0

THIS REPORT IS SUBMITTED PURSUANT TO THE REQUIREMENTS OF 10 CFR 5: (Check one or more of the following): (11)

OPERATING MODE (9): 4	20.402(b)	20.406(c)	50.73(a)(2)(iv)	73.71(b)
POWER LEVEL (10): 0, 0, 0	20.406(a)(1)(i)	50.36(a)(1)	50.73(a)(2)(v)	73.71(c)
	20.406(a)(1)(ii)	50.36(a)(2)	50.73(a)(2)(vi)	OTHER (Specify in Abstract below and in Text, NRC Form 365A)
	20.406(a)(1)(iii)	X 50.73(a)(2)(i)	50.73(a)(2)(vii)(A)	
	20.406(a)(1)(iv)	50.73(a)(2)(ii)	50.73(a)(2)(vii)(B)	
	20.406(a)(1)(v)	50.73(a)(2)(iii)	50.73(a)(2)(viii)	

LICENSEE CONTACT FOR THIS LER (12):  
NAME: R. L. Koenigs, Compliance Engineer  
TELEPHONE NUMBER: 5 0 9 3 7 7 - 2 5 0 1  
AREA CODE: Ext. 2279

COMPLETE ONE LINE FOR EACH COMPONENT FAILURE DESCRIBED IN THIS REPORT (13)

CAUSE	SYSTEM	COMPONENT	MANUFACTURER	REPORTABLE TO NRC	CAUSE	SYSTEM	COMPONENT	MANUFACTURER	REPORTABLE TO NRC
A	-	-	-	N					

SUPPLEMENTAL REPORT EXPECTED (14):  
YES (If not, complete EXPECTED SUBMISSION DATE)  NO   
EXPECTED SUBMISSION DATE (15): MONTH DAY YEAR

ABSTRACT (16):  
Equipment operator failed to complete fire tour assigned pursuant to Plant Technical Specifications.

8409200013 840906  
PDR ADOCK 05C00397  
S PDR

IE22  
1/1

LICENSEE EVENT REPORT (LER) TEXT CONTINUATION

FACILITY NAME (1)  Washington Nuclear Plant - Unit 2	DOCKET NUMBER (2)  0 5 0 0 0 3 9 7 8 4	LER NUMBER (6)			PAGE (3)	
		YEAR	SEQUENTIAL NUMBER	REVISION NUMBER		
		8 4	- 0 8 6	- 0 0 0	2	OF 0 2

TEXT (If more space is required, use additional NRC Form 388A's) (17)

Plant Conditions

- a) Plant Mode - 4
- b) Power Level - 0%

Event

On 08/14/84 the equipment operator assigned to perform hourly fire tours pursuant to Technical Specification 3.7.7 failed to complete approximately one half of the required checks for 0500 and 0600.

Immediate Corrective Action

Fire tour was re-established and continued in the manner prescribed by Technical Specification 3.7.7. Operator involved was strongly reprimanded with emphasis on timely performance of Technical Specification related duties.

Further Corrective Action

No further corrective action is required as this was a single occurrence involving a single operator.

Safety Significance

Fire protection was compromised for safety related systems during the period of time (2 hours) the fire tour was not completed. No fires occurred and all active fire suppression systems were operational during this period.

## Washington Public Power Supply System

P.O. Box 968 3000 George Washington Way Richland, Washington 99352 (509) 372-5000

Docket No. 50-397

September 6, 1984


Document Control Desk  
U.S. Nuclear Regulatory Commission  
Washington, D.C. 20555

Subject: NUCLEAR PLANT NO. 2  
LICENSEE EVENT REPORT NO. 84-086

Dear Sir;

Transmitted herewith is Licensee Event Report No. 84-086 for WNP-2 Plant. This report is submitted in response to the report requirements of 10CFR50.73 and discusses the item of reportability, corrective action taken, and action taken to preclude recurrence.

Very truly yours,



J. D. Martin (M/D 927M)  
WNP-2 Plant Manager

JDM:mm

Enclosure:

Licensee Event Report No. 84-086

cc: Mr. John B. Martin, NRC - Region V  
Mr. A. D. Toth, NRC - Site (901A)  
Ms. Dottie Sherman, ANI  
INPO Records Center - Atlanta, GA

IE22  
11