



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D.C. 20555-0001

SOUTH CAROLINA ELECTRIC & GAS COMPANY

DOCKET NO. 50-395

VIRGIL C. SUMMER NUCLEAR STATION

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 131  
License No. NPF-12


1. The Nuclear Regulator Commission (the Commission) has found that:
  - A. The application for amendment by South Carolina Electric & Gas Company (the licensee) dated February 10, 1996, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act) and the Commission's rules and regulations set forth in 10 CFR Chapter I;
  - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
  - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
  - D. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.C.(2) of Facility Operating License No. NPF-12 is hereby amended to read as follows:

(2) Technical Specifications

The Technical Specifications contained in Appendices A and B, as revised through Amendment 131, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of the date of its issuance to be implemented immediately.

FOR THE NUCLEAR REGULATORY COMMISSION



Frederick J. Hebbon, Director  
Project Directorate II-3  
Division of Reactor Projects - I/II  
Office of Nuclear Reactor Regulation

Attachment:  
Changes to the Technical Specifications

Date of Issuance: February 10, 1996

ATTACHMENT TO AMENDMENT 131

FACILITY OPERATING LICENSE NO. NPF-12

DOCKET NO. 50-395

Revise Appendix A as follows:

Remove Pages

3/4 7-15

3/4 9-13

Insert Pages

3/4 7-15

3/4 9-13

## REFUELING OPERATIONS

### SURVEILLANCE REQUIREMENTS (Continued)

---

2. Verifying within 31 days after removal that a laboratory analysis of a representative carbon sample obtained in accordance with Regulatory Position C.6.b of Regulatory Guide 1.52, Revision 2, March 1978, meets the laboratory testing criteria of ANSI N509-1980, at a test media temperature of 30°C.
  3. Verifying a system flow rate of 30,000 cfm  $\pm$  10% during system operation when tested in accordance with ANSI N510-1975.
- c. Prior to the movement of fuel or crane operation with loads over the pool by verifying that a laboratory analysis of a representative carbon sample obtained in accordance with Regulatory Position C.6.b of Regulatory Guide 1.52, Revision 2, March 1978, meets the laboratory testing criteria of ANSI N509-1980, at a test media temperature of 30°C. Subsequent to each initial analysis (which must be completed prior to fuel movement or crane operation with loads over the pool), during the period of time in which there is to be fuel or crane movement with loads over the pool, verify charcoal adsorber operation every 720 hours by obtaining and analyzing a sample as described above. These subsequent analyses are to be completed within thirty-one (31) days of sample removal.
- d. At least once per 18 months by:
1. Verifying that the pressure drop across the combined HEPA and roughing filters and charcoal adsorber banks is less than 6 inches Water Gauge while operating the system at a flow rate of 30,000 cfm  $\pm$  10%.
  2. Verifying that on a loss of offsite power test signal, the system automatically starts.
  3. Verifying that the system maintains the spent fuel pool area at a negative pressure greater than or equal to 1/8 inches Water Gauge relative to the outside atmosphere during system operation.
- e. After each complete or partial replacement of a HEPA filter bank by verifying that the HEPA filter banks remove greater than or equal to 99.95% of the DOP when they are tested in-place in accordance with ANSI N510-1975 while operating the system at a flow rate of 30,000 cfm  $\pm$  10%.
- f. After each complete or partial replacement of a charcoal adsorber bank by verifying that the charcoal adsorbers remove greater than or equal to 99.95% of a halogenated hydrocarbon refrigerant test gas when they are tested in-place in accordance with ANSI N510-1975 while operating the system at a flow rate of 30,000 cfm  $\pm$  10%.

## PLANT SYSTEMS

### SURVEILLANCE REQUIREMENTS (Continued)

1. Verifying that the cleanup system satisfies the in-place testing acceptance criteria and uses the test procedures of Regulatory Positions C.5.a, C.5.c and C.5.d of Regulatory Guide 1.52, Revision 2, March 1978, and the system flow rate is  $21,270 \text{ cfm} \pm 10\%$ .
  2. Verifying, within 31 days after removal, that a laboratory analysis of a representative charcoal sample obtained in accordance with Regulatory Position C.6.b of Regulatory Guide 1.52, Revision 2, March 1978, meets the laboratory testing criteria of ANSI N509-1980, at a relative humidity of 70% and  $25^{\circ}\text{C}$  with a methyl iodide penetration of  $< 1\%$ .
  3. Verifying a system flow rate of  $21,270 \text{ cfm} \pm 10\%$  during system operation when tested in accordance with ANSI N510-1975.
- d. After every 720 hours of charcoal adsorber operation by verifying within 31 days after removal, that a laboratory analysis of a representative carbon sample obtained in accordance with Regulatory Position C.6.b of Regulatory Guide 1.52, Revision 2, March 1978, meets the laboratory testing criteria of ANSI N509-1980, at a relative humidity of 70% and  $25^{\circ}\text{C}$  with a methyl iodide penetration of  $< 1\%$ .
- e. At least once per 18 months by:
1. Verifying that the pressure drop across the combined HEPA and roughing filters and charcoal adsorber banks is less than 6 inches Water Gauge while operating the system at a flow rate of  $21,270 \text{ cfm} \pm 10\%$ .
  2. Verifying that on a simulated SI or high radiation test signal, the system automatically switches into a recirculation mode of operation with flow through the HEPA filters and charcoal adsorber banks.
  3. Verifying that on a simulated SI or high radiation test signal the system starts the normal and emergency air handling systems which pressurize the control room to a positive pressure of greater than or equal to  $1/8$  inch W.G. relative to the outside atmosphere and maintains the  $1/8$  inch W. G. positive pressure with a maximum of 1000 cfm of outside air during system operation.
- f. After each complete or partial replacement of a HEPA filter bank by verifying that the HEPA filter banks remove greater than or equal to 99.96% of the DOP when they are tested in-place in accordance with ANSI N510-1975 while operating the system at a flow rate of  $21,270 \text{ cfm} \pm 10\%$ .
- g. After each complete or partial replacement of a charcoal adsorber bank by verifying that the charcoal adsorbers remove greater than or equal to 99.96% of a halogenated hydrocarbon refrigerant test gas when they are tested in-place in accordance with ANSI N510-1975 while operating the system at a flow rate of  $21,270 \text{ cfm} \pm 10\%$ .