

February 16, 1996

LICENSEE: Georgia Power Company, et al.

FACILITY: Vogtle Nuclear Plant, Units 1 and 2

SUBJECT: SUMMARY OF JANUARY 11-12, 1996, MEETING WITH GEORGIA POWER COMPANY ON ENGINEERING PROGRAM PERFORMANCE

Members of the NRC staff met with representatives of Georgia Power Company (GPC) on January 11, 1996, at the Vogtle Electric Generating Plant (VEGP) site near Waynesboro, Georgia, and on January 12, 1996, at GPC's corporate offices in Birmingham, Alabama. The purpose of the meetings was to review site and corporate engineering activities that have supported plant operations for the past 18 months. Enclosure 1 is a list of attendees at both meetings.

The engineering program areas of interest to the NRC staff were overall management performance; engineering design control; engineering support for operations, outages, maintenance, testing, surveillances and procurement; and, support for licensing activities. Specific items reviewed by the NRC staff during the site visit included the licensee's Deficiency Card system, the Performance Team organization, operability determinations, and the development of safety evaluations under the provisions of 10 CFR 50.59. Additional items reviewed were the status of implementation of the Maintenance Rule, contingency planning for unscheduled outages, and the trending of engineering program performance indicators. Discussions with licensee representatives at the corporate offices focused on the use of probabilistic risk assessments and engineering support for licensing activities. Enclosure 2 provides the documents used by the licensee during their discussions. The NRC staff also expressed an interest in feedback from the licensee on the regulatory impact of NRC activities on licensee programs and plant operations.

Original signed by:

Louis L. Wheeler, Senior Project Manager  
Project Directorate II-2  
Division of Reactor Projects - I/II  
Office of Nuclear Reactor Regulation

Docket Nos. 50-424 and 50-425

Enclosures: 1. List of Attendees  
2. Meeting Document

cc w/encl: See next page

Distribution w/encls. 1&2

Docket File  
PUBLIC  
PD 2-2 Reading  
EMerschhoff, RII  
DWheeler

Distribution w/encl. 1 only

WRussell/FMiraglia  
RZimmerman  
SVarga  
JZwolinski  
SShankman  
LBerry  
OGC  
EJordan  
ACRS  
GTracy, EDO  
LWiens

DOCUMENT NAME: G:\VOGTLE\MEETSUM.SLP

To receive a copy of this document, indicate in the box: "C" = Copy without attachment/enclosure "E" = Copy with attachment/enclosure "N" = No copy

OFFICE	LA:PD22:DRPE	E	PM:PD22:DRPE	AD:PD22:DRPE				
NAME	LBerry	DWheeler						
DATE	2/15/96	2/15/96		2/16/96				

9602220039 960216  
PDR ADOCK 05000424  
P PDR

CIAL RECORD COPY

NRC FILE CENTER COPY

DF011



UNITED STATES  
NUCLEAR REGULATORY COMMISSION

WASHINGTON, D.C. 20555-0001

February 16, 1996

LICENSEE: Georgia Power Company, et al.

FACILITY: Vogtle Nuclear Plant, Units 1 and 2

SUBJECT: SUMMARY OF JANUARY 11-12, 1996, MEETING WITH GEORGIA POWER COMPANY  
ON ENGINEERING PROGRAM PERFORMANCE

Members of the NRC staff met with representatives of Georgia Power Company (GPC) on January 11, 1996, at the Vogtle Electric Generating Plant (VEGP) site near Waynesboro, Georgia, and on January 12, 1996, at GPC's corporate offices in Birmingham, Alabama. The purpose of the meetings was to review site and corporate engineering activities that have supported plant operations for the past 18 months. Enclosure 1 is a list of attendees at both meetings.

The engineering program areas of interest to the NRC staff were overall management performance; engineering design control; engineering support for operations, outages, maintenance, testing, surveillances and procurement; and support for licensing activities. Specific items reviewed by the NRC staff during the site visit included the licensee's Deficiency Card system, the Performance Team organization, operability determinations, and the development of safety evaluations under the provisions of 10 CFR 50.59. Additional items reviewed were the status of implementation of the Maintenance Rule, contingency planning for unscheduled outages, and the trending of engineering program performance indicators. Discussions with licensee representatives at the corporate offices focused on the use of probabilistic risk assessments and engineering support for licensing activities. Enclosure 2 provides the documents used by the licensee during their discussions. The NRC staff also expressed an interest in feedback from the licensee on the regulatory impact of NRC activities on licensee programs and plant operations.

A handwritten signature in black ink, appearing to read "Louis L. Wheeler".

Louis L. Wheeler, Senior Project Manager  
Project Directorate II-2  
Division of Reactor Projects - I/II  
Office of Nuclear Reactor Regulation

Docket Nos. 50-424 and 50-425

Enclosures: 1. List of Attendees  
2. Meeting Documents

cc w/encl: See next page

Georgia Power Company

cc:

Mr. J. A. Bailey  
Manager - Licensing  
Georgia Power Company  
P. O. Box 1295  
Birmingham, Alabama 35201

Mr. J. B. Beasley  
General Manager, Vogtle Electric  
Generating Plant  
P. O. Box 1600  
Waynesboro, Georgia 30830

Regional Administrator, Region II  
U. S. Nuclear Regulatory Commission  
101 Marietta Street, NW., Suite 2900  
Atlanta, Georgia 30323

Office of Planning and Budget  
Room 615B  
270 Washington Street, SW.  
Atlanta, Georgia 30334

Office of the County Commissioner  
Burke County Commission  
Waynesboro, Georgia 30830

Mr. J. D. Woodard  
Senior Vice President -  
Nuclear Operations  
Georgia Power Company  
P. O. Box 1295  
Birmingham, Alabama 35201

Mr. C. K. McCoy  
Vice President - Nuclear  
Vogtle Project  
Georgia Power Company  
P. O. Box 1295  
Birmingham, Alabama 35201

Vogtle Electric Generating Plant

Harold Reheis, Director  
Department of Natural Resources  
205 Butler Street, SE. Suite 1252  
Atlanta, Georgia 30334

Attorney General  
Law Department  
132 Judicial Building  
Atlanta, Georgia 30334

Mr. Thomas P. Mozingo  
Program Manager  
Nuclear Operations  
Oglethorpe Power Corporation  
2100 East Exchange Place  
P. O. Box 1349  
Tucker, Georgia 30085-1349

Charles A. Patrizia, Esquire  
Paul, Hastings, Janofsky & Walker  
12th Floor  
1050 Connecticut Avenue, NW.  
Washington, DC 20036

Arthur H. Dombey, Esquire  
Troutman Sanders  
NationsBank Plaza  
600 Peachtree Street, NE.  
Suite 5200  
Atlanta, Georgia 30308-2216

Resident Inspector  
U. S. Nuclear Regulatory Commission  
8805 River Road  
Waynesboro, Georgia 30830

LIST OF ATTENDEES

January 11, 1996

NRC

L. Wheeler  
L. Wiens

GPC

W. Burmeister  
K. Holmes  
E. Kozinski  
R. Odom  
P. Rushton  
M. Sheibani  
J. Swartzwelder

January 12, 1996

NRC


L. Wheeler  
L. Wiens

GPC

J. Bailey  
J. Edwards  
K. Glandon  
D. Lloyd  
H. Majors  
A. Streetman


VOGTLE NUCLE/ PLANT


November 8, 1995




Manager	(1)
Supervisors	(8)
System/Reactor Engineers	(24)
Performance Engineers	(7)
QC Specialists	(4)
Licensing Engineers/Spec	(4)
Procedure Writers	(4)
Admin Assistants	(3)
<b>TOTAL</b>	<b>55</b>


Supervisory Engineers	7
Engineers	33


Approved By <b>W.F. Kitchens</b>	<b>Vogtle Electric Generating Plant</b> 	Procedure Number    Rev <b>00150-C      20</b>
Date Approved <b>05/03/95</b>	<b>DEFICIENCY CONTROL</b>	Page Number <b>1 of 22</b>
1.0	<p><b><u>PURPOSE AND SCOPE</u></b></p> <p>This procedure describes the requirement and responsibilities for identifying, evaluating, reporting, and dispositioning deficiencies at the Vogtle Electric Generating Plant. The procedure also provides the details for processing Deficiency Cards generated when a deficiency is identified.</p>	
2.0	<p><b><u>DEFINITIONS</u></b></p>	
2.1	<p><b>CONDITIONAL RELEASE</b></p>	
	<p>Allowing an item/component which has been received but has been found nonconforming or indeterminate, to be installed in the plant, but may not be relied upon to perform its intended function until the condition has been resolved and found acceptable for use. Consumable materials are not conditionally released.</p>	
2.2	<p><b>DEFICIENCY</b></p>	
	<p>A deficiency is a nonconforming condition adverse to quality, such as failures or malfunctions of equipment, deviations from design documents or plant procedures, and personnel errors. For additional guidance, refer to Section 4.0.</p>	
2.3	<p><b>DEFICIENCY CARD (DC)</b></p>	
	<p>A card, similar to that shown in Figure 1, used to identify deficiencies.</p>	
2.4	<p><b>DEFICIENCY CARD NUMBER</b></p>	
	<p>A unique number assigned to a tan Deficiency Card (Figure 1) [i.e., 1-87-0001 (unit-year-sequential number)]. DCs on common systems will use Unit 1 prefix.</p>	
2.5	<p><b>HARDWARE NOT AFFECTED</b></p>	
	<p>A disposition assigned when a deviation from procedures or programs occurs that in no way alters or deviates from the design or changes any hardware.</p>	
2.6	<p><b>IMMEDIATE CORRECTION ACTION</b></p>	
	<p>Actions directed by the Unit Shift Supervisor (USS) to place the plant in a safe condition, comply with license requirements, and return equipment to normal operating conditions.</p>	
2.7	<p><b>LONG TERM CORRECTIVE ACTION</b></p>	
	<p>Actions recommended to prevent recurrence. These actions are determined after root cause determination.</p>	


Approved By <b>W.F. Kitchens</b>	<b>Vogtle Electric Generating Plant</b> 	Procedure Number <b>00150-C</b> Rev <b>20</b>
Date Approved <b>05/03/95</b>	<b>DEFICIENCY CONTROL</b>	Page Number <b>2 of 22</b>
<p><b>2.8</b></p> <p><b>2.9</b></p> <p><b>2.10</b></p> <p><b>2.11</b></p> <p><b>2.12</b></p> <p><b>2.13</b></p> <p><b>2.14</b></p> <p><b>2.15</b></p> <p><b>2.16</b></p>	<p><b>MAINTENANCE PREVENTABLE FUNCTIONAL FAILURE (MPFF)</b></p> <p>The failure of a structure, system, or component (SSC) to perform its intended Maintenance Rule Function, where the cause of the failure of the SSC is attributable to a maintenance-related activity or absence thereof.</p> <p><b>MATERIAL DEFICIENCY</b></p> <p>The condition of a procurement level AQ, CG, or SR item (equipment, components, parts, material, etc.) that is adverse (non-conforming) to the technical and quality requirements of the plant. Material deficiencies may be identified at any time prior to installation.</p> <p><b>MATERIAL DEFICIENCY CARD (Material DC)</b></p> <p>A card, similar to that shown in Figure 2, used to identify material deficiencies.</p> <p><b>MATERIAL DEFICIENCY CARD NUMBER</b></p> <p>A unique number assigned to a white deficiency card (Figure 2) [i.e., M-87-001 (material-year-sequential number)].</p> <p><b>NO DISPOSITION REQUIRED</b></p> <p>A disposition assigned when it is determined that the identified deficiency will be dispositioned using other administrative controls or that no deficient condition exists</p> <p><b>NOTIFICATION</b></p> <p>Notification to appropriate regulatory agencies as described in Procedure 00152-C, "Federal And State Reporting Requirements."</p> <p><b>OBTAIN VALID DOCUMENTATION</b></p> <p>A disposition imposed as a result of incorrect or incomplete quality assurance documentation, including existing issued drawings.</p> <p><b>MATERIAL HOLD TAG</b></p> <p>A tag used to identify non-conforming materials.</p> <p><b>RADIOLOGICAL DEFICIENCY</b></p> <p>A radiological deficiency is an unsatisfactory radiological condition or personnel performance which could lead to increased personnel exposure.</p>	


Approved By <b>W.F. Kitchens</b>	<b>Vogtle Electric Generating Plant</b> 	Procedure Number <b>00150-C</b> Rev <b>20</b>
Date Approved <b>05/03/95</b>	<b>DEFICIENCY CONTROL</b>	Page Number <b>3 of 22</b>
<b>2.17</b>	<b>REJECT</b>	
	A disposition imposed when the deficient item in present condition is unacceptable for intended use.	
<b>2.18</b>	<b>REPAIR</b>	
	A disposition and the process of restoring a deficient characteristic to a condition such that the capability of the item to function reliably and safely is unimpaired, even though the item still may not conform to the original requirement.	
<b>2.19</b>	<b>REWORK</b>	
	A disposition and the process by which a deficient item is made to conform to a prior specified requirement by completion, re-machining, reassembling, or other corrective means.	
<b>2.20</b>	<b>USE-AS-IS</b>	
	A disposition which may be imposed for a deficiency when it can be established that the deficient item will result in no adverse conditions and that the item under consideration will continue to meet applicable requirements including performance, maintainability, fit, and safety.	
<b>2.21</b>	<b>SAFETY-RELATED</b>	
2.20.1	Plant structures, systems, and components necessary to assure:	
	<ul style="list-style-type: none"> <li>a. The integrity of the reactor coolant pressure boundary,</li> <li>b. The capability to shut down the reactor and maintain it in a safe shutdown condition, or</li> <li>c. The capability to prevent or mitigate the consequences of accidents which could result in off-site exposures that exceed the guidelines established in 10CFR 100.</li> </ul>	
	<b>NOTE</b>	
	Procedure 11850-C, "Safety-Related Equipment Classification" contains the information listed in FSAR Table 3.2.2-1 and FSAR Table 7.5.2-1.	
2.21.2	Systems, components, or instrumentation designated as Nuclear Safety Class 0, 1, 2, or 3 or listed in FSAR Table 3.2.2-1; and much of the instrumentation designated Category 1 or 2, as listed in FSAR Table 7.5.2-1.	





Approved By <b>W.F. Kitchens</b>	<b>Vogtle Electric Generating Plant</b> 	Procedure Number <b>00150-C</b>	Rev <b>20</b>
Date Approved <b>05/03/95</b>	<b>DEFICIENCY CONTROL</b>	Page Number <b>4 of 22</b>	
2.21.3	Although not safety-related, the following augmented quality items are treated as safety-related: Fire Protection systems/components as described in Procedure 92000-C, "Fire Protection Program"; Radwaste systems/components having Project Classification of XX7, where XX are safety class and seismic class, respectively.		
3.0	<b><u>RESPONSIBILITIES</u></b>		
3.1	All plant personnel are responsible for reporting deficiencies.		
3.2	<b>PLANT REVIEW BOARD (PRB)</b>		
	The PRB:		
3.2.1	Reviews deficiencies designated as 3B or 3C for concurrence with the reportability determination and for detection of potential hazards to nuclear safety. PRB recommendations regarding corrective actions will be forwarded to appropriate individuals.		
3.2.2	Reviews the root cause and corrective actions taken for reportable items. This review is performed as part of the PRB review of reportable items.		
3.3	<b>UNIT SHIFT SUPERVISOR (USS)/OPERATIONS</b>		
	<b>NOTE</b>		
	The duties assigned to the USS may be performed by the Shift Support Supervisor (SSS) provided the SSS notifies the USS of any DC that requires immediate notification.		
	The USS:		
3.3.1	Evaluates Deficiency Cards for immediate reportability. The Shift Superintendent (SS) will make required notification to regulatory agencies.		
3.3.2	Evaluates affect on plant operation and initiates compensatory action as required.		
3.3.3	Assigns sequential numbers to Deficiency Cards.		
3.3.4	Maintains a number assignment log for Deficiency Cards to include number assigned, date number was assigned, and Deficiency Card topic.		
3.4	<b>NUCLEAR SAFETY AND COMPLIANCE SUPERVISOR</b>		
	The Nuclear Safety and Compliance (NSAC) Supervisor ensures:		
3.4.1	Deficiency Card tracking is maintained.		

Approved By <b>W.F. Kitchens</b>	<b>Vogtle Electric Generating Plant</b> 	Procedure Number <b>00150-C</b>	Rev <b>20</b>
Date Approved <b>05/03/95</b>	<b>DEFICIENCY CONTROL</b>		Page Number <b>5 of 22</b>
3.4.2	Deficiency Cards are reviewed to determine significance and reportability.		
3.4.3	Responsibility for disposition of Deficiency Cards is assigned.		
3.4.4	An Event Investigation per Procedure 00057-C, "Event Investigations," is recommended, if appropriate.		
3.4.5	Deficiency Cards and corrective actions are tracked to closure.		
3.4.6	Deficiency Cards are trended.		
3.4.7	Completed Deficiency Cards and applicable documentation are forwarded to Document Control.		
3.4.8	A Licensee Event Report or other report is initiated, if required per Procedure 00152-C.		
3.4.9	Deficiency Cards which identify a significant condition adverse to quality are designated as either 3B or 3C deficiencies and receive a root cause evaluation, as appropriate.		
3.4.10	Conditions identified through trending of Deficiency Cards are reported to the appropriate department for corrective action and to the General Manager and the Supervisor SAER.		
<b>3.5</b>	<b>SUPERVISOR MATERIALS</b>		
	The Supervisor Materials ensures		
3.5.1	Material Hold Tags are used to identify material deficiencies in the warehouse.		
3.5.2	Sequential numbers are assigned to Material Deficiency Cards.		
3.5.3	A log is maintained for Material Deficiency Cards to include number assigned, date number was assigned, and Material Deficiency Card topic.		
3.5.4	Material Deficiency Cards are sent to Document Control after closure.		
3.5.5	The Materials Engineering Group provides the disposition for material deficiencies including the required corrective actions.		
3.5.6	The Supervisor Materials approves material deficiencies dispositioned "use-as-is" or "repair."		
3.5.7	The Materials Engineering Group Supervisor approves all other dispositions for material deficiencies.		
3.5.8	Material deficiencies are controlled to prevent inadvertent use of the material in the plant.		

Approved By <b>W.F. Kitchens</b>	<b>Vogtle Electric Generating Plant</b> 	Procedure Number <b>00150-C</b> Rev <b>20</b>
Date Approved <b>05/03/95</b>	<b>DEFICIENCY CONTROL</b>	Page Number <b>6 of 22</b>
<p><b>3.6      DEPARTMENT MANAGERS</b></p>		
<p>Department managers are responsible for:</p>		
<p>3.6.1      Dispositioning assigned deficiencies.</p>		
<p>3.6.2      Determining if a root cause evaluation is required for assigned deficiencies and assigning individual(s) to perform root cause determinations.</p>		
<p>3.6.3      Ensuring appropriateness of identified corrective actions and ensuring implementation thereof.</p>		
<p><b>4.0      <u>INSTRUCTIONS FOR INITIATION OF A DEFICIENCY CARD</u></b></p>		
<p>4.1      Plant personnel are required to initiate a Deficiency Card (Figure 1) when any of the following conditions occur or are identified, with the exceptions noted in 4.2.</p>		
<p><b>NOTES</b></p>		
<p>a.      Both Sections 4.1 and 4.2 should be reviewed when determining if a deficiency card is required.</p>		
<p>b.      Individuals identifying deficiencies may consult with their supervisor or NSAC for assistance in determining whether the condition requires a Deficiency Card.</p>		
<p>c.      If in doubt, initiate a Deficiency Card.</p>		
<p>4.1.1      Unplanned reactor/turbine trips.</p>		
<p>4.1.2      Unplanned Engineered Safety Features (ESF) Actuations.</p>		
<p>4.1.3      Declaration of an emergency in accordance with the Emergency Plan.</p>		
<p>4.1.4      Events which resulted in or could have easily resulted in personnel injuries of more than minor nature.</p>		
<p>4.1.5      Diesel generator failures (i.e., whenever the diesel generator fails to start, whenever the diesel generator is shut down for other than a planned shutdown, or upon discovery of a condition that could lead to a diesel generator failure).</p>		
<p>4.1.6      Discovery of discrepancies between design documents and installed equipment that involve safety-related or Technical Specifications required equipment or structures.</p>		
<p>4.1.7      Identification of design or manufacturing errors that involve safety-related or Technical Specifications required equipment or structures.</p>		

Approved By W.F. Kitchens	Vogtle Electric Generating Plant 	Procedure Number 00150-C	Rev 20
Date Approved 05/03/95	DEFICIENCY CONTROL		Page Number 7 of 22
4.1.8	Deficiencies in computer codes/programs classified as basic components.		
4.1.9	Significant damage of a major plant component.		
4.1.10	Near miss reactor/turbine trips.		
4.1.11	Occurrence or discovery of multiple component failures during the same event, such that the ability of a system to perform its intended safety function under accident conditions would be questionable.		
4.1.12	Identification of inappropriate personnel actions (e.g. valve, breaker, or switch mispositioning events, improper lubrication, etc.) which resulted in or could have resulted in a loss or degradation of a safety system function, an unplanned power reduction, or damage to plant equipment.		
4.1.13	Failures involving different plant components but which may have resulted from a common cause.		
4.1.14	Repetitive failures or problems involving the same component or identical components.		
4.1.15	Noncompliance with a specification of the VEGP Technical Specifications (e.g. a failure to meet the requirements of an LCO and associated action requirements within the specified time or a failure to complete a Technical Specifications required surveillance within the specified time).		
4.1.16	Identification of procedural inadequacies which, if uncorrected, could have reasonably resulted in a failure to meet Technical Specifications, LCO requirements, or surveillance requirements.		
4.1.17	Conditions which require or may require a non-routine report to federal or state agencies as described by Procedure 00152-C.		
4.1.18	Identification of faulty or missing vendor supplied information which resulted in or could have reasonably resulted in failure or damage to safety related or Technical Specifications required equipment or structures.		
4.1.19	Failure to meet Technical Specifications Surveillance Test acceptance criteria (i.e., the Surveillance Task Sheet must be marked "UNSAT") or discovery of an inoperable condition or an "as found" value such as instrument drift that is outside allowable Technical Specification values.		
4.1.20	Deficiencies involving safety-related components which are to be dispositioned "use-as-is" or "repair."		
4.1.21	Other conditions involving safety-related components which require Engineering Support or other technical assistance to determine if the component is deficient.		

Approved By W.F. Kitchens	Vogtle Electric Generating Plant 	Procedure Number 00150-C	Rev 20
Date Approved 05/03/95	DEFICIENCY CONTROL		Page Number 8 of 22
4.1.22	A violation of procedural requirements (for example: a procedure violation which makes the quality of an item indeterminate, a violation of/deviation from administrative controls which could result in a violation of VEGP Technical Specifications, etc.).		
4.1.23	Any radiological deficiency as follows:		
4.1.23.1	An individual exceeds an authorized administrative limit as specified in 00920-C, "Radiation Exposure Limits."		
4.1.23.2	A known high radiation area is found improperly posted, or a high radiation area having general area dose rates greater than 1000 millirem per hour is found without proper locks or barricades in place.		
4.1.23.3	An entry is made to any posted high radiation area without an RWP and/or without proper monitoring as described in 00930-C, "Radiation And Contamination Control."		
4.1.23.4	VEGP licensed radioactive material is lost, stolen, or discovered unattended outside of an established RCA or radioactive material storage area.		
<b>NOTE</b>			
Report requirements for on-site sources licensed to a vendor, radiographer, or other contractor are decided on a case-by-case basis by Manager HP/Chemistry.			
4.1.23.5	Radioactive contamination exceeding station limits for uncontrolled release is discovered outside of an RCA.		
4.1.23.6	An individual receives an unplanned exposure to airborne radioactivity exceeding 200 DAC-hours in any seven consecutive days.		
4.1.23.7	An individual is contaminated and sustains an injury necessitating on-site first-aid actions only.		
4.1.23.8	Work is stopped and personnel are evacuated because of an unexpected deterioration of radiological conditions in the immediate work area.		
4.1.23.9	An individual's work actions result in repeated radiological deficiencies.		
4.1.24	If <u>significant</u> trends develop from deficiencies identified in Section 4.2.1 through 4.2.4 as determined by the applicable department manager, a Deficiency Card should be initiated in accordance with this procedure.		
4.1.25	High Energy Line Break (HELB) doors which do not meet design requirements.		

Approved By <b>W.F. Kitchens</b>	<b>Vogtle Electric Generating Plant</b> 	Procedure Number <b>00150-C</b>	Rev <b>20</b>
Date Approved <b>05/03/95</b>	<b>DEFICIENCY CONTROL</b>	Page Number <b>9 of 22</b>	

4.1.26 Maintenance Preventable Functional Failures as identified by Engineering Support and approved by the Maintenance Manager..

4.2 The following are examples where deficiency cards are NOT required:

4.2.1 For isolated or random equipment malfunctions or failures requiring "Maintenance," Procedure 00350-C, "Work Request Program" and appropriate Outage and Planning Department procedures are to be used to document, perform, and trend corrective maintenance actions and to assess operability and reportability.

**NOTE**

In general, failure or conditions involving plant equipment or structures would not require initiation of a Deficiency Card, unless the failure or condition could impact operation of safety related equipment or structures, could effect plant reliability or availability, or could represent one or more of the conditions identified in Section 4.1.

4.2.2 For Security-related deficiencies, other than events requiring a 30-day written report (Licensee Event Report), Security Department procedures are to be used to document and trend security deficiencies and their resolution.

4.2.3 For fire protection related deficiencies, other than those requiring a 30 day written report (Licensee Event Report), the appropriate Fire Protection procedure is to be used to document and trend fire protection deficiencies and resolution.


4.2.4 Administrative deficiencies that are documented and resolved through departmental processes, do not require Deficiency Cards, as defined by this procedure. The departmental process should trend the deficiencies if appropriate, and take corrective action.


**4.3 COMPLETION AND PROCESSING OF DEFICIENCY CARDS**

The individual identifying the deficiency should complete Block 1 of the Deficiency Card and deliver the Deficiency Card to the Unit Shift Supervisor (USS).

**NOTE**

Completion of the Deficiency Card and submittal to the Control Room should be completed within 1 hour after determining that a deficiency exists. Do not use the mail to forward Deficiency Cards to the Unit Shift Supervisor.

Approved By <b>W.F. Kitchens</b>	<b>Vogtle Electric Generating Plant</b> 	Procedure Number <b>00150-C</b> Rev <b>20</b>
Date Approved <b>05/03/95</b>	<b>DEFICIENCY CONTROL</b>	Page Number <b>10 of 22</b>
4.4	The originator should include sufficient information to clearly identify the deficient condition and the components MPL tag number when identifiable from name plate data. If available, include the item serial number on the MPL tag number line. Additional sheets should be attached, if needed.	
4.5	The USS may require the initiator to provide additional information for any DC that does not contain sufficient information to evaluate the deficiency.	
4.6	After receiving the Deficiency Card the Unit Shift Supervisor will assign the card a Deficiency Card Number. This number will be of the form N-YY-XXXX where N is the applicable unit, YY is the last two digits of the current year and XXXX is a sequential number beginning with 0001 for each new year.	
4.7	The USS will review the Deficiency Card to determine if compensatory action is required to maintain safe plant conditions. This review should include consideration for placement of Clearance and/or Caution tags. The Unit Shift Supervisor should request technical assistance from applicable plant technical staff to assist in evaluating specific components that may be deficient and the effect that equipment has on plant operations. (These items include, but are not limited to containment isolation valves and snubbers.)	
4.8	The USS will review the Deficiency Card to determine the need for immediate reporting in accordance with Procedure 00152-C. If technical assistance is needed to determine reportability, assistance should be requested from appropriate plant staff.	
<b>NOTES</b>		
	<ul style="list-style-type: none"> <li>a. All Immediate Corrective Actions taken by the Unit Shift Supervisor should be noted on the Deficiency Card. This includes work initiated per Procedure 00350-C and Limiting Conditions for Operation (LCO) initiated per Procedure 10008-C, "Recording Limiting Conditions for Operation."</li> <li>b. The Unit Shift Supervisor review should be completed within 2 hours after submittal.</li> </ul>	
4.9	After completing the reviews required in Steps 4.7 and 4.8 the USS should complete Block 2 on the Deficiency Card and forward the Deficiency Card to the NSAC Section.	
4.10	The NSAC Section will process the Deficiency Card in accordance with Procedure 80014-C, "Handling Of Deficiency Cards."	
4.11	The NSAC Section will review each Deficiency Card for reportability in accordance with Procedure 00152-C. The NSAC review is independent of the USS review. The NSAC Section will consult with HP on evaluation of radiological deficiencies.	

Approved By <b>W.F. Kitchens</b>	<b>Vogtle Electric Generating Plant</b> 	Procedure Number <b>00150-C</b>	Rev <b>20</b>
Date Approved <b>05/03/95</b>	<b>DEFICIENCY CONTROL</b>	Page Number <b>11 of 22</b>	

**4.12 3A DISPOSITION PROCESSING**

If the NSAC Section's review determines that the deficient condition does not require a disposition (i.e. the item may be processed using a different control program, such as 00350-C, "Work Request Program"; 90018-C, "Incident Report Review"; or 92040-C, "Fire Protection LCO Program") the NSAC reviewer will perform the following:


- 4.12.1 Check Block 3A of the Deficiency Card and provide an explanation of why a disposition is not required.
- 4.12.2 Sign and date the Reviewer section of Block 3 on the Deficiency Card.
- 4.12.3 Denote the responsible department based on the item identified
- 4.12.4 "N/A" Blocks 4 - 9 of the Deficiency Card and forward the DC to the NSAC Supervisor for concurrence and signature in Block 3.
- 4.12.5 Forward a copy of the Deficiency Card to the appropriate Department Manager for any further action, as appropriate.
- 4.12.6 Close and forward the original Deficiency Card to Document Control for storage as a permanent record in accordance with 00100-C, "Quality Assurance Records Administration."


**4.13 3B DISPOSITION PROCESSING**

If the NSAC Section's review determines the identified deficiency is reportable per Procedure 00152-C, the NSAC reviewer will perform the following:

- 4.13.1 Check Block 3B of the Deficiency Card and provide an explanation of why it is reportable.
- 4.13.2 Denote the LER number or other special report number in Block 3B, if applicable.
- 4.13.3 Denote the responsible department for dispositioning the deficiency. Sign and date the Reviewer section of Block 3 on the Deficiency Card.
- 4.13.4 Forward the DC to the NSAC Supervisor for concurrence and signature in Block 3.
- 4.13.5 Forward a copy of the DC to the PRB for concurrence with the reportability determination and for review of potential hazards to nuclear safety.
- 4.13.6 For reportable DCs requiring an LER or Special Report, the NSAC Section will normally be the responsible department and will process the DC in accordance with Sections 4.13.7 through 4.13.9. For other DCs, forward original DC to the responsible department for dispositioning in accordance with Section 4.14.3.



Approved By W.F. Kitchens	Vogtle Electric Generating Plant 	Procedure Number 00150-C	Rev 20
Date Approved 05/03/95	DEFICIENCY CONTROL		Page Number 12 of 22
4.13.7	If an investigation is in process or has been completed per Procedure 00057-C or Procedure 81030-C, "Preparation And Processing Of Draft Licensee Event Reports And Special Reports" then reference the report number in Block 3B and complete Blocks 4 - 9 as appropriate.		
4.13.8	Close and forward the original Deficiency Card to Document Control for storage as a permanent record in accordance with 00100-C.		
4.13.9	The NSAC Section will enter completed corrective actions that require tracking and corrective actions awaiting implementation and/or require long term tracking in the Open Item/Commitment Tracking system in accordance with Procedure 00409-C, "Open Item/Commitment Tracking."		
4.14	<b>3C DISPOSITION PROCESSING</b>		
	If the NSAC review determines the identified deficiency is not reportable per Procedure 00152-C, the DC will be processed as follows:		
4.14.1	The NSAC reviewer will check Block 3C, include an explanation as to why the DC is not reportable, assign a responsible department to disposition the Deficiency Card and sign and date Block 3. Forward the DC to the NSAC Supervisor for concurrence and signature in Block 3.		
4.14.2	Forward the original DC to the responsible department and a copy to the Plant Review Board for their concurrence with the reportability determination and review of potential hazards to nuclear safety.		
4.14.3	The responsible department assigned the DC will normally perform the following within 30 days. If the required actions can not be completed within a reasonable time frame (by the 35th day) an extension should be requested from the Assistant General Manager.		
4.14.3.1	If in dispositioning or performing a root cause evaluation for a DC, the evaluator becomes aware of a condition that could effect the safe operation of the plant, and such condition (or its significance) was not adequately identified by the original DC, then another DC should be initiated immediately to ensure proper compensatory action is taken.		

Approved By <b>W.F. Kitchens</b>	<b>Vogtle Electric Generating Plant</b> 	Procedure Number <b>00150-C</b>	Rev <b>20</b>
Date Approved <b>05/03/95</b>	<b>DEFICIENCY CONTROL</b>	Page Number <b>13 of 22</b>	
4.14.3.2	<p>Complete Block 4, the "Disposition" section, of the DC with an appropriate disposition. Examples of dispositions include: Use-As-Is, Repair, Rework, Reject, Obtain Valid Documentation, Hardware Not Affected, or No Disposition Required. Refer to Section 2.0 for definition of these dispositions.</p> <p style="text-align: center;"><b>NOTE</b></p> <p>If the department performing the disposition is not the department causing the deficiency, the deficiency card will be returned to the NSAC Section. NSAC will send the deficiency card to the causing department for RCCA evaluation.</p>		
4.14.3.3	<p>Screen the DC in accordance with the guidance provided in Attachment 1 and indicate the determination in Block 5. If an RCCA is required, complete the RCCA in accordance with Procedure 00058-C, "Root Cause Determination," then return to 4.14.3.4. If an RCCA is not required, perform the following:</p> <ol style="list-style-type: none"> <li>a. If an evaluation has been completed per Procedure 00057-C, then reference the Event Report number in the disposition section.</li> <li>b. Determine the cause(s) of the deficient condition, if known, and enter the determination in Block 6.</li> <li>c. Determine the actions to be taken to prevent recurrence if applicable, and enter in Block 7.</li> </ol>		
4.14.3.4	<p>Enter the cause code and causing department in Block 8.</p> <p style="text-align: center;"><b>NOTE</b></p> <p>If an RCCA is not performed, determine the cause code using the listing in Procedure 00058-C.</p>		
4.14.3.5	<p>Ensure corrective actions assigned to another department have the receiving department's concurrence in Block 7. (Corrective actions are tracked against the department assigned to complete the action.)</p>		
4.14.3.6	<p>Return the dispositioned DC and the completed RCCA worksheet(s), if applicable, to NSAC for tracking. The NSAC Section will enter the Event Type Code when required.</p>		
4.14.4	<p>The NSAC Section will review Blocks 4-9 for concurrence that an adequate investigation of the DC was performed and that corrective actions are appropriate. Concurrence will be indicated by initialing in the appropriate space in Block 9. If the investigation or corrective actions appear to be inadequate, the DC may be returned to the responsible department for further action.</p>		

4.14.5 The NSAC Section will enter completed corrective actions that require tracking in the Open Item/Commitment Tracking system in accordance with Procedure 00409-C. Corrective actions awaiting implementation and corrective actions that require long term tracking will also be entered.

4.14.6 The NSAC Section will update computer data base to reflect final dispositioning and close out the DC and forward the original and any supporting documentation to Document Control for storage as a permanent record in accordance with 00100-C, "Quality Assurance Records Administration."

4.14.7 The NSAC Section will provide management with a periodic status of open DCs.

**5.0 MATERIAL DEFICIENCY CARD INITIATION**

5.1 When material deficiencies are identified, the individual will initiate a Material Deficiency Card (Figure 2). The individual identifying the material deficiency should complete Blocks 2, 3, 4, 5, 6, 7, 8, 9, 10, 11, 12, 13, and 14 and forward the Material Deficiency Card to Materials Engineering.

5.2 Materials Engineering personnel will assign the card a Material Deficiency Card Number. This number will be of the form M-YY-XXXX where M denotes Material Deficiency, YY is the last two digits of the current year and XXXX is a sequential number beginning with 0001 for each new year.


5.3 After receiving a Material Deficiency Card, the Materials Engineering Group (MEG) will ensure Hold Tags are attached to the deficient material/components identified and complete Block 15 of the Material Deficiency Card.


5.4 MEG ensures the deficient material/components are uniquely tagged or segregated from acceptable material to prevent inadvertent use in the plant.


5.5 MEG will forward a copy of the Material Deficiency Card (Material DC) to the NSAC Section for initial reportability screening.

5.6 MEG will disposition the Material DC. The disposition will identify corrective actions and implementing documents for completion of corrective action (i.e., WO numbers, RERs, etc.). Dispositioning of Material deficiencies should normally occur within 30 days and will be in accordance with Procedure 70546-C, "Evaluation And Disposition Of Material Deficiency Cards."

5.7 The MEG Supervisor will approve all material dispositions except those dispositioned "use-as-is" or "repair." "Use-as-is" or "repair" dispositions require approval by the Supervisor Materials.

Approved By W.F. Kitchens	Vogtle Electric Generating Plant 	Procedure Number 00150-C	Rev 20
Date Approved 05/03/95	DEFICIENCY CONTROL		Page Number 15 of 22
5.8	MEG will forward the dispositioned Material DC to NSAC. Corrective actions, including removal of hold tags and release of materials, may be performed concurrently with the NSAC Section review.		
5.9	The NSAC reviewer will determine if the material deficiency is reportable in accordance with Procedure 00152-C. If reportable, NSAC will prepare the required report.		
5.10	Material Deficiencies determined reportable will be evaluated by MEG in accordance with 00058-C. Completed Root Cause Determination worksheets will be attached to the Material Deficiency Card. A copy of the root cause determination will be sent to NSAC for trending purposes. An RCCA may be performed on other material deficiencies if deemed necessary by the MEG Supervisor.		
5.11	The MEG will be responsible for the assignment and completion of Material DC corrective actions. These may be assigned to other departments with their concurrence.		
5.12	MEG shall close Material DCs after receiving or obtaining evidence of corrective actions.		
5.13	Hold tags will be removed from Material DC items upon completion of corrective actions OR when hold tag removal is necessitated to facilitate the completion of corrective actions.		
<b>NOTE</b>			
Hold tags will be removed prior to shipment of material off-site.			
5.14	For Material DCs dispositioned "use-as-is" or "repair," a copy of the Material DC and associated paperwork are to be made part of the Quality Assurance documentation associated with the item.		
5.15	Material DCs will be forwarded to Document Control upon closure for storage as a permanent record in accordance with 00100-C.		
<b>NOTE</b>			
Use of conditionally released materials will be in accordance with Procedure 00853-C, "Material Identification, Control And Issue."			
6.0	<b><u>DUPLICATE DEFICIENCY CARDS</u></b>		
When a deficiency card is found to be a duplicate of a previously identified deficiency, the deficiency card will be stamped or marked "DUPLICATE" referencing the DC number it duplicated, and closed out by NSAC. NSAC will forward the "duplicate" DC to Document Control for storage.			

Approved By <b>W.F. Kitchens</b>	<b>Vogtle Electric Generating Plant</b> 	Procedure Number <b>00150-C</b> Rev <b>20</b>
Date Approved <b>05/03/95</b>	<b>DEFICIENCY CONTROL</b>	Page Number <b>16 of 22</b>
<b>7.0</b>	<b><u>TRENDING</u></b>	
<b>7.1</b>	All DCs dispositioned 3B and 3C should be trended to identify recurring deficiencies which might indicate procedural or programmatic breakdowns that could adversely affect the quality of the plant and associated equipment. A trend is identified when a repetitive occurrence or a sustained increasing frequency of occurrence is observed and is not explainable as an occasional or isolated procedural or programmatic inadequacy.	
<b>7.2</b>	A quarterly trend report should be prepared by NSAC and distributed to department managers and the General Manager-Nuclear Plant. A copy of the trend report will also be forwarded to the Supervisor Safety Audit Engineering Review.	
<b>7.3</b>	If requested, department managers should provide a response and take appropriate corrective actions as necessary for trends identified within their departments area of responsibility.	
<b>7.4</b>	Material DCs requiring a root cause determination (reportable Material DCs) will be trended and included in the trend report issued by the NSAC Section as appropriate.	
<b>8.0</b>	<b><u>RECORDS</u></b>	
	Deficiency Cards and supporting documentation shall be handled and maintained in accordance with Procedure 00100-C.	
<b>9.0</b>	<b><u>REFERENCES</u></b>	
<b>9.1</b>	ANSI N18.7 - 1976	
<b>9.2</b>	ANSI N45.2 - 1977	
<b>9.3</b>	Title 10CFR50 Appendix B, Criteria XV and XVI	
<b>9.4</b>	Title 10CFR50.59, Changes, Tests & Experiments	
<b>9.5</b>	Title 10CFR21, Reporting of Defects and Noncompliances	
<b>9.6</b>	Title 10CFR50.72, Immediate Notification Requirements for Operating Nuclear Power Reactors	
<b>9.7</b>	Title 10CFR50.73, License Event Report System	
<b>9.8</b>	Title 10CFR50.45 (X), Conditions of Licenses	
<b>9.9</b>	Title 10CFR50.55 (e)	
<b>9.10</b>	Regulatory Guide 1.33, Quality Assurance Program Requirements	

Approved By W.F. Kitchens	Vogtle Electric Generating Plant 	Procedure Number 00150-C	Rev 20
Date Approved 05/03/95	DEFICIENCY CONTROL		Page Number 17 of 22
9.11	Regulatory Guide 1.38, Quality Assurance Requirements Packing, Shipping, Receiving, Storage, and Handling of Items for Water-Cooled Nuclear Power Plants.		
9.12	Regulatory Guide 1.123, Quality Assurance Requirements for Control of Procurement of Items and Services for Nuclear Power Plants.		
9.13	<b>PROCEDURES</b>		
9.13.1	00057-C,	"Event Investigations"	
9.13.2	00058-C,	"Root Cause Determination"	
9.13.3	00100-C,	"Quality Assurance Records Administration"	
9.13.4	00152-C,	"Federal And State Reporting Requirements"	
9.13.5	00350-C,	"Work Request Program"	
9.13.6	00400-C,	"Plant Design Control"	
9.13.7	00409-C,	"Open Item/Commitment Tracking"	
9.13.8	00853-C,	"Material Identification, Control, And Issue"	
9.13.9	00920-C,	"Radiation Exposure Limits"	
9.13.10	00930-C,	"Radiation And Contamination Control"	
9.13.11	10008-C,	"Recording Limiting Conditions For Operation"	
9.13.12	50011-C,	"Engineering Evaluation And Disposition Of Deficiency Reports"	
9.13.13	70546-C,	"Evaluation And Disposition Of Material Deficiency Cards"	
9.13.14	80014-C,	"Handling Of Deficiency Cards"	
9.13.15	81030-C,	"Preparation And Processing Of Draft Licensee Event Reports And Special Reports"	
9.13.16	90018-C,	"Incident Report Review"	
9.13.17	92040-C,	"Fire Protection LCO Program"	
<b>END OF PROCEDURE TEXT</b>			

### Deficiency Card

Completed By Initiator	Card # _____ <input type="checkbox"/> Unit 1 <input type="checkbox"/> Unit 2 <input type="checkbox"/> Common
	1: Description of Deficiency _____ (Additional Sheets Attached? <input type="checkbox"/> Yes <input type="checkbox"/> No)
	_____
	_____
	_____
	MPL Tag Number _____ Serial No. _____
	Location Of Deficiency? _____
	What Is Affected By The Deficiency?/What Controls Were Violated? _____
	How Was The Deficiency Discovered? _____
	Event Time _____ Date _____ Discovery Time _____ Date _____
Discovered By? _____ Work # _____ Dept. _____	
Completed By USS Within 2 Hours	2. Shift Supervisor Review Name Of USS Reported To? _____ Time _____ Date _____
	Plant Mode/Condition: _____
	Is Immediate Notification Required? <input type="checkbox"/> Yes <input type="checkbox"/> No
	If Yes, <input type="checkbox"/> 1 Hour, <input type="checkbox"/> 4 Hour, or <input type="checkbox"/> 24 Hour      Reported: Date _____ Time _____
	Tech. Spec. Required Action Taken? <input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A
	List Applicable Tech. Spec. Section(s) _____
	Summarize Compensatory Action Taken: _____
	LCO Initiated <input type="checkbox"/> Yes <input type="checkbox"/> No # _____ Type: Info    LCO    Fire
	WO Initiated <input type="checkbox"/> Yes <input type="checkbox"/> No # _____
	Signature Of USS _____ Date _____ Time _____
Completed in 1 Day	3: NSAC Evaluation/Review (Check Appropriate Box)    Date Received: _____
	A. <input type="checkbox"/> No Disposition Required. Send Copy To Responsible Dept., Close Original
	B. <input type="checkbox"/> Reportable Deficiency. Report # _____
	C. <input type="checkbox"/> Deficiency, Not Reportable.
	Explanation: _____
	_____
	_____
	_____
	_____
	Responsible Dept.: _____
NSAC Reviewer: _____ Date: _____ NSAC Supervisor: _____ Date: _____	

**Figure 1 Front (Tan)  
Example**

Approved By  
W.F. Kitchens

Vogtle Electric Generating Plant



Procedure Number Rev  
00150-C 20

Date Approved  
05/03/95

DEFICIENCY CONTROL

Page Number  
19 of 22

Completed in 1 Month By Responsible Department

4. Disposition:

\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

5. RCCA Required:  Yes (Complete per 00058-C)  No (Complete 6 & 7 below)

6. Cause(s), if known:

\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

7. Action to Prevent Recurrence, if applicable:


\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

Concurrence for Corrective Actions Assigned to Another Dept.:

8. Cause Code(s): \_\_\_\_\_ Cause Dept(s): \_\_\_\_\_  
Department Manager: \_\_\_\_\_ Date: \_\_\_\_\_  
9. Event Code(s): \_\_\_\_\_ NSAC Initials: \_\_\_\_\_

Figure 1 Back (Tan) (Cont'd.)  
Example




Approved By <b>W.F. Kitchens</b>	<b>Vogtle Electric Generating Plant</b> 	Procedure Number <b>00150-C</b>	Rev <b>20</b>
Date Approved <b>05/03/95</b>	<b>DEFICIENCY CONTROL</b>		Page Number <b>20 of 22</b>

**MATERIAL DEFICIENCY CARD**

1. MATERIAL DC NO. M- \_\_\_\_\_
2. P.O. NO. \_\_\_\_\_
3. P.O. ITEM NO. \_\_\_\_\_
4. NO. OF ITEMS \_\_\_\_\_
5. M.I.R. NO. \_\_\_\_\_
6. PROCUREMENT LEVEL \_\_\_\_\_
7. SAFETY CLASS \_\_\_\_\_
8. ITEM DESCRIPTION \_\_\_\_\_  
\_\_\_\_\_
9. ITEM LOCATION \_\_\_\_\_
10. VENDOR/SUPPLIER \_\_\_\_\_ LOCATION \_\_\_\_\_
11. DEFICIENCY \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_
12. CAUSE (IF KNOWN) \_\_\_\_\_
13. OTHER INFORMATION \_\_\_\_\_
14. ORIGINATOR (PRINT) \_\_\_\_\_ DATE \_\_\_\_\_
15. MATERIAL HOLD TAG (QTY) \_\_\_\_\_ RECEIPT INSPECTOR \_\_\_\_\_
16. DISPOSITION: \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_
17. APPROVAL:  
USE-AS-IS/REPAIR(SUPV MATERIALS) \_\_\_\_\_ DATE \_\_\_\_\_  
OTHER(MEG SUPV) \_\_\_\_\_ DATE \_\_\_\_\_
18. REPORT REQ'D: YES \_\_\_\_\_ NO \_\_\_\_\_ # \_\_\_\_\_
19. NSAC SECTION REVIEW BY: \_\_\_\_\_ DATE \_\_\_\_\_
20. CLOSURE: \_\_\_\_\_ DATE \_\_\_\_\_

**Figure 2 (White)  
(Example)**


Approved By <b>W.F. Kitchens</b>	<b>Vogtle Electric Generating Plant</b> 	Procedure Number <b>00150-C</b>	Rev <b>20</b>
Date Approved <b>05/03/95</b>	<b>DEFICIENCY CONTROL</b>	Page Number <b>21</b>	<b>of 22</b>

### ATTACHMENT 1

#### GUIDELINES TO DETERMINE IF AN RCCA IS REQUIRED


The following are examples of events which require an RCCA to be completed.

- Events which require an investigation per Procedure 00057-C, "Event Investigations."
- Unplanned Turbine Trips.
- Diesel Generator valid failures.
- Discovery of significant damage of a major plant component (i.e. damage that requires or could have required a forced plant shutdown or a forced power reduction).
- Occurrence or discovery of multiple component failures during the same event such that the ability of a system to perform its intended safety function under accident conditions would be questionable.
- Identification of a failure to meet Technical Specifications LCO requirements, including not completing LCO required actions within the specified time.
- Missed Technical Specifications surveillance.
- Any event which results in a personnel injury of more than a minor nature.
- An individual exceeds an authorized administrative limit as specified in Procedure 00920-C, "Radiation Exposure Limits And Administrative Guidelines" (does not exceed 10CFR20 exposure limits).
- A known high radiation area or very high radiation area is found improperly posted, or a high radiation area having general area dose rates greater than 1000 millirem per hour is found without proper locks or barricades in place, or a very high radiation area having general area dose rates greater than 500 rad/hour at 1 meter is found without proper locks or barricades in place.
- An entry is made to any posted high radiation area without an RWP.
- Discovery of lost, stolen, or unattended radioactive material outside of an established RCA or a radioactive material storage area (less severe than an event which would require reporting per 10CFR20).
- Maintenance Rule systems that become an (a)1 category system, as defined in 10CFR50.65.
- Any Maintenance Preventable Functional Failure (MPFF).


Approved By <b>W.F. Kitchens</b>	<b>Vogtle Electric Generating Plant</b> 	Procedure Number    Rev <b>00150-C            20</b>
Date Approved <b>05/03/95</b>	<b>DEFICIENCY CONTROL</b>	Page Number <b>22 of 22</b>
<ul style="list-style-type: none"> <li>• Identification of procedural inadequacies which, if uncorrected, could have reasonably resulted in a failure to meet Technical Specifications LCO requirements or surveillance requirements.</li> <li>• Failure to meet Technical Specification Surveillance Test acceptance criteria or discovery of an inoperable condition or an "as found" value such as instrument drift that is outside allowable Technical Specification value(s).</li> <li>• Identification of a failure to meet Fire Protection LCO requirements.</li> <li>• Violation of procedural requirements (for example; violation of/deviation from administrative controls which could result in a violation of VEGP Technical Specifications, etc.).</li> <li>• Violation of procedural or programmatic requirements pertaining to personnel safety such as violations of RWP requirements, clearance and tagging requirements, or confined space work permit requirements.</li> <li>• Discovery of a significant discrepancy between design documents and installed equipment.</li> <li>• Identification of a significant design or manufacturing error.</li> <li>• Significant deficiencies in computer codes/programs classified as basic components.</li> </ul> <p style="text-align: center;"><b>NOTE</b></p> <p>Events which do not meet any of the above examples do not require a root cause determination unless deemed necessary by Department Management.</p>		


# PERFORMANCE TEAM ORGANIZATION

at. & Sun. 7am - 7 pm  
ues. & Wed. 4pm - 12 am




Complete  
Within 30 days





Complete  
Within 30 days



(Management Standard No. 5)

**STANDARD FOR DETERMINATION OF  
OPERABILITY**

(APPROVED 5/20/92)



## STANDARD FOR DETERMINATION OF OPERABILITY

### - GENERAL

OPERABILITY is a condition of compliance with the Technical Specifications. It is initially achieved through an exhaustive construction and testing program, and maintained by successful and timely completion of surveillance requirements. The achieved state of operability is protected and ensured by our work and configuration control programs and deficient condition evaluations.

OPERABILITY applies only to the specific equipment covered by the Technical Specifications. (Equipment not included in the Technical Specifications should be called "functional" or "not functional" to avoid confusion).

### - DEFINITION

A system, subsystem, train, component or device shall be OPERABLE or have OPERABILITY when it is capable of performing its specified function(s), and when all necessary attendant instrumentation, controls, electrical power, cooling or seal water, lubrication or other auxiliary equipment that are required for the system, subsystem, train component, or device to perform its function(s) are also capable of performing their related support function(s).

### - RESPONSIBILITY

The determination of OPERABILITY is the responsibility of the Operations Department. The other plant groups are responsible to observe conditions, report specific problems, and support operations in making a determination of equipment status. Clarification of Technical Specification requirements is the responsibility of operations line management with the assistance of the Technical Support Department.

When surveillance requirements are not met, or specific evidence exists that Technical Specification required equipment does not meet the OPERABILITY definition, the equipment shall be declared INOPERABLE and the appropriate ACTION statement shall be followed. The time of entry into the LCO ACTION statement shall be the time of discovery - the point in time at which responsible parties become aware of the condition.

At times, degraded or nonconforming conditions are revealed that result in equipment operability becoming indeterminate. In these cases the operability evaluation is to be prompt, with the timeliness commensurate with the potential safety significance of the issue. An intermediate determination of operability, pending the evaluation results, will be predicated on a reasonable expectation that the equipment is operable and that the prompt evaluation process will support that expectation. Corrective or compensatory actions should be initiated, where possible and prudent, in parallel with this operability evaluation. If the OPERABILITY evaluation reveals that the equipment fails to meet the definition of OPERABILITY, the equipment shall be declared INOPERABLE, and the appropriate action statement entered with the action clock beginning at the time INOPERABILITY was determined.

Special attention must be paid to peripheral operability impacts such as equipment qualification, flood protection, missile shields, impingement plates, or high energy line break protection. These items, often referred to as "hazard" protection, may require special design engineering expertise for a proper OPERABILITY evaluation. (Even though OPERABILITY may not be affected, we shall take timely corrective action to restore the plant to its intended design condition.)

W. S. Korman 1 5/20/92  
General Manager Date  
Nuclear Plant - Approval

(Management Standard No. 18)

**Standard for Removal of Safety Related or  
Risk Significant Systems From Service**

# STANDARD FOR REMOVAL OF SAFETY RELATED OR RISK SIGNIFICANT SYSTEMS FROM SERVICE

## GENERAL:

Safety related systems may be removed from service during power operations to perform elective maintenance that will improve the overall system or plant performance and reliability. These planned system outages will be planned and scheduled to ensure that the out of service time is held to a minimum and that all applicable work activities are performed.

## SCOPE:

This standard applies to all elective outages on safety related systems. This standard also applies where specific considerations are required for systems considered "risk significant" as defined by 00353-C "Maintenance Rule". The "Maintenance Rule Scoping Manual", (Manual MSV-1748), contains a list of all Maintenance Rule systems along with their performance criteria and risk significance designation.

## RESPONSIBILITIES: The following guidelines will be used by plant personnel when developing Safety System Outages:

Schedules will be developed for all outages on Safety Related Systems that have multiple work tasks or for single work item outages on risk significant systems with a duration of greater than 1 shift.

Planning should ensure that the outage is scheduled in the correct "train" week. The planning process should include a review of the impact of other work activities, that are scheduled concurrently with the outage, which may affect overall plant or system performance.

The schedule should provide all activities that will be performed during the outage including operations activities for removal from and return to service, any integration that may be required for the work activities, the estimated duration for each activity as well as the overall outage duration, and appropriate notes for special considerations that must be taken during the outage. A statement on the risk significance of the system should also be included in the notes to the schedule.

Planned outages for risk significant systems should be performed as necessary to maintain reliability. The outage will be evaluated against the Maintenance Rule performance criteria for out of service time. The system engineer is responsible for providing the status of this criteria which will also be noted on the schedule.

**RESPONSIBILITIES:** The outage plan, including scope and schedule, will be presented and discussed as part of the plant Plan of the Day (POD) meeting. The preliminary schedule will typically be included as part of the POD approximately 3 weeks prior to the scheduled start date with an associated breakout discussion approximately 2 weeks before the start date.


(Continued)

All work controls programs should be reviewed for scope development when planning a system outage. This includes but is not limited to any identified corrective, preventative, predictive, surveillance, or design change activities. Scope inclusion should be based on improving performance, minimizing overall out of service time, or ALARA.


All schedules will be approved by a individual in the departments that are affected by the work. As a minimum, approvals will include management representatives for the Maintenance, Operations, Engineering and Outages & Planning Departments. The system engineer will also be provided a copy to review during the approval /development stage.

If the cumulative out of service time for the system (including the projected outage duration) does not exceed the assumed IPE unavailability per cycle, then the outage will have an acceptable impact on the Core Damage Frequency as determined by PRA. This assumes no other safety system out of service.

Planned outages that will cause the out of service time established in the performance criteria to be exceeded will require special consideration which may include a verification through PRA methodology. The necessity of the maintenance will have to be evaluated against the increase in projected risk. This evaluation, if necessary, will also be noted on the schedule.

  
GMINR Approval \_\_\_\_\_ Date 1/29/95

# ***TOTAL DEFICIENCIES GENERATED AT VOGTLE***



■ Total DC's

TOTALDC)

# Improved Tech Specs Status Report

Report Date: Thursday, January 11, 1996

Responsible Management	Responsible Department	Procedure Revision Status		
		Planned for 01/10	Complete on 01/10	Total to revise
<b>Plant Operations</b>	Chemistry/HP	29	29	29
	Maintenance	390	397	669
	Operations	234	225	580
	Outage/Plan	0	0	0
<b>Subtotal</b>		<b>653</b>	<b>651</b>	<b>1278</b>

<b>Plant Support</b>	Eng Support	37	38	56
	Plant Mods	0	0	0
	Plant Admin	0	0	0
	Security	0	0	0
	NSAC	5	5	16
	Training	0	0	0
<b>Subtotal</b>		<b>42</b>	<b>43</b>	<b>72</b>

<b>Other</b>	ISEG/SAER	0/0	0/0	0/0
	Management	0	0	0
	Corporate	0	0	2
<b>Total</b>		<b>695</b>	<b>694</b>	<b>1352</b>

**UNIT 1 AND UNIT 2  
IMMEDIATE  
RELEASE  
MWO'S**

**TO PREVENT THE DESTRUCTION OF EVIDENCE  
THAT COULD BE USEFUL TO THE INVESTIGATION  
OF THE EVENT THAT CAUSED THE FORCED  
OUTAGE, NO WORK SHALL BE UNDERTAKEN  
THAT COULD BE REMOTELY ASSOCIATED WITH  
THE CAUSE, WITHOUT FIRST BEING APPROVED  
BY THE VOGTLE DUTY MANAGER OR THE EVENT  
REVIEW TEAM LEADER.**



WMO NO.	ST	TYPE	TEAM	DISC	FORE	NUMBERS	MPL/TAG	SYS	FEG	LOCATION	CLR	RWP	SCH	REQ	DATES	P2	CODE	CONTROL	PRI	
															SCH	END	REQUIRED	RFL	RFR	
19485278	65	COP	I&CC	ICOP	MLD	1LT8582		1501	IABBA	1RB184-3	Y	Y	05/08/96	05/09/96	00/00/00	16	05	I	4	
WORK REQUESTED ... TUBING CONNECTION AT TRANSMITTER IS LEAKING ACTIVE LEAK FOUND BY JOHN CHURCHWELL ON CONTAINMENT WALKDOWN																				
FOREMAN COMMENTS: *F.F.T. IMMEDIATE RELEASE**																				
WORK INSTRUCTIONS: SEE ATT. LOOSEM SWAGELOR/CLEAN/TIGHTEN PER MAINTENANCE PROCEDURE 2044 0-C. MAINTAIN ZONE IV HOUSEKEEPING.																				
MPL/TAG ...																				
MPL/TAG 1LRT 1LT8582																				
CLEARANCE ...																				
CLEAR 0 STA MPL/TAG 11505PIPE SYS FEG 1305 IAD80 P&ID M/A M LOCATION IVARIOUS OPS DESCRIPTION SYSTEM 1305 PIPE SEGMENT																				
19485466	65	COP	HSSB	ICOP	HWG	1PI5264		1501	IABBB	1RB171-6	N	Y	05/05/96	05/04/96	00/00/00	16	05	I	5044	
WORK REQUESTED ... GLASS BROKE ON 1PI-5264 GAGE APPEARS TO STILL READ CORRECTLY.																				
FOREMAN COMMENTS: *CONTAINMENT ENTRY REQUIRED																				
WORK INSTRUCTIONS: REPLACE BROKEN GLASS, CAL IF REQUIRED																				
MPL/TAG ...																				
MPL/TAG 1PI5264																				
CLEARANCE ...																				
CLEAR 0 STA MPL/TAG 11505PIPE SYS FEG 1305 IAD80 P&ID M/A M LOCATION IVARIOUS OPS DESCRIPTION SYSTEM 1305 PIPE SEGMENT																				
19508188	65	COP	TRBA	ICOP	JEL	1XV6005		1501	IABNE	1TB2	N	N	08/05/95	08/05/95	00/00/00	16	05	I	4028	
WORK REQUESTED ...																				
WRT-47017: FOUND COMPUTER POINTS ZD-2010, -2012, -2014 AND -2016. CONTROL VALVES INDICATION WAS INCORRECT. LIMIT SWITCH IS NOT SET-UP CORRECTLY.																				
WRT-47018: FOUND COMP. PNTS ZD-2056 AND -2058, INTERCEPT VALVE INDICATION WAS INCORRECT. LIMIT SWITCH APPEARS TO BE PROBLEM.																				
FOREMAN COMMENTS: *FORCED OUTAGE, PARTS ARE IN. *TROUBLESHOOT COMPUTER PTS																				
WORK INSTRUCTIONS: INVESTIGATE/TROUBLESHOOT COMPUTER POINT LOOPS. ADJUST LIMIT SWITCHES IF NECESSARY. REPLACE DEFECTIVE BOARDS IF REQUIRED. VERIFY COMPUTER PD. 'S ARE OPERATING CORRECTLY HWG 2/8/95 REF 1X44A01-280																				
MPL/TAG ...																				
MPL/TAG 1XV6005																				
CLEARANCE ...																				
CLEAR 0 STA MPL/TAG 11505PIPE SYS FEG 1305 IAD80 P&ID M/A M LOCATION IVARIOUS OPS DESCRIPTION SYSTEM 1305 PIPE SEGMENT																				
19508674	2A	COP	TRBA	MEOP	JLF	1HV6179		1501	IABCH	1TB5-TC/	M	N	10/25/95	10/25/95	04/26/95	16	05	I	4811	

WMO NO.	ST	TYPE	TEAM	DISC	FORE	NUMBERS	MPL/TAG	SYS	FEG	LOCATION	CLR	RWP	SCH	REQ	DATES	P2	CODE	CONTROL	PRI	
															SCH	END	REQUIRED	RFL	RFR	

WORK REQUESTED ... VALVE HAS A SMALL PACKING LEAK. INVESTIGATE AND TIGHTEN PACKING AS NECESSARY TO STOP LEAK.																				
FOREMAN COMMENTS: *																				
WORK INSTRUCTIONS: ADJUST VALVE PACKING AND VERIFY OPERABILITY PER MAINTENANCE PROCEDURE 2 5056-C. NO SPECIFIC STROKE TIME. MAINTAIN ZONE IV HOUSEKEEPING.																				
MPL/TAG ...																				
MPL/TAG 1HV6179																				
CLEARANCE ...																				
CLEAR 0 STA MPL/TAG 11505PIPE SYS FEG 1305 IAD80 P&ID M/A M LOCATION IVARIOUS OPS DESCRIPTION SYSTEM 1305 PIPE SEGMENT																				
19485772	65	COP	TRBC	ICOP	F&Z	1LV4535		1504	IAPAF	1TB4-TE/	N	N	05/04/96	05/05/96	00/00/00	16	05	I	P	40
WORK REQUESTED ... BOTH OF THE HEATER DRAIN TANK HIGH LEVEL DUMP VALVES SEEM TO BE LEAKING PAST THE SEAT AS INDICATED BY HIGH INLET PIPE TEMPERATURES. 1LV4534 IS ALSO HOT ON THE OUTLET SIDE.																				
FOREMAN COMMENTS: *I&C TO CHECK SETUP- POTENTIAL EFFICIENCY GAIN**																				
WORK INSTRUCTIONS: ICOP TO SETUP VALVES IN ACCORDANCE WITH PROCEDURE 22285-C. IF VALVES REQUIRE REMORK RETURN WMO TO MEOP MFG FOR WORK INSTRUCTIONS AND PARTS. MAINTAIN ZONE IV HOUSEKEEPING. TGD 6/14/95																				
MPL/TAG ...																				
MPL/TAG 1LV4535																				
CLEARANCE ...																				
CLEAR 0 STA MPL/TAG 11505PIPE SYS FEG 1305 IAD80 P&ID M/A M LOCATION IVARIOUS OPS DESCRIPTION SYSTEM 1305 PIPE SEGMENT																				
19484884	65	COP	TRBB	ICOP	LN2	1LV4524		1504	IAPCB	1TB2	N	N	08/06/88	08/06/88	00/00/88	16	05	I	P	4011
WORK REQUESTED ... HSDT "C" DUMP VALVE IS PASSING FLOW TO CONDENSER - UPSTREAM PIPE TEMP IS 245 DEG WITH VALVE APPEARING CLOSED. (INSTRUMENT SIGNAL WAVING FROM 18 TO 19.5 PSI WITH OUTPUT STEADY AT 34.5) NOTE: SIMILAR TEMP FOR 1LV4525 IS 100 DEG																				
FOREMAN COMMENTS: ** I&C CHECK SET UP AT FORCED OUTAGE**																				
MPL/TAG ...																				
MPL/TAG 1LV4524																				
CLEARANCE ...																				
CLEAR 0 STA MPL/TAG 11505PIPE SYS FEG 1305 IAD80 P&ID M/A M LOCATION IVARIOUS OPS DESCRIPTION SYSTEM 1305 PIPE SEGMENT																				
19484171	65	COP	TRBC	MEOP	LN2	11504X4680		1504	IAPAA	1TB5	Y	N	05/04/96	05/04/96	01/06/95	16	05	I	4	4011
WORK REQUESTED ... VALVE HAS PACKING LEAK. PLEASE INVESTIGATE AND REPAIR. 16 DROPS PER MINUTE ON 12/28/94. THIS IS AN ISOLATION VALVE TO MSR A HIGH LEVEL TRIP SWITCH																				
WORK INSTRUCTIONS: CAUTION: THIS IS AN ISOLATION VALVE TO MSR A HIGH LEVEL TRIP SWITCH. ADJUST PACKING PER 25039-C. REPACK VALVE PER 25039-C																				
MPL/TAG ...																				
MPL/TAG 11504X4680																				
CLEARANCE ...																				
CLEAR 0 STA MPL/TAG 11505PIPE SYS FEG 1305 IAD80 P&ID M/A M LOCATION IVARIOUS OPS DESCRIPTION SYSTEM 1305 PIPE SEGMENT																				

MWO NO. ST TYPE TEAM D1C FORE NUMBERS MPL/TAG SYS FEG LOCATION CLR RWP SCH BEG SCH END REQUIRED P2 CODE CONTROL PRI

19501939 65 COP TRBA WEDP LH2 1TV6888 1526 ICEAB 1TB1 Y N 85/85/96 85/85/96 86/86/88 16 05 I 3028  
WORK REQUESTED ... VALVE ACTUATOR YOKE IS MOVING WHEN VALVE MOVEMENT IS CALLED FOR.  
APPEARS LIKE YOKE LOCK NUT IS NOT TIGHT, HOWEVER IT LOOKS LIKE SOMEONE  
HAS ATTEMPTED TO TIGHTEN SAME WITHOUT SUCCESS.  
VALVE OBSERVED TO BE OPERATING SATISFACTORY BY LAVENDER/DUNN/STANLEY  
ON 06/23/95 AM YOKE RING APPEARED TO BE TIGHT BUT LOOKS TO HAVE BEEN  
HAMMERED. VALVE ALSO HAS A SLIGHT PACKING LEAK. JBS  
WORK INSTRUCTIONS: REPACK VALVE PER 25859-C.  
MPL/TAG ...  
MPL/TAG 1TV6888 SYS FEG 1526 ICEAB LOCATION 1TB1 P&ID 1K40B195 OPS DESCRIPTION STATOR CLG, TEMPERATURE, CONTROL, VALVE, FAILS TO  
CLEARANCE ... CLEAR 0 STA MPL/TAG SYS FEG P&ID LOCATION OPS DESCRIPTION

19502790 65 COP TRBA ELOP JEL 1HS6915 1526 ICEAA 1TB1 N W 18/14/95 18/16/95 18/16/95 16 05 I 3028  
WORK REQUESTED ... STATOR COOLING PUMP "A" NOT RUNNING - RED FLAG (BELIEVE MECH INDICATION  
BROKEN)  
WORK INSTRUCTIONS: REMOVR OR REPLACE AS REQUIRED. DOCUMENT ALL WORK PERFORMED.  
MAINTAIN ZONE 4 HOUSEKEEPING.  
MPL/TAG ...  
MPL/TAG 1HS6915 SYS FEG 1526 ICEAA LOCATION 1TB1 P&ID 1K40B195 OPS DESCRIPTION CONT SM (PHSC) FOR 1-1526-E4-501-P81, STATOR C  
11526E4501H81 1526 ICEAA 1TB1 1K40B195 B4 GEN STAT COOL PUMP A MTR  
RXTRIP 1MB1286 1805 ICEAA 1TB2-TC/T12 1K40B195 B4 480V SWGR FOR BKR FOR 1-1526-E4-501-P81  
CLEARANCE ... CLEAR 0 STA MPL/TAG SYS FEG P&ID LOCATION OPS DESCRIPTION

19502866 60 COP TRBA ICOP JEL 11528P50EC 1528 1HB00 1TB3-YE/ N W 08/12/95 08/13/95 08/08/88 16 05 I E 3028  
WORK REQUESTED ... GEN. EXCITATION POWER SUPPLY FAILURE ALARM IN.  
ALARM CLEARED  
FOREMAN COMMENTS: #COOLED POWER SUPPLY-ALARM NO LONGER IN  
#PARTS ARE IN. JCC 12/20/95  
WORK INSTRUCTIONS: INVESTIGATE TO DETERMINE CAUSE FOR ALARM. REMOVR, REPLACE, CALIBRATE  
COMPONENTS AS REQUIRED TO RESTORE SYSTEM OPERABILITY.  
#1 24V POWER SUPPLY IS DRIFTING. 24.4 TO 24.2V. MAY NEED TO ADJUST  
AND/OR REPLACE.  
MPL/TAG ...  
MPL/TAG 11528P50EC SYS FEG 1528 1HB00 LOCATION 1TB3-YE/T14 P&ID 1K40B195 OPS DESCRIPTION GENREX EXCITER CUBICLE  
CLEARANCE ... CLEAR 0 STA MPL/TAG SYS FEG P&ID LOCATION OPS DESCRIPTION

19502885 65 COP TRBA ICOP JEL 11615Q5EHC 1615 1CH01 1CB165 N W 85/94/96 85/87/96 88/87/95 16 05 I 4028  
WORK REQUESTED ... IN CABINET 1HCQHC1 THERE IS A FAN FOR POWER SUPPLY (-22V PWG-08)  
WHICH IS NOT RUNNING. THIS CAUSED A MALFUNCTION LIGHT ON THE TURBINE  
EHC PANEL IN THE CONTROL ROOM.  
FOREMAN COMMENTS: #  
#  
WORK INSTRUCTIONS: INVESTIGATE/REMOVR AS REQUIRED TO RESTORE FAN TO PROPER OPERATION.  
REF. ATTACHED LETTER FROM JIM MONTGOMERY AND MWO 19502847. MAINTAIN  
ZONE IV HOUSEKEEPING. TGG 7/31/95  
MPL/TAG ...  
MPL/TAG SYS FEG LOCATION P&ID OPS DESCRIPTION

MWO NO. ST TYPE TEAM D1C FORE NUMBERS MPL/TAG SYS FEG LOCATION CLR RWP SCH BEG SCH END REQUIRED P2 CODE CONTROL PRI

11615Q5EHC 1615 1CH01 1CB165 EHC CABINET  
CLEARANCE ... CLEAR 0 STA MPL/TAG SYS FEG P&ID LOCATION OPS DESCRIPTION  
19502425 65 COP TRBA ICOP JEL 11615Q5EHC 1615 1CH01 1CB165 N W 85/86/96 85/87/96 88/88/88 16 05 I 4028  
WORK REQUESTED ... "PNC IN CONTROL" STATUS LIGHT IS BURNED OUT. MAY REQUIRE TURBINE OFF  
LINE TO REPLACE.  
THE FOLLOWING LIGHTS ON EHC SYSTEM MONITORING PANEL WILL NOT  
ILLUMINATE.  
REACTOR TRIP HAZARD DUE TO LOCATION OF BULB SOCKET TGG 9/87/95  
FOREMAN COMMENTS: #  
#  
WORK INSTRUCTIONS: REPLACE LIGHTS AS REQUIRED. \*\*\*\*\*CAUTION\*\*\*\*\* TRIP HAZARD  
MAINTAIN ZONE IV HOUSEKEEPING. TGG 8/18/95  
MPL/TAG ...  
MPL/TAG 11615Q5EHC SYS FEG 1615 1CH01 LOCATION 1CB165 OPS DESCRIPTION EHC CABINET  
CLEARANCE ... CLEAR 0 STA MPL/TAG SYS FEG P&ID LOCATION OPS DESCRIPTION


19502776 65 COP TRBA ICOP JLP 11615Q5TTP 1615 1CH01 1CB165 N W 85/85/96 85/85/96 88/88/88 16 05 I 3028  
WORK REQUESTED ... DURING THE PERFORMANCE OF THE TURBINE MECHANICAL TRIP PISTON TEST  
THE TEST MALFUNCTION LIGHT COMES ON WHILE THE TEST CIRCUIT IS  
RESETTING. LIGHT GOES OUT AFTER A FEW SECONDS. NOTE THIS ONLY OCCURS  
AFTER THE TEST HAS NOT BEEN PERFORMED IN SEVERAL DAYS. TESTING  
IMMEDIATELY FOLLOWING A TEST IN WHICH THE LIGHT COMES ON RESULTS IN A  
NORMAL TEST WITH THE MALFUNCTION LIGHT NOT COMING ON.  
WORK INSTRUCTIONS: INVESTIGATE PROBLEM WITH THE TEST MALFUNCTION LIGHT DURING THE TURBINE  
MECHANICAL TRIP TEST. REMOVR OR REPLACE PARTS AS REQUIRED.  
CO-ORDINATE ALL WORK WITH OPERATIONS. IF OUTAGE IS REQUIRED TO  
CORRECT PROBLEM RETURN TO WORK PLANNING TO BE RESCHEDULE.  
MPL/TAG ...  
MPL/TAG 11615Q5TTP SYS FEG 1615 1CH01 LOCATION 1CB165 OPS DESCRIPTION TURBINE TEST PANEL  
CLEARANCE ... CLEAR 0 STA MPL/TAG SYS FEG P&ID LOCATION OPS DESCRIPTION

19502880 65 COP IACC ICOP JRW 11627CSW08MM1 1627 R165 N W 85/26/96 85/28/96 18/18/95 16 05 IX 20  
WORK REQUESTED ... COMPUTER POINT UV0035 VALIDATE# NEUTRON FLUX INTERMEDIATE RANGE IS BAD  
WITH ALL INPUTS HAVING GOOD QUALITY CAUSING REACTIVITY STATUS TREE TO  
BE BAD (PURPLE) AND THE CSFST QMCD ANNUNCIATOR TO BE IN A SOLID ALARM  
STATE. COMPARISON OF 1M156 AND 1M155 SHOWED THAT 1M156 IS DRIFTING  
HIGH.  
FOREMAN COMMENTS: #1-56; \*\*\*\*\*IMMEDIATE RELEASE\*\*\*\*\* ON RICK JAMES DESK.  
WORK INSTRUCTIONS: INVESTIGATE COMPUTER POINT CIRCUITRY AND LOGIC TO DETERMINE WHY IT IS  
READING "BAD". MAKE ADJUSTMENTS AS NECESSARY TO RESTORE PROPER  
INDICATION AND VALUE. CALIBRATE IF NEEDED. RETURN TO W/P FOR FURTHER  
PACKAGING IF CONTAINMENT ENTRY IS REQUIRED. MWG 10/16/95  
MPL/TAG ...  
MPL/TAG 11627CSW08MM1 SYS FEG 1627 R165 OPS DESCRIPTION ALTERNATE SPDS M15TH MONITOR  
RXTRIP 11602Q5M1R 1602 1SC06 1CB165 NUCLEAR INST RACKS  
1RES1105 1602 1SC06 1RB194-RXCV INTERMEDIATE RANGE DETECT (NE 36)  
1RES1101 1602 1SC06 1RB194-RXCV-0M1 SOURCE RANGE DETECTOR (NE 32)  
1DF1111R 1602 1SC06 1RB194-RXCV-0M1

UNIT 1 FORCED OUTAGE

ID	Task Name	Duration	12 AM   4 AM   8 AM   12 PM   4 PM   8 PM						12 AM   4 AM   8 AM   12 PM   4 PM   8 PM						12 AM   4 AM					
			Gantt Chart Area																	
1	ASSEMBLE RESPONSE TE	2h	ASSEMBLE RESPONSE TEAM																	
2	SCOPE MEETING	1h	FORCED OUTAGE SCOPE MEETING-EVALUATE DEMIN WATER NEEDS																	
3	COLLECT DATA	4h	COLLECT TRIP DATA																	
4	START DISCOVERY WORK	17h	DISCOVERY WORK																	
5	START FORCED OUTAGE	2.42d	FORCED OUTAGE IMMEDIATE																	
6	OPS COOLDOWN TO	5h	OPS COOLDOWN TO 250 DEG ON STM DUMPS																	
7	OPS HANG CLEARAN	5h	OPS HANG FORCED OUTAGE CLR'S																	
8	ICOP 19502880	48h	I&C REPLACE 1N136																	
9	ICOP 19404084	5h	I&C SETUP 1LV4624																	
10	ICOP 19502386	6h	I&C CHANGE PWR SUPPLY ON 11328P6GEC																	
11	ICOP 19500180	6h	I&C INVESTIGATE COMPUTER POINTS																	
12	ICOP 19502283	6h	ICOP REPLACE FAN 11616Q5EHC																	
13	ICOP 19502425	3h	ICOP REPLACE LIGHT 11616Q5EHC																	
14	ICOP 19503772	8h	I&C SETUP 1LV4333/4334																	
15	ICOP 19500479	4h	ICOP REWORK FITTINGS 1FS6806A																	
16	ICOP 19502776	5h	I&C TROUBLE SHOOT TURB TEST PANEL																	
17	ELOP 19502790	2h	ELOP REPLACE HAND SWITCH 1HS6916																	
18	MEOP 19404183	3h	MEOP ADJUST 1LV4362																	
19	ICOP 19404183	4h	I&C SETUP 1LV4362																	
20	MEOP 19500170	3h	MEOP ADJ PACKING 1LV4395B																	
21	MEOP 19404171	4h	MEOP REPACK 11304X4680																	
22	MEOP 19501939	4h	MEOP REPAIR 1TV6800																	
23	MEOP 19500495	2h	MEOP ADJUST PACKING 1HV5227																	
24	OFS PERFORM 14850-	1h	OPS PERFORM 14850-1 FOR 1HV5227																	
25	MEOP 19500674	2h	MEOP ADJUST PACKING 6179																	

UNIT 1 FORCED OUTAGE



MWO NO. ST TYPE TEAM DISC FORE NUMBERS NPL/TAG SYS FEG LOCATION CLR RFP SCR BEG DATES P2 CODE CONTROL PRI  
REQD RFL RFR

29501422 65 COP NSSB WEDP MWO ZHV3026B 1501 ZABCF 2CB1-R12 N M 00/00/00 00/00/00 00/00/00 25 05 I 3536  
WORK REQUESTED ... MSIV ZHV-3026B HAS A PACKING LEAK  
FOREMAN COMMENTS: " "  
WORK INSTRUCTIONS: ADJUST PACKING ON VALVE ZHV3026B PER MAINT.PROC. 26510-C & Z5036-C.  
IF LEAK CONTINUES REPACK VALVE PER MAINT.PROC. 26510-C & Z5036-C.  
MAINTAIN ZONE IV HOUSEKEEPING.

MPL/TAG .....  
NPL/TAG  
RXTRIP/ILRT ZHV3026B  
CLEARANCE ...  
CLEAR 0 STA MPL/TAG SYS FEG LOCATION P&ID OPS DESCRIPTION  
240D159-2 D7 MAIN STEAM,SG 3 DNSTRM,MSIV,,FC,,B

29501565 65 COP NSSB WEDP RSH ZHV5006B 1501 ZABAF ZAB159-1 M N 10/25/95 10/25/95 05/11/95 25 05 I 30  
WORK REQUESTED ... DURING PERFORMANCE OF OSP 14042-2,MSIV ZHV5006B WENT PAST THE 90% OPEN  
POSITION. BLOCK VALVES WERE CLOSED, THE AIR SUPPLY PRESSURE TO THE  
HYDRAULIC FLUID PUMP HAS RAISED FROM 65 PSIG TO 72 PSIG AND THE VALVE  
RE-OPENED. TROUBLESHOOT AND REPAIR VALVE PROBLEM.  
FOREMAN COMMENTS: W/N SURV. 14042-201 SCHEDULED 10-25-95.  
WORK INSTRUCTIONS: TROUBLE SHOOT VALVE ZHV5006B PER MAINTENANCE PROC.20253-C. CHECK LIST W1  
LL BE DEVELOP BY THE SYSTEM ENGINEER. IF REWORK IS REQUIRED RETURN MWO  
TO MFG FOR REV.TO MWO.  
MAINTAIN ZONE IV HOUSEKEEPING.

MPL/TAG .....  
NPL/TAG  
RXTRIP/ILRT ZHV5006B  
CLEARANCE ...  
CLEAR 0 STA MPL/TAG SYS FEG LOCATION P&ID OPS DESCRIPTION  
240B159-2 H7 MAIN STEAM,SG 1 DNSTRM,MSIV,,FC,,B

29502124 65 COP YRBB WEDP MWO ZHV4250A 1505 ZAGAD ZTB245-Y M N 00/00/00 00/00/00 00/00/00 25 05 I 4028  
WORK REQUESTED ... 5A EXTRACTION STM MOV HAS A SMALL PACKING LEAK. TIGHTEN OR REPACK  
VALVE AS NECESSARY.  
WORK INSTRUCTIONS: ADJUST/REPACK VALVE PER Z5059-C.  
RDA 09/05/95

MPL/TAG .....  
NPL/TAG  
RXTRIP/ILRT ZHV4250A  
CLEARANCE ...  
CLEAR 0 STA MPL/TAG SYS FEG LOCATION P&ID OPS DESCRIPTION  
2K40B162-2 F7 EXTRACT STM,9TH STG TO,HTR 5A STOP,,MOV 400V

29501571 2P COP YRBC WEDP JS ZLSH4546B 1504 ZAFCA ZTB5 Y N 10/10/95 10/11/95 05/01/95 25 05 I 30  
WORK REQUESTED ... FITTING ON PIPING TO LEVEL SWITCH ZLSH4246B HAS A SMALL STEAM LEAK.  
THE LEAK IS JUST A WISP AT THIS TIME. FITTING MAY BE ABLE TO BE  
TIGHTENED TO STOP LEAK. USE CAUTION DUE TO HEAT IN THE AREA. PLEASE  
INVESTIGATE AND REPAIR AS NECESSARY.  
FOREMAN COMMENTS: CAUTION RX TRIP SEE CONT. SHT.  
WORK INSTRUCTIONS: TIGHTEN INSTRUMENT FITTINGS AS REQUIRED TO STOP LEAK PER PROC.20440-C.  
SEE CONT.SHT.  
MAINTAIN ZONE IV HOUSEKEEPING.

MPL/TAG .....  
NPL/TAG  
RXTRIP ZLSH4546B  
RXTRIP ZLSH4546C  
RXTRIP ZLSH4546A  
RXTRIP ZLSH4547A  
1504 ZAFCA ZTB5 2K40B163-2 H8 MSR C HI TRIP  
1504 ZAFCA ZTB5 2K40B163-2 H8 MSR C HI TRIP  
1504 ZAFCA ZTB5 2K40B163-2 H8 MSR C HI TRIP  
1504 ZAFDA ZTB5 2K40B163-2 H5 MSR D HI TRIP

MWO NO. ST TYPE TEAM DISC FORE NUMBERS NPL/TAG SYS FEG LOCATION CLR RFP SCR BEG DATES P2 CODE CONTROL PRI  
REQD RFL RFR

RXTRIP 2LSH4547B 1504 ZAFDA ZTB5 2K40B163-2 H5 MSR D HI TRIP  
RXTRIP 2LSH4547C 1504 ZAFDA ZTB5 2K40B163-2 H5 MSR D HI TRIP  
RXTRIP 2LSH4545A 1504 ZAFBA ZTB5 2K40B163-1 H5 MSR B HI TRIP  
RXTRIP 2LSH4545B 1504 ZAFBA ZTB5 2K40B163-1 H5 MSR B HI TRIP  
RXTRIP 2LSH4545C 1504 ZAFBA ZTB5 2K40B163-1 H5 MSR B HI TRIP  
RXTRIP 2LSH4544A 1504 ZAFAA ZTB5 2K40B163-1 H7 MSR A HI TRIP  
RXTRIP 2LSH4544B 1504 ZAFAA ZTB5 2K40B163-1 H8 MSR A HI TRIP  
RXTRIP 2LSH4544C 1504 ZAFAA ZTB5 2K40B163-1 H8 MSR A HI TRIP  
CLEARANCE ...  
CLEAR 0 STA MPL/TAG SYS FEG LOCATION P&ID LOCATION OPS DESCRIPTION

29501999 65 COP YRBB ICOP JLF ZLV4552 1504 ZAFCC ZTB2 T/F-T/2 M N 00/10/95 00/11/95 07/31/95 I 30  
WORK REQUESTED ... THE POSITIONER GUIDE NEEDS TO BE REPLACE ON ZLV-4552. PLEASE  
INVESTIGATE AND REPAIR AS NECESSARY.  
WORK INSTRUCTIONS: REWORK/ REPLACE POSITIONER GUIDE AS REQUIRED. REF. VENDOR MANUAL  
ZKSAC00-925. MWG 7/31/95

MPL/TAG .....  
NPL/TAG  
RXTRIP ZLV4552  
CLEARANCE ...  
CLEAR 0 STA MPL/TAG SYS FEG LOCATION P&ID OPS DESCRIPTION  
2K40B163-2 B6 FW HTR DRMS,RDT C DRAIN,TO HEATER 6B,,ADV FC

29501330 65 COP YRBA WEDP JEL Z1506K4002 1506 ZFCBA ZTB1-T7/H M N 04/15/95 04/15/95 00/00/00 25 05 I 3026  
WORK REQUESTED ... INSIDE THE B MFPT ACCESORIES PANEL THERE ARE SEVERAL HYDRAULIC OIL  
LEAKS  
FOREMAN COMMENTS: " "  
WORK INSTRUCTIONS: REWORK LEAKS AS REQUIRED

MPL/TAG .....  
NPL/TAG  
RXTRIP Z1506K4002  
CLEARANCE ...  
CLEAR 0 STA MPL/TAG SYS FEG LOCATION P&ID OPS DESCRIPTION  
2K40B166 E7 STM GEN FW PUMP TURB DRIV


29501352 65 COP NSSC WEDP MWO Z1612M6001 1612 ZSE00 ZRBA M N 00/00/00 00/00/00 04/11/95 25 05 I 2044  
WORK REQUESTED ... THERE IS A SMALL LEAK AT UNIT 2 SEAL TABLE. IAC DISCOVERED LEAK AND  
BELIEVE IT TO BE ON THINBLE A-6 (A 10 PATH, 06 LOCATION). MAY BE  
LEAKING AT THE HIGH PRESSURE SWAGE LOCK. PLEASE INVESTIGATE AND REPAIR  
AS NECESSARY.

MPL/TAG .....  
NPL/TAG  
RXTRIP Z1612M6001  
CLEARANCE ...  
CLEAR 0 STA MPL/TAG SYS FEG LOCATION P&ID OPS DESCRIPTION  
1612 ZSE00 ZRBA INCORE DET DRIVE UNIT

29502165 65 COP YRBA ICOP JEL Z1615052HC 1615 ZCH00 ZCB164 M N 00/00/00 00/00/00 00/00/00 25 05 I 4028  
WORK REQUESTED ... "PMG IN CONTROL" STATUS LIGHT IS BURNED OUT.MAY REQUIRE TURBINE OFF  
LINE TO REPLACE.  
FOREMAN COMMENTS: " "  
WORK INSTRUCTIONS: REPLACE STATUS LIGHT AS REQUIRED. CAUTION TRIP HAZARD  
MAINTAIN ZONE IV HOUSEKEEPING. TCG 8/18/95

MPL/TAG .....  
NPL/TAG  
RXTRIP Z1615052HC  
CLEARANCE ...  
CLEAR 0 STA MPL/TAG SYS FEG LOCATION P&ID OPS DESCRIPTION  
1615 ZCH00 ZCB164 FMC FIB TRIP

Unit 2 Forced Outage



NMO NO.	ST	TYPE	TEAM	DISC	FORE	NUMBERS	MPL/TAG	SYS	FEG	LOCATION	CLR	RHP	SCH	BEG	DATES	SCH	END	REQUIRED	P2	CODE	CONTROL	PRI																																													
19105576	45	COP	TRBA	MEOP	WMO	1UV6281	1501 IABBG	1501 IABBG	TBA-T20	STEAMT1X4DB160-1	D1				05/04/96	05/04/96	08/15/95	16	05	T	FB	P	30567																																												
<p>WORK REQUESTED .. PACKING WAS ADJUSTED TO STOP PACKING LEAK UNDER NMO 19104226. DUE TO PLANT CONDITION OPERATION COULD NOT STROKE THE MOV. WHEN PLANT CONDITIONS PERMIT THE MOV NEEDS TO BE STROKE TO TAKE CURRENT AND STROKE TIME. NOTE WRT WILL BE PLACED ON MCC FEEDER BKR 1MBB-17 ADD WRT 22751. ADD WRT 51271 FOR DUAL LIGHT INDICATION NPRODS 'Y'</p> <p>FOREMAN COMMENTS.: *VALVE NEEDS SETTING UP AND THEN STROKED WHEN PLANT STEAM IS DOWN. MHW 18/24/94 1R6 - 1R6 - 1R6 ----- STEAM BLOWS TO ATMOSPHERE WHEN STROKED</p> <p>WORK INSTRUCTIONS: REMOVE OPERATOR AND REMOVE ANY BROKEN MOUNTING BOLTS. REPLACE OPERATOR AND WRENCH TIGHTEN MOUNTING BOLTS (SEE WRT 22751) STROKE VALVE AND ADJUST PACKING AS REQUIRED PER 25056-C. MAINTAIN ZONE IV HOUSEKEEPING</p>																																																																			
<p>MPL/TAG .....</p> <table border="1"> <thead> <tr> <th>MPL/TAG</th> <th>SYS</th> <th>FEG</th> <th>LOCATION</th> <th>PaID</th> <th>OPS DESCRIPTION</th> </tr> </thead> <tbody> <tr> <td>1UV6281</td> <td>1501</td> <td>IABBG</td> <td>TBA-T20</td> <td>STEAMT1X4DB160-1</td> <td>D1</td> </tr> </tbody> </table> <p>CLEARANCE ..</p> <table border="1"> <thead> <tr> <th>CLEAR #</th> <th>STA</th> <th>MPL/TAG</th> <th>SYS</th> <th>FEG</th> <th>PaID</th> <th>LOCATION</th> <th>OPS DESCRIPTION</th> </tr> </thead> <tbody> <tr> <td>19200470</td> <td>A</td> <td>1UV6281</td> <td>1501</td> <td>IABBG</td> <td>1X4DB160-1</td> <td>D1</td> <td>ITBA-T20-STEAMTAIN STEAM,SV 1 AND 2,UPSTREAM</td> </tr> <tr> <td>19615725</td> <td>I</td> <td>1130SPIPE</td> <td>1505</td> <td>IAD00</td> <td>MM N/A MM</td> <td>VARIOUS</td> <td>SYSTEM 1505 PIPE SEGMENT</td> </tr> <tr> <td>19615748</td> <td>I</td> <td>1UV6281</td> <td>1501</td> <td>IABBG</td> <td>1X4DB160-1</td> <td>D1</td> <td>ITBA-T20-STEAMTAIN STEAM,SV 1 AND 2,UPSTREAM</td> </tr> </tbody> </table>																								MPL/TAG	SYS	FEG	LOCATION	PaID	OPS DESCRIPTION	1UV6281	1501	IABBG	TBA-T20	STEAMT1X4DB160-1	D1	CLEAR #	STA	MPL/TAG	SYS	FEG	PaID	LOCATION	OPS DESCRIPTION	19200470	A	1UV6281	1501	IABBG	1X4DB160-1	D1	ITBA-T20-STEAMTAIN STEAM,SV 1 AND 2,UPSTREAM	19615725	I	1130SPIPE	1505	IAD00	MM N/A MM	VARIOUS	SYSTEM 1505 PIPE SEGMENT	19615748	I	1UV6281	1501	IABBG	1X4DB160-1	D1	ITBA-T20-STEAMTAIN STEAM,SV 1 AND 2,UPSTREAM
MPL/TAG	SYS	FEG	LOCATION	PaID	OPS DESCRIPTION																																																														
1UV6281	1501	IABBG	TBA-T20	STEAMT1X4DB160-1	D1																																																														
CLEAR #	STA	MPL/TAG	SYS	FEG	PaID	LOCATION	OPS DESCRIPTION																																																												
19200470	A	1UV6281	1501	IABBG	1X4DB160-1	D1	ITBA-T20-STEAMTAIN STEAM,SV 1 AND 2,UPSTREAM																																																												
19615725	I	1130SPIPE	1505	IAD00	MM N/A MM	VARIOUS	SYSTEM 1505 PIPE SEGMENT																																																												
19615748	I	1UV6281	1501	IABBG	1X4DB160-1	D1	ITBA-T20-STEAMTAIN STEAM,SV 1 AND 2,UPSTREAM																																																												
19501802	0F	COP	HSSB	MEOP	OPS	11901X4219	1901 IHB01	1901 IHB01	IRB171-2	Y	Y				09/11/94	09/11/94	08/08/00	16	05	F		5044																																													
<p>WORK REQUESTED .. VALVE WILL NOT TURN. VALVE STEM APPEARS TO BE BINDING. NPRODS 'Y'</p> <p>FOREMAN COMMENTS.: F/T-OPS VER PROP VLV OPS</p> <p>WORK INSTRUCTIONS: REWORK VALVE PER 26640-C AND 25056-C, TACK WELD YOKE PER MPCS # 950888. *1-1901-K4-219 &amp; 106 NEED TO CUT OF 1/2 TO 1" ON EACH END OF T-HANDLE &amp; REF REV SHEET. AG 9/11/94</p>																																																																			
<p>MPL/TAG .....</p> <table border="1"> <thead> <tr> <th>MPL/TAG</th> <th>SYS</th> <th>FEG</th> <th>LOCATION</th> <th>PaID</th> <th>OPS DESCRIPTION</th> </tr> </thead> <tbody> <tr> <td>11901X4219</td> <td>1901</td> <td>IHB01</td> <td>IRB171-20/21</td> <td>1X4DB127</td> <td>D1</td> </tr> </tbody> </table> <p>CLEARANCE ..</p> <table border="1"> <thead> <tr> <th>CLEAR #</th> <th>STA</th> <th>MPL/TAG</th> <th>SYS</th> <th>FEG</th> <th>PaID</th> <th>LOCATION</th> <th>OPS DESCRIPTION</th> </tr> </thead> <tbody> <tr> <td>19500350</td> <td>I</td> <td>11901X4219</td> <td>1901</td> <td>IHB01</td> <td>1X4DB127</td> <td>D1</td> <td>IRB171-20/21</td> </tr> </tbody> </table>																								MPL/TAG	SYS	FEG	LOCATION	PaID	OPS DESCRIPTION	11901X4219	1901	IHB01	IRB171-20/21	1X4DB127	D1	CLEAR #	STA	MPL/TAG	SYS	FEG	PaID	LOCATION	OPS DESCRIPTION	19500350	I	11901X4219	1901	IHB01	1X4DB127	D1	IRB171-20/21																
MPL/TAG	SYS	FEG	LOCATION	PaID	OPS DESCRIPTION																																																														
11901X4219	1901	IHB01	IRB171-20/21	1X4DB127	D1																																																														
CLEAR #	STA	MPL/TAG	SYS	FEG	PaID	LOCATION	OPS DESCRIPTION																																																												
19500350	I	11901X4219	1901	IHB01	1X4DB127	D1	IRB171-20/21																																																												
19502799	7H	COP	TRBB	MEOP	L/JZ	1HV6129	1501 IABBM	1501 IABBM	ITB3-T18/TF	Y	N				05/05/96	05/04/96	08/08/00	16	05	FI	P	4058																																													
<p>WORK REQUESTED .. THE MSR "C" SUPPLY DRAIN MOV DOES NOT CLOSE COMPLETELY BY THE MOTOR. VALVE MUST BE PUT IN HAND WHEEL MODE TO COMPLETELY CLOSE. NPRODS 'M'</p> <p>FOREMAN COMMENTS.: MPCS</p> <p>WORK INSTRUCTIONS: REWORK VALVE PER 26500-C AND REPACK PER 25059-C. SEAL WELD PER MPCS # 940704. REWORK OPERATOR AND SET ROTORS/LIMITSWITCHES PER SETPOI WT DATA SMT. IF OPERATOR REWORK DOES NOT ACHIEVE SATISFACTORY RESULTS ROUTE TO MEOP TO REWORK PER PROC. 26500-C AND 25059-C.</p>																																																																			
<p>MPL/TAG .....</p> <table border="1"> <thead> <tr> <th>MPL/TAG</th> <th>SYS</th> <th>FEG</th> <th>LOCATION</th> <th>PaID</th> <th>OPS DESCRIPTION</th> </tr> </thead> <tbody> <tr> <td>1HV6129</td> <td>1501</td> <td>IABBM</td> <td>ITB3-T18/TF</td> <td>1X4DB160-2</td> <td>B3</td> </tr> </tbody> </table> <p>CLEARANCE ..</p> <table border="1"> <thead> <tr> <th>CLEAR #</th> <th>STA</th> <th>MPL/TAG</th> <th>SYS</th> <th>FEG</th> <th>PaID</th> <th>LOCATION</th> <th>OPS DESCRIPTION</th> </tr> </thead> <tbody> <tr> <td>19615751</td> <td>I</td> <td>1HV6129</td> <td>1501</td> <td>IABBM</td> <td>1X4DB160-2</td> <td>B3</td> <td>ITB3-T18/TF</td> </tr> <tr> <td>19615725</td> <td>I</td> <td>1130SPIPE</td> <td>1505</td> <td>IAD00</td> <td>MM N/A MM</td> <td>VARIOUS</td> <td>SYSTEM 1505 PIPE SEGMENT</td> </tr> </tbody> </table>																								MPL/TAG	SYS	FEG	LOCATION	PaID	OPS DESCRIPTION	1HV6129	1501	IABBM	ITB3-T18/TF	1X4DB160-2	B3	CLEAR #	STA	MPL/TAG	SYS	FEG	PaID	LOCATION	OPS DESCRIPTION	19615751	I	1HV6129	1501	IABBM	1X4DB160-2	B3	ITB3-T18/TF	19615725	I	1130SPIPE	1505	IAD00	MM N/A MM	VARIOUS	SYSTEM 1505 PIPE SEGMENT								
MPL/TAG	SYS	FEG	LOCATION	PaID	OPS DESCRIPTION																																																														
1HV6129	1501	IABBM	ITB3-T18/TF	1X4DB160-2	B3																																																														
CLEAR #	STA	MPL/TAG	SYS	FEG	PaID	LOCATION	OPS DESCRIPTION																																																												
19615751	I	1HV6129	1501	IABBM	1X4DB160-2	B3	ITB3-T18/TF																																																												
19615725	I	1130SPIPE	1505	IAD00	MM N/A MM	VARIOUS	SYSTEM 1505 PIPE SEGMENT																																																												

NMO NO.	ST	TYPE	TEAM	DISC	FORE	NUMBERS	MPL/TAG	SYS	FEG	LOCATION	CLR	RHP	SCH	BEG	DATES	SCH	END	REQUIRED	P2	CODE	CONTROL	PRI																																					
19400702	65	COP	TRBB	ICOP	JLF	1TE14462	1505 IAD00	1505 IAD00	K5D5P796	M	N				05/09/96	05/12/96	08/08/00	16	05	F	3	5016F																																					
<p>WORK REQUESTED .. COMPUTER POINT T2450, UNIT 1, CONDENSATE PUMP B MOTOR UPPER THRUST BEARING, IS READING KXXX. ADD WRT 48134 - PROTEUS POINT IT2450 FOR CONDENSATE PUMP B UPPER BEARING TEMP IS READING KXX. * OSCR WRITTEN TO DELETE FROM OUTAGE SCOPE PER RBR. AG 9-30-94</p> <p>FOREMAN COMMENTS.: INVESTIGATE/REWORK TEMP LOOP "T2450" REPLACE/CAL LOOP COMPONENTS AS REQUIRED</p> <p>WORK INSTRUCTIONS: MAINTAIN ZONE IV HOUSEKEEPING. REMOVE ALL INTERFERENCES NEEDED TO PULL MOTOR COVER FOR REPLACEMENT OF RTD'S.</p>																																																											
<p>MPL/TAG .....</p> <table border="1"> <thead> <tr> <th>MPL/TAG</th> <th>SYS</th> <th>FEG</th> <th>LOCATION</th> <th>PaID</th> <th>OPS DESCRIPTION</th> </tr> </thead> <tbody> <tr> <td>1TE14462</td> <td>1505</td> <td>IAD00</td> <td>K5D5P796</td> <td>1X4DB100P</td> <td></td> </tr> </tbody> </table> <p>CLEARANCE ..</p> <table border="1"> <thead> <tr> <th>CLEAR #</th> <th>STA</th> <th>MPL/TAG</th> <th>SYS</th> <th>FEG</th> <th>PaID</th> <th>LOCATION</th> <th>OPS DESCRIPTION</th> </tr> </thead> <tbody> <tr> <td>1161805001</td> <td></td> <td>1618 IRJ01</td> <td>1CB165</td> <td></td> <td></td> <td>1X4DB196</td> <td>D7</td> </tr> </tbody> </table>																								MPL/TAG	SYS	FEG	LOCATION	PaID	OPS DESCRIPTION	1TE14462	1505	IAD00	K5D5P796	1X4DB100P		CLEAR #	STA	MPL/TAG	SYS	FEG	PaID	LOCATION	OPS DESCRIPTION	1161805001		1618 IRJ01	1CB165			1X4DB196	D7								
MPL/TAG	SYS	FEG	LOCATION	PaID	OPS DESCRIPTION																																																						
1TE14462	1505	IAD00	K5D5P796	1X4DB100P																																																							
CLEAR #	STA	MPL/TAG	SYS	FEG	PaID	LOCATION	OPS DESCRIPTION																																																				
1161805001		1618 IRJ01	1CB165			1X4DB196	D7																																																				
19403650	65	COP	VALV	MEOP	JEL	1HV6052	1501 IABBM	1501 IABBM	ITB2-TF/T19	Y	N				05/15/96	05/14/96	08/08/00	16	05	F	P	5058																																					
<p>WORK REQUESTED .. UNDER NMO 19402250 THE BODY, PLUG AND SEAT WAS FOUND TO BE DAMAGED DURING INSPECTION OF VALVE INTERNALS. NO PARTS COULD BE PROCURED TO MAKE NECESSARY REPAIRS. THE VALVE WAS REASSEMBLED USING DEGRADED PARTS. REPLACE VALVE DURING THE NEXT REFUELING OUTAGE (1R6)</p> <p>FOREMAN COMMENTS.: * CUT OUT VALVE AND WELD IN NEW VALVE PER MPCS # 950756 AND 1V1-1501-665-01, REPACK VALVE PER 25059-C. INSTALL OPERATOR AND PERFORM CHECKOUT PER 26836-C.</p>																																																											
<p>MPL/TAG .....</p> <table border="1"> <thead> <tr> <th>MPL/TAG</th> <th>SYS</th> <th>FEG</th> <th>LOCATION</th> <th>PaID</th> <th>OPS DESCRIPTION</th> </tr> </thead> <tbody> <tr> <td>1HV6052</td> <td>1501</td> <td>IABBM</td> <td>ITB2-TF/T19</td> <td>1X4DB160-5</td> <td>H2</td> </tr> </tbody> </table> <p>CLEARANCE ..</p> <table border="1"> <thead> <tr> <th>CLEAR #</th> <th>STA</th> <th>MPL/TAG</th> <th>SYS</th> <th>FEG</th> <th>PaID</th> <th>LOCATION</th> <th>OPS DESCRIPTION</th> </tr> </thead> <tbody> <tr> <td>19615752</td> <td>I</td> <td>1HV6052</td> <td>1501</td> <td>IABBM</td> <td>1X4DB160-5</td> <td>H2</td> <td>ITB2-TF/T19</td> </tr> <tr> <td>19615725</td> <td>I</td> <td>1130SPIPE</td> <td>1505</td> <td>IAD00</td> <td>MM N/A MM</td> <td>VARIOUS</td> <td>SYSTEM 1505 PIPE SEGMENT</td> </tr> </tbody> </table>																								MPL/TAG	SYS	FEG	LOCATION	PaID	OPS DESCRIPTION	1HV6052	1501	IABBM	ITB2-TF/T19	1X4DB160-5	H2	CLEAR #	STA	MPL/TAG	SYS	FEG	PaID	LOCATION	OPS DESCRIPTION	19615752	I	1HV6052	1501	IABBM	1X4DB160-5	H2	ITB2-TF/T19	19615725	I	1130SPIPE	1505	IAD00	MM N/A MM	VARIOUS	SYSTEM 1505 PIPE SEGMENT
MPL/TAG	SYS	FEG	LOCATION	PaID	OPS DESCRIPTION																																																						
1HV6052	1501	IABBM	ITB2-TF/T19	1X4DB160-5	H2																																																						
CLEAR #	STA	MPL/TAG	SYS	FEG	PaID	LOCATION	OPS DESCRIPTION																																																				
19615752	I	1HV6052	1501	IABBM	1X4DB160-5	H2	ITB2-TF/T19																																																				
19615725	I	1130SPIPE	1505	IAD00	MM N/A MM	VARIOUS	SYSTEM 1505 PIPE SEGMENT																																																				
19405021	65	COP	HSSA	MEOP	ELK	11201U4065	1201 IBBMP	1201 IBBMP	IRB207-19/20	Y	Y				05/05/96	05/04/96	08/08/00	16	05	F		5446																																					
<p>WORK REQUESTED .. WATER LEAKING FROM UNDER INSULATION DOWN TO C-LEVEL. BORON BUILDING ON FLOOR. APPEARS TO BE COMING FROM VALVE 1-1201-U4-065 BUT CANNOT SEE PACKING LEAK FROM OUTSIDE INSULATION. 15 DPH</p> <p>FOREMAN COMMENTS.: * CONTACT SECURITY PRIOR TO ENTRY. INSULATION REMOVAL REQUIRED, TIGHTEN PACKING NUT AND TORQUE BONNET PER MAINTENANCE PROCEDURE 26540-C. MAINTAIN ZONE III HOUSEKEEPING SEE ATT PROCEDURE</p>																																																											
<p>MPL/TAG .....</p> <table border="1"> <thead> <tr> <th>MPL/TAG</th> <th>SYS</th> <th>FEG</th> <th>LOCATION</th> <th>PaID</th> <th>OPS DESCRIPTION</th> </tr> </thead> <tbody> <tr> <td>11201U4065</td> <td>1201</td> <td>IBBMP</td> <td>IRB207-19/20</td> <td>1X4DB140</td> <td>B7</td> </tr> </tbody> </table> <p>CLEARANCE ..</p> <table border="1"> <thead> <tr> <th>CLEAR #</th> <th>STA</th> <th>MPL/TAG</th> <th>SYS</th> <th>FEG</th> <th>PaID</th> <th>LOCATION</th> <th>OPS DESCRIPTION</th> </tr> </thead> <tbody> <tr> <td>19615107</td> <td>I</td> <td>11201U4065</td> <td>1201</td> <td>IBBMP</td> <td>1X4DB140</td> <td>B7</td> <td>IRB207-19/20</td> </tr> </tbody> </table>																								MPL/TAG	SYS	FEG	LOCATION	PaID	OPS DESCRIPTION	11201U4065	1201	IBBMP	IRB207-19/20	1X4DB140	B7	CLEAR #	STA	MPL/TAG	SYS	FEG	PaID	LOCATION	OPS DESCRIPTION	19615107	I	11201U4065	1201	IBBMP	1X4DB140	B7	IRB207-19/20								
MPL/TAG	SYS	FEG	LOCATION	PaID	OPS DESCRIPTION																																																						
11201U4065	1201	IBBMP	IRB207-19/20	1X4DB140	B7																																																						
CLEAR #	STA	MPL/TAG	SYS	FEG	PaID	LOCATION	OPS DESCRIPTION																																																				
19615107	I	11201U4065	1201	IBBMP	1X4DB140	B7	IRB207-19/20																																																				
19405051	65	COP	YRBB	MEOP	LRZ	1PSV4040	1510 IAFAP	1510 IAFAP	ITB5-YG/	Y	N				05/04/96	08/08/00	16	05	F	PG	5071																																						
<p>WORK REQUESTED .. PW WTR HTR SA RELIEF VLV 1PSV-4040 LEAKING BY, SHELL SIDE ADD WRT-55972: PSV-4040 HAS SMALL STEAM LEAK AT FLANGE THAT BOLTS TO HEATER. AG 2-22-95</p> <p>FOREMAN COMMENTS.: *</p>																																																											

WMO NO.	ST	TYPE	TEAM	DISC	FORZE	NUMBERS	MPL/TAG	SYS	FEG	LOCATION	CLR	RHP	SCR	BEG	DATES	SCH	END	REQUIRED	P2	CODE	CONTROL	PRI	
FOREMAN COMMENTS: WALKDOWN COMMITMENT C0029191. WMO, CAN'T WE DO THIS NOW. CJP 10/25/95																							
WORK INSTRUCTIONS: REMOVE AIR PUMP LIFTING HANDLE TO ALLOW MIN. CLEARANCE																							
MPL/TAG .....																							
RXTRIP/ILRT 1HV15196																							
CLEARANCE ..:																							
CLEAR 0 STA MPL/TAG SYS FEG LOCATION P&ID OPS DESCRIPTION																							
19615700 1 1HV15196 1502 1ALMA 1AB11-6MS1 1X4DB168-5 E2 MFW,SG 1 BYPASS,FEEDWATER,ISOLATION,ADV-FC,M,																							
19615651 1 1120186001 1201 1BBA8 1X4DB111 D7 1RBB																							
1950884 65 COP 1ACB ICOP WLD 1FV8538 1505 1ADCC 1CBA- H N 05/05/96 05/05/96 08/06/98 F 50																							
WORK REQUESTED ... COLLECT FEEDWATER REGULATION VALVE CONTROL SIGNAL AND VALVE POSITION DATA FOR COMPARISON TO UNIT 2. RECORDER WILL BE INSTALLED IN 11604QSPCS AND A TEMPORARY POSITION FEEDBACK INDICATOR ATTACHED TO THE VALVE. REFER TO W0 29501421																							
FOREMAN COMMENTS: WMO FORCED OUTAGE WMO																							
WORK INSTRUCTIONS: INSTALL RECORDER IN 11604QSPCS AND A TEMPORARY POSITION FEEDBACK INDICATOR TO 1FV-538. COLLECT VALVE CONTROL SIGNAL AND VALVE POSITION DATA TO COMPARE WITH UNIT 2. CONTACT SYSTEM ENGINEER JAMES WESLEY WITH RESULTS. WMO 5/2/95																							
MPL/TAG .....																							
RXTRIP/ILRT 1FV8538																							
11604QSPCS																							
CLEARANCE ..:																							
CLEAR 0 STA MPL/TAG SYS FEG LOCATION P&ID OPS DESCRIPTION																							
1505 1ADCC 1CBA- 1X4DB168-5 D7 S/G LOOP 3 FMTR VALVE																							
1604 1SC02 1CB1- PROCESS I&C CONTROL GRP 5																							
19501249 65 COP TRBC NEOP WMO 1LSL4356 1504 1AFBF 1TB1-TF/ Y N 05/04/96 05/05/96 08/08/00 16 05 F 4																							
WORK REQUESTED ... LEAK REPAIR WAS INSTALLED BY WMO29501536 AND TEMP-MOD 95-V11029, REMOVE TEMP-MOD AND REMOKE/REPLACE VALVE TO RESTORE VALVE 1LSL4356-GIL																							
FOREMAN COMMENTS: "																							
WORK INSTRUCTIONS: REMOVE TEMP MOD BY CUTTING OUT VALVE 1LSL4356-GIL AND WELDING IN A N EW VALVE. WELD PER WPCS 0 950478																							
REPACK NEW VALVE PER 25039-C																							
MPL/TAG .....																							
RXTRIP/ILRT 1LSL4356																							
CLEARANCE ..:																							
CLEAR 0 STA MPL/TAG SYS FEG LOCATION P&ID OPS DESCRIPTION																							
1504 1AFBF 1TB1-TF/T17 1X4DB165-6 HDT B SHELL																							
11505PIPE 1 1505 1AD00 M N/A M N IVARIOUS OPS DESCRIPTION																							
SYSTEM 1505 PIPE SEGMENT																							
19502172 65 COP TRBA ICOP JEL 1PI0500 1505 1ADNH 1CB165 H N 05/15/96 05/18/96 07/27/95 16 05 F 5																							
WORK REQUESTED ... DELTA P BETWEEN 1PI-507 AND 1PI-508 IS READING APPROX 170 LBS, SHOULD BE 200 LBS. AT 100% POWER. FEED PUMP DISCHARGE PRESSURES ARE BOTH INDICATING 1150 LBS. AND 1PI-508 IS INDICATING APPROX 1120 LBS.																							
SUSPECT INDICATION PROBLEM. INVESTIGATE AND CALIBRATE AS NECESSARY.																							
FOREMAN COMMENTS: "																							
WORK INSTRUCTIONS: REMOKE/REPLACE COMPONENTS AS REQUIRED TO RESTORE INDICATION.																							
MAINTAIN ZONE IV HOUSEKEEPING. TGG 7/15/95																							
MPL/TAG .....																							
RXTRIP/ILRT 1PI0500																							
CLEARANCE ..:																							
CLEAR 0 STA MPL/TAG SYS FEG LOCATION P&ID OPS DESCRIPTION																							
1505 1ADNH 1CB165 1X4DB168-5 A8 FW PUMPS DISCH,HEATER																							

WMO NO.	ST	TYPE	TEAM	DISC	FORZE	NUMBERS	MPL/TAG	SYS	FEG	LOCATION	CLR	RHP	SCR	BEG	DATES	SCH	END	REQUIRED	P2	CODE	CONTROL	PRI	
1PT0500 1505 1ADNH 1 1X4DB168-3 A8 COMD & FW,HEATERS 6A & 6B FEEDWATER,DISCH PRE																							
11604QSPC1 1604 1SC02 1CB1- PROCESS I&C CONTROL GROUP 1 (QCP1)																							
CLEARANCE ..:																							
CLEAR 0 STA MPL/TAG SYS FEG LOCATION OPS DESCRIPTION																							
19502504 40 COP WSSB ICOP WMO 1PI1004 1901 1HB01 1ABD56 H Y 05/07/96 05/07/96 09/18/95 16 05 F 5044																							
WORK REQUESTED ... RCDT PRESSURE OFFSCALE LOW. H2 REGULATOR INDICATES 2 PSIG AND VALVE AL LOWMENT VERIFIED CORRECT. PREVIOUS WMO COSED PENDING RER ON SMALLER RA HGE SCALE,BUT INDICATION HAS ALWAYS BEEN SLIGHTLY POSITIVE UNTIL NOW.																							
FOREMAN COMMENTS: WMO VAM081 IS PENDING TRANSMITTER RESCALE HTG PAUL JACKSON.																							
WORK INSTRUCTIONS: INVESTIGATE LOOP 1P-1004 USING ATTACHED GENERIC CAL DATA PACKAGE. REPLACE ANY DEFECTIVE COMPONENTS AS REQUIRED.																							
MAINTAIN ZONE IV HOUSEKEEPING. REF. 1X6AA02-504. TGG 9/11/95																							
MPL/TAG .....																							
RXTRIP/ILRT 1PI1004																							
1PT1004																							
CLEARANCE ..:																							
CLEAR 0 STA MPL/TAG SYS FEG LOCATION P&ID OPS DESCRIPTION																							
1901 1HB01 1ABD56 1X4DB127 F6 WPSL,REACTOR,COOLANT DRN,TANK PRESS,M,M,M																							
1901 1HB01 1-RF-171-807 1X4DB127 E6 WPSL,REACTOR COOL,DRAIN TANK 1,PRESSURE,M,M,M																							
19502595 65 COP TRBB NEOP LNZ 1LV4525 1504 1AFDB 1TB1-TF/ Y N 05/04/96 05/04/96 09/26/95 16 05 F 50																							
WORK REQUESTED ... MOISTURE SEPARATOR DRAIN TANK 'D' TO HEATER DRAIN TANK 'B' HAS A SMALL PACKING LEAK. PLEASE INVESTIGATE AND REPAIR AS NECESSARY.																							
FOREMAN COMMENTS: "																							
WORK INSTRUCTIONS: ADJUST VALVE PACKING ON VALVE 1LV4525 PER 25036-C. I&C TO SET-UP VALVE PER 22285-C. MAINTAIN ZONE IV HOUSEKEEPING.																							
REPACK VALVE PER 25036-C.																							
MPL/TAG .....																							
RXTRIP/ILRT 1LV4525																							
CLEARANCE ..:																							
CLEAR 0 STA MPL/TAG SYS FEG LOCATION P&ID OPS DESCRIPTION																							
1504 1AFDB 1TB1-TF/T17 1X4DB163-4 FW HTR DRN,MSDT D DRAIN,TO HEATER DRAIN TANK																							
1LV4525 1 1LV4525 1504 1AFDB 1X4DB163-4 1TB1-TF/T17 FW HTR DRN,MSDT D DRAIN,TO HEA																							
19502938 65 OHP 1ACB ICOP WMO 11627CSCP1PR1 1627 RASB H N 05/04/96 05/04/96 08/08/00 16 05 F 50																							
WORK REQUESTED ... REMOVE TMP MOD 95-V17046 TO CHANGE SOFTWARE CODE IN MODULE VAGS.PAS																							
FOREMAN COMMENTS: FIELD WORK TO BE DONE BY JOE BRITT. WMO FORCED OUTAGE WMO																							
WORKORDERS LOCATED IN I&C FORCED OUTAGE FILE																							
WORK INSTRUCTIONS: REMOVE TMP MOD 95-V17046 TO CHANGE SOFTWARE CODE IN MODULE VAGS.PAS.																							
MPL/TAG .....																							
RXTRIP/ILRT 11627CSCP1PR1																							
CLEARANCE ..:																							
CLEAR 0 STA MPL/TAG SYS FEG LOCATION P&ID OPS DESCRIPTION																							
1627 RASB PRIMARY MIMICOMPUTER PROCESSOR																							
19505008 5A OHP TRBA ICOP JEL 11506R4001 1504 1PCAA 1TB1-TF/ W N 11/06/95 11/06/95 11/20/95 F 5025																							
WORK REQUESTED ... NUMEROUS MFP A HP TURBINE VIBRATION ALARMS WITH THE PUMP IN AUTO AT 6P PROXIMATELY 4925 RPM. INVESTIGATION REVEALED SPIKES IN MFP A SPEED CO INCURRANT WITH THE VIBRATION SPIKES. SPEED CONTINUED TO SPIKE AT A REDUCED FREQUENCY WITH THE MFP IN MANUAL ON THE WESTINGHOUSE CONTROLLER AT VARIOUS STEADY STATE SPEEDS BETWEEN 4925 & 5050 RPM. PUMP IS NOW IN																							



WMO NO.	ST	TYPE	TEAM	DISC	FORE	NUMBERS	MPL/TAG	SYS	FEG	LOCATION	IND	CLR	RWP	SCH	BEG	DATES	SCH	END	REQUIRED	P2	CODE	CONTROL	PRI
---------	----	------	------	------	------	---------	---------	-----	-----	----------	-----	-----	-----	-----	-----	-------	-----	-----	----------	----	------	---------	-----

THIS DID NOT SOLVE THE PROBLEM. PLEASE REPAIR DISPATCHER ALSO OBSERVED LEAK AT BOTH RTD ON TOP OF THIS BRG. ALSO OBSERVE LEAK AT OIL INLET FLANGE TO THIS BEARING. SUGGEST ATTEMPTING TO STOP LEAK BY INCREASING TORQUE. JBS 04/04/95 (PUMP OUTBOARD)  
OIL LEAK AT TURBINE IMBOARD BEARING JCP 11/2/95  
=RTD OIL LEAK  
OIL INLET FLANGE; MEOP - TORQUE FLANGE TO MAX PER MAINT B/T MANUAL.  
SEND WMO TO ICOP FOR INSTRUCTIONS ON RTD LEAK  
MAINT ZONE 7/ HOUSEKEEPING. WMC 5/6/95  
REWORK IMBOARD SEAL TO STOP OIL LEAK

FOREMAN COMMENTS:  
WORK INSTRUCTIONS:

MPL/TAG  
MPL/TAG  
2TE14475  
213054004  
2TE14474  
CLEARANCE  
CLEAR 0  
29508550

MPL/TAG	SYS	FEG	LOCATION	PaID	LOOP	OPS DESCRIPTION
2TE14475	1505	2CF00	2TB1-TG/T4	X40B		SGFP A OUTER THRUST BRG M
213054004	1505	2ADAD	2TB1-7E8S6	2X40B168-2	D4	STEAM GENERATOR FEED PUMP 'A'
2TE14474	1505	2ADNM	XSDS1M05	X40B	167-4	SGFP A OUTB JNL BRG LO DR

29501396 65 COP YRBA MEOP ALL 21326E4501P01 1326 2CEAA 2TB1- Y N 04/21/95 04/21/95 08/08/00 F 5028  
WORK REQUESTED ... STATOR COOLING PUMP A IS LEAKING OIL FROM THE MOTOR END OF THE PUMP BEARING SEAL AREA. INVESTIGATE AND REPAIR.  
WORK INSTRUCTIONS: TIGHTEN/REWORK AS REQUIRED TO STOP LEAK. DOCUMENT ALL WORK IN BLOCK 27.

MPL/TAG  
MPL/TAG  
21326E4501P01  
CLEARANCE  
CLEAR 0  
29508550

MPL/TAG	SYS	FEG	LOCATION	PaID	OPS DESCRIPTION	
21326E4501P01	1326	2CEAA	2TB1-	2X40B195-5	B4	GEN STATOR COOLANT PUMP A

29501450 65 COP YRBA MEOP JEL 216155A501T01 1615 2CHBA 2TB1- Y N 11/14/95 11/14/95 05/25/95 25 DS F 6028  
WORK REQUESTED ... 1. THERE IS A SMALL EMC FLUID LEAK AT THE CONNECTION TO THE B HIGH PRESSURE MANIFOLD. THIS IS THE MOST EASTERN VERTICAL PIPE ON TOP OF THE CONNECTION BLOCK LOCATED AT THE NW CORNER OF RESEVOIR. CONNECTION HAS A TACK WELDED RESTRAINT STRAP. (CONTINUED)

FOREMAN COMMENTS:  
WORK INSTRUCTIONS:  
2 GRIND LOCKING TAB ON THE TUBE SIDE TO PREVENT DAMAGING O-RINGS. TORQUE NUT TO MAX TORQUE PER 2X40A11-198. IF NUT WRENCHES OPS PRESSURIZE LINE AND VERIFY NO LEAKAGE. TACK WELD LOCKING TABS PER WPCS 095-0528

MPL/TAG  
MPL/TAG  
216155A501T01  
21615PIPE  
21615U4592  
21615A501P02  
CLEARANCE  
CLEAR 0  
29508550

MPL/TAG	SYS	FEG	LOCATION	PaID	OPS DESCRIPTION	
216155A501T01	1615	2CHBA	2TB1	2X40B194	B5	EMC HYDR FLUID RESERVOIR
21615PIPE	1615	ZVA2T0US		2X40B194		MISC 1615 PIPE
21615U4592	1615	TURB		2X40B194		EMC PUMP A DISCHARGE FILTER INLET ISOLATION V
21615A501P02	1615	2CHBA	2TB1-220	2X40B194	C4	EMC HYDR FLUID PMP B

29501502 65 COP YRBA MEOP WMO 21301K4081HP 1501 2ABAH 2TB5 N N 08/08/00 08/08/00 08/08/00 25 DS F 4028  
WORK REQUESTED ... HIGH PRESSURE TURBINE SHELL IS LEAKING AT THE MATING SURFACE ON THE GENERATOR END. LEAK IS ABOUT 4 OR 5 BOLTS ON EITHER SIDE OF SHAFT. LEAK IS SMALL AT THIS TIME. NEED TO TRY TO TIGHTEN DURING A TURBINE

WMO NO.	ST	TYPE	TEAM	DISC	FORE	NUMBERS	MPL/TAG	SYS	FEG	LOCATION	IND	CLR	RWP	SCH	BEG	DATES	SCH	END	REQUIRED	P2	CODE	CONTROL	PRI
---------	----	------	------	------	------	---------	---------	-----	-----	----------	-----	-----	-----	-----	-----	-------	-----	-----	----------	----	------	---------	-----

SHUTDOWN.  
FOREMAN COMMENTS:  
WORK INSTRUCTIONS: TIGHTEN AS DIRECTED BY GE REP. CJP 6/29/95

MPL/TAG  
MPL/TAG  
21301K4081HP  
CLEARANCE  
CLEAR 0  
29508226

MPL/TAG	SYS	FEG	LOCATION	PaID	OPS DESCRIPTION	
21301K4081HP	1501	2ABAH	2TB5	2X40B160-2	E4	HIGH PRESSURE TURBINE

29501525 65 COP YRBC MEOP WMC 21504295 1504 2AFBH 2TB5-BEH Y N 05/25/95 05/25/95 05/25/95 F 50  
WORK REQUESTED ... HTR 5B VALVE HAS PACKING LEAK  
21504295GIL IS VLV WITH PACKING LEAK  
ADD 21CL4285 EIL PER BLOCK 27: PACKING LEAK.

FOREMAN COMMENTS:  
WORK INSTRUCTIONS: 21504295GIL: REWORK VALVE PER 26140-C AND REPACK PER 25039-C  
21CL4285EIL: REPACK VALVE PER 25039-C  
21504295GIL: INSPECT STEM, REPLACE IF NECESSARY.

MPL/TAG  
MPL/TAG  
21504295  
21CL4285  
CLEARANCE  
CLEAR 0  
29508226

MPL/TAG	SYS	FEG	LOCATION	PaID	OPS DESCRIPTION	
21504295	1504	2AFBH	2TB5-BEH	2X40B163-4	B4	HTR 5B SHELL
21CL4285	1504	2AFBH	2TB5	2X40B163-4	B5	HTR 5B SHELL

29501557 65 COP YRBC MEOP WMO 2HV6022 1316 2ACAB 2TB2-T2/Y Y N 08/08/00 08/08/00 05/25/96 F 4038  
WORK REQUESTED ... UNIT 2, STOP VALVE, BEFORE SEAT DRAIN IS LEAKING BY TO THE CONDENSER.  
PLEASE INVESTIGATE AND REPAIR AS NECESSARY.

FOREMAN COMMENTS:  
WORK INSTRUCTIONS: SEE ATTACHED PACKAGE INSTRUCTION SHEET

MPL/TAG  
MPL/TAG  
2HV6022  
CLEARANCE  
CLEAR 0  
29508226

MPL/TAG	SYS	FEG	LOCATION	PaID	OPS DESCRIPTION	
2HV6022	1316	2ACAB	2TB2-T2/TD	LEV2X40B197	G2	TURB DRAINS, STOP VALVE 4, BEFORE SEAT, DRN TO C

29501561 65 COP YRBC MEOP WMO 2FE14249 1504 2AFBB XSDS1L05 Y N 08/08/00 08/08/00 08/08/00 F 4012  
WORK REQUESTED ... MSDT B TO HDT A FLOW ANNUBAR ROOT VALVE 2-1304-X4-744 IS LEAKING 50 DPM AT THE THREADED CONNECTION TO ANNUBAR. DOES NOT APPEAR THAT VALVE CAN BE TIGHTENED WITHOUT REMOVING ANNUBAR FROM PIPE  
==HAVE PACKAGE READY FOR FORCED OUTAGE OR MSR OUTAGE==  
REMOVE TUBING, REMOVE VALVE, CLEAN THREADS, APPLY SEALANT AND REINSTALL L. IF ANNUBAR HAS TO BE REMOVED TO PERFORM WORK, REMOVE AND REINSTALL PER MANUAL AX5AG14-68. (LADDER REQUIRED) (LOCATED AT 235' MEZZ ON WEST END TURB BLDG)

MPL/TAG  
MPL/TAG  
2FE14249  
21304X4744  
CLEARANCE  
CLEAR 0  
29508226

MPL/TAG	SYS	FEG	LOCATION	PaID	OPS DESCRIPTION	
2FE14249	1504	2AFBB	XSDS1L05	2X40B163-3		MS DRN TK B TO HTR DRN TK
21304X4744	1504	2AFBB	2TB1	2X40B163-3	D6	FW HTR DRMS, MSDT B DRN, TO HDT A, FT-14249 RT, N

29501589 65 COP YRBC MEOP WMC 21304X4591 1304 2AFBC 2TB2- Y N 08/08/00 08/08/00 08/08/00 F 4  
WORK REQUESTED ... LEAK REPAIR WAS INSTALLED BY WMO29501536 AND TEMP-MOD 95-V2050, DENOVE TEMP-MOD AND DENOVE OPIFACE VALVE TO OPIFACE VALVE

MWO NO. ST TYPE TEAM DISC FORE NUMBERS MPL/TAG SYS FEG LOCATION CLR RRP SCH BEG DATES SCH END REQUIRED P2 CODE CONTROL PRI  
RFL RFR

FOREMAN COMMENTS.:  
WORK INSTRUCTIONS: REPACK VALVE 21301X4886 PER 25059-C.  
MPL/TAG .....  
MPL/TAG 21301X4994 SYS FEG 1301 ZABCH LOCATION 2TB1 P&ID 2X4DB160-002 HS OPS DESCRIPTION MAIN STEAM, TO MSR A, P1-16604 AND, PT-6015 ROOT  
21301X4886 1301 ZABCH 2TB5 P&ID 2X4DB160-2 HS OPS DESCRIPTION MAIN STEAM, TO MSR A, PRESS TEST, POINT, MC, M, M  
CLEARANCE ..:  
CLEAR # STA MPL/TAG SYS FEG P&ID LOCATION OPS DESCRIPTION

29502351 6S COP 1&CB ICOP ALL 2TE6275 1301 ZABAG 2TB1 H W 09/25/95 09/25/95 09/30/95 F 50  
WORK REQUESTED ... STEAM GENERATOR OUTLET HEADER TEMPERATURE INDICATION IS READING LESS THAN 535 DEGREES AND ACTUAL TEMPERATURE IS ABOVE 540 DEGREES. THIS CAUSES INACCURATE INDICATION OF STEAM GEN TEMP, YIELDING PLANT DIAGNOSTICS IMPOSSIBLE. THE IPC POINTS ARE T2001 AND T2002. PLEASE INVESTIGATE AND REPAIR AS NECESSARY  
FOREMAN COMMENTS.:  
WORK INSTRUCTIONS: RER 95-0215 FORECAST FOR 10/31/95. WTG OUTAGE BECAUSE OF 2FV5200/5201 WILL BE AFFECTED WHEN PULLING OUT VLL CARD. \*\*\*FORCED OUTAGE\*\*\*  
REWORK/REPLACE AS REQUIRED TO RESTORE LOOP TO OPERATIONAL CONDITION. SEE C. CHASTAIN IF ADDITIONAL INFO IS REQUIRED. (HE HAS GRAPHS OF THE DEGRADED CONDITION OF TEMP INPUTS. MAINTAIN ZONE IV CLEANLINESS TLW 9-21-95)  
MPL/TAG .....  
MPL/TAG 2TE6275 SYS FEG 1301 ZABAG LOCATION 2TB1 P&ID 2X4DB160-001 OPS DESCRIPTION MAIN STM TO STOP VALVE  
2TE6280 1301 ZABDF 2TB1 P&ID 2X4DB160-001 OPS DESCRIPTION MAIN STM TO STOP VALVE  
2TR6275 1301 ZABAG 2CB164 P&ID 2X4DB160-1 G2 OPS DESCRIPTION MAIN STM TO STOP VALVE  
2160405PCG 1604 2SC01 2CB164- OPS DESCRIPTION BOP CONTROL PANEL 1  
2160405BCP 1604 2SC01 2CB164 OPS DESCRIPTION BOP CONTROL PANEL 2  
CLEARANCE ..:  
CLEAR # STA MPL/TAG SYS FEG P&ID LOCATION OPS DESCRIPTION

29502365 6D COP YRBB HEDP JLF 21305U4589 1305 ZADAD 2TB1 H 08/08/00 08/08/00 10/30/95 25 05 F 5025  
WORK REQUESTED ... ONE OR BOTH OF THESE VALVES (2-1305-U4-509 AND 2-1305-U4-590) ARE LEAKING BY THE SEAT INTO THE FLOOR DRAIN. INSULATION REMOVAL IS REQUIRED TO EVALUATE.  
MPL/TAG .....  
MPL/TAG 21305U4589 SYS FEG 1305 ZADAD LOCATION 2TB1 P&ID 2X4DB160-000 D4 OPS DESCRIPTION MFW,MFP A VENT, TO COND MISC, DRAIN TANK, MC, M, M  
21305U4590 1305 ZADAD 2TB1 P&ID 2X4DB160-2 D4 OPS DESCRIPTION MFW,MFP A VENT, TO MISC COND, DRAIN TANK, MC, M, M  
CLEARANCE ..:  
CLEAR # STA MPL/TAG SYS FEG P&ID LOCATION OPS DESCRIPTION

29502484 8E CNP SHP HEDP OPS 21V4259 1304 ZAF CJ 2TB2 Y/ Y W 12/02/95 12/02/95 10/30/95 F 50  
WORK REQUESTED ... 21V-4259 HAS A PACKING LEAK AND MAY HAVE A PIPING FLANGE LEAK. INSULATION WILL HAVE TO BE REMOVED TO INVESTIGATE.  
FOREMAN COMMENTS.:  
WORK INSTRUCTIONS: \*REPLACE FLANGE GASKETS AND REPACK  
ADJUST PACKING PER 25036-C. IF PACKING CONTINUES TO LEAK REPACK PER 25039-C. REMOVE INSULATION PER 20002-C AND INVESTIGATE POSSIBLE FLANGE LEAK.  
MAINTAIN ZONE IVHOUSEKEEPING CLASS "C" CLEANLINESS  
MPL/TAG .....  
MPL/TAG 21V4259 SYS FEG 1304 ZAF CJ LOCATION 2TB2 T/C-Y/6 P&ID 2X4DB163-7 OPS DESCRIPTION FW HTR DRMS, HTR 3C OUT, DRAIN TO HTR, 2C, ADV FO  
CLEARANCE ..:  
CLEAR # STA MPL/TAG SYS FEG P&ID LOCATION OPS DESCRIPTION

MWO NO. ST TYPE TEAM DISC FORE NUMBERS MPL/TAG SYS FEG LOCATION CLR RRP SCH BEG DATES SCH END REQUIRED P2 CODE CONTROL PRI  
RFL RFR

29502490 6S COP YRBB HEDP JLF 21304P4002 1304 ZAFBE 2TB4-TS/TF W H 08/08/00 08/08/00 08/08/00 25 05 F 4014  
WORK REQUESTED ... LOWER PIPE PLUG ON HGP B STUFFING BOX HAS A SMALL STEAM LEAK.  
WORK INSTRUCTIONS: SEAL WELD DRAIN PLUG. LHR 10/10/95  
MPL/TAG .....  
MPL/TAG 21304P4002 SYS FEG 1304 ZAFBE LOCATION 2TB4-TS/TF P&ID 2X4DB163-4 B5 OPS DESCRIPTION HEATED DRAIN PUMP B  
CLEARANCE ..:  
CLEAR # STA MPL/TAG SYS FEG P&ID LOCATION OPS DESCRIPTION


29502755 6S COP YRBB HEDP ALL 21304U4190 1304 ZAF CB 2TB2TF/74 Y W 12/02/95 12/02/95 12/04/95 25 05 F 50  
WORK REQUESTED ... VALVE IS LEAKING AROUND PIPE PLUG ON HINGE PIN ON NORTH SIDE OF VALVE  
INSULATION HAS BEEN REMOVED. SCAFFOLD WILL BE REQUIRED  
VALVE IS LOC ON SECOND FLOOR SOUTH SIDE OF CONDENSER UNDER HTR DRAIN TANK  
FOREMAN COMMENTS.:  
WORK INSTRUCTIONS: \*SEAL WELD PIPE PLUG  
REMOVE PIPE PLUG, CLEAN THREADS ON PLUG AND BODY THREADS. SEAL WELD PIPE PLUG PER WPCS 950970.  
MPL/TAG .....  
MPL/TAG 21304U4190 SYS FEG 1304 ZAF CB LOCATION 2TB2TF/74 P&ID 2X4DB163-4 E7 OPS DESCRIPTION FW HTR DRMS, MSDT C TO, HDY B LV-4522, INLET CHE  
CLEARANCE ..:  
CLEAR # STA MPL/TAG SYS FEG P&ID LOCATION OPS DESCRIPTION  
21500557 I MPL/TAG 21304U4190 SYS FEG 1304 ZAF CB P&ID 2X4DB163-4 E7 LOCATION 2TB2TF/74 OPS DESCRIPTION FW HTR DRMS, MSDT C TO, HDY B LV

29502757 6S COP 1&CB ICOP WLD 2PT10945 1206 ZBKMB 2ABB131- W Y 11/29/95 11/29/95 12/22/95 F  
WORK REQUESTED ... PRESSURE INDICATES 1.12 PSIG BELOW 2PT10942. THOUGH WITHIN TOLERANCE IT APPEARS THE INSTRUMENT MAY NEED RECALIBRATION. 2PT-10942 INDICATION IS IN LINE WITH CURRENT NARROW RANGE PRESSURE INDICATION. THIS IS A T ECH SPEC INDICATOR  
FOREMAN COMMENTS.:  
WORK INSTRUCTIONS: \*\*\*FORCED OUTAGE\*\*\*  
REWORK/RECALIBRATE LOOP 2P-10945 TO ENSURE LOOP REFLECTS CURRENT PLANT CONDITIONS. IF NECESSARY, REPLACE ALL DEFECTIVE COMPONENTS.  
WORK IN CONJUNCTION WITH SURVEILLANCE 24572-201 IF PERFORMED DURING REFUEL OUTAGE  
MPL/TAG .....  
MPL/TAG ILRT 2PT10945 SYS FEG 1206 ZBKMB LOCATION 2ABB131-5E19MS P&ID 2X4DB131 F7 OPS DESCRIPTION CONTAINMENT WIDE RANGE  
2160405PP2 1604 2SC02 2CB164- OPS DESCRIPTION BOP PROTECTION CH 2 PANEL  
CLEARANCE ..:  
CLEAR # STA MPL/TAG SYS FEG P&ID LOCATION OPS DESCRIPTION

29502894 6D COP YRBA HEDP JLF 21301K4001LPC 1301 ZABCL 2TB3- H 08/08/00 08/08/00 08/08/00 25 05 F 4028  
WORK REQUESTED ... THERE IS A SMALL OIL LEAK ON THE SOUTH SIDE OF THE SHAFT ON THE WEST END OF LOW PRESSURE TURBINE "C". LEAK IS ON BOLTED FLANGE ON COVER, 6TH BOLT UP FROM DECKING.  
MPL/TAG .....  
MPL/TAG 21301K4001LPC SYS FEG 1301 ZABCL LOCATION 2TB3- P&ID 2X4DB160-2 E7 OPS DESCRIPTION LOW PRESSURE TURBINE C  
CLEARANCE ..:  
CLEAR # STA MPL/TAG SYS FEG P&ID LOCATION OPS DESCRIPTION




# RER Average Age







# Open DCRs



# Open MDCs



## UNIT 1 DIESEL GENERATOR SAFETY SYSTEM PERFORMANCE INDICATOR



$$SSPI = \frac{\text{known unavailable hours} + \text{estimated unavailable hours}}{\text{hours system required} \times \text{number of trains}}$$

### DEFINITION:

The safety system performance indicator is defined as the sum of the unavailabilities, due to all causes, of the emergency generator during a time period. For emergency generators unavailability is recorded only when the emergency generator is unavailable to produce emergency AC power.


Unavailability is defined as that fraction of time that a generator is unable to perform its intended function when it is required to be available for service. Emergency generators are considered to be required at all times.

### YEAR TO DATE VALUES

DIESEL	1992	1993	1994	1995	1995 3 YR.
1A	0.0085	0.0000	0.0022	0.0063	0.0028
1B	0.0000	0.0000	0.0000	0.0016	0.0005



## UNIT 2 DIESEL GENERATOR SAFETY SYSTEM PERFORMANCE INDICATOR



$$SSPI = \frac{\text{known unavailable hours} + \text{estimated unavailable hours}}{\text{hours system required} \times \text{number of trains}}$$

### DEFINITION:


The safety system performance indicator is defined as the sum of the unavailabilities, due to all causes, of the emergency generator during a time period. For emergency generators unavailability is recorded only when the emergency generator is unavailable to produce emergency AC power.

Unavailability is defined as that fraction of time that a generator is unable to perform its intended function when it is required to be available for service. Emergency generators are considered to be required at all times.

### YEAR TO DATE VALUES

DIESEL	1992	1993	1994	1995	1995 3 YR
2A	0.0056	0.0026	0.0000	0.0402	0.0143
2B	0.0014	0.0038	0.0001	0.0009	0.0016

## HIGH HEAD SAFETY INJECTION SAFETY SYSTEM PERFORMANCE INDICATOR



$$SSPI = \frac{[(\text{known unavailable hours} + \text{estimated unavailable hours})]}{(\text{hours system required} \times \text{number of trains})}$$

### DEFINITION:

The safety system performance indicator is defined as the sum of the unavailabilities, due to all causes, of the components in the system during a time period, divided by the number of trains in the system.


Unavailability is defined as that fraction of time that a component is unable to perform its intended function when it is required to be available for service. High head safety injection is considered to be required when the reactor is critical.

The high head safety injection system has four trains, 2 centrifugal charging and 2 safety injection. Additionally RHR unavailability counts on a component basis but not as a separate train.

### YEAR TO DATE VALUES

UNIT	1992	1993	1994	1995	1995 3 YR
1	0.0008	0.0029	0.0076	0.0004	0.0034
2	0.0006	0.0015	0.0007	0.0019	0.0014

## AUXILIARY FEEDWATER SAFETY SYSTEM PERFORMANCE INDICATOR



$$SSPI = \frac{(\text{known unavailable hours} + \text{estimated unavailable hours})}{(\text{hours system required} \times \text{number of trains})}$$

### DEFINITION:

The safety system performance indicator is defined as the sum of the unavailabilities, due to all causes, of the components in the system during a time period, divided by the number of trains in the system.

Unavailability is defined as that fraction of time that a component is unable to perform its intended function when it is required to be available for service. Auxiliary feedwater is considered to be required when the reactor is critical.

The auxiliary feedwater system has three trains, 2 motor driven pumps and 1 turbine driven.


### YEAR TO DATE VALUES

UNIT	1992	1993	1994	1995	1995 3 YR
1	0.0285	0.0009	0.0013	0.0006	0.0009
2	0.0177	0.0057	0.0124	0.0003	0.0062

FIGURE 4


UNIT 1 MONTHLY GROSS HEAT RATE

CYCLE 6 BASIS



UNIT 1 THERMAL PERFORMANCE INDICATOR

CYCLE 6 BASIS




$$TPI = \frac{\text{Design Gross Heat Rate (corrected)}}{\text{Adjusted Actual Gross Heat Rate}} \times 100$$

FIGURE 5


UNIT 2 MONTHLY GROSS HEAT RATE

CYCLE 5 BASIS



UNIT 2 THERMAL PERFORMANCE INDICATOR

CYCLE 5 BASIS



$$TPI = \frac{\text{Design Gross Heat Rate (corrected)}}{\text{Adjusted Actual Gross Heat Rate}} \times 100$$

NOTE: There are no March values for heat rate or Thermal Performance Indicator since the unit did not operate at above 80% power during the month.

## Improved Tech Specs Status Report


Report Date: Thursday, January 11, 1996

Responsible Management	Responsible Department	Procedure Revision Status		
		Planned for 01/10	Complete on 01/10	Total to revise
<b>Plant Operations</b>	Chemistry/HP	<b>29</b>	<b>29</b>	<b>29</b>
	Maintenance	<b>390</b>	<b>397</b>	<b>669</b>
	Operations	<b>234</b>	<b>225</b>	<b>580</b>
	Outage/Plan	<b>0</b>	<b>0</b>	<b>0</b>
<b>Subtotal</b>		<b>653</b>	<b>651</b>	<b>1278</b>

<b>Plant Support</b>	Eng Support	<b>37</b>	<b>38</b>	<b>56</b>
	Plant Mods	<b>0</b>	<b>0</b>	<b>0</b>
	Plant Admin	<b>0</b>	<b>0</b>	<b>0</b>
	Security	<b>0</b>	<b>0</b>	<b>0</b>
	NSAC	<b>5</b>	<b>5</b>	<b>16</b>
	Training	<b>0</b>	<b>0</b>	<b>0</b>
<b>Subtotal</b>		<b>42</b>	<b>43</b>	<b>72</b>

<b>Other</b>	ISEG/SAER	<b>0/0</b>	<b>0/0</b>	<b>0/0</b>
	Management	<b>0</b>	<b>0</b>	<b>0</b>
	Corporate	<b>0</b>	<b>0</b>	<b>2</b>
<b>Total</b>		<b>695</b>	<b>694</b>	<b>1352</b>


# PLANT VOGTLE PERSONNEL ERROR LERs







■ LERs YTD

NOTE: UNIT 2 OPERATION BEGAN IN 1989  
(LERPE)

# CONTROL ROOM INSTRUMENTS & ANNUNCIATORS WORK EFFICIENCY INDICATORS




 UNIT 1 LIT ANNUN  
 UNIT 1 CR INST OOS

 UNIT 2 LIT ANNUN  
 UNIT 2 CR INST OOS



# PLANT VOGTLE PERSONNEL ERROR LERs



■ LERs YTD

NOTE: UNIT 2 OPERATION BEGAN IN 1989  
(LERPE)

# Management Attention Items

Report Date: 01/09/96

Responsible Management	Responsible Department	Open Item/ Commitment Tracking Program		Improved Tech Specs Open Items Status		Deficiency Card Status	
		Late on 01/08	Due on 01/15	Due on 12/01	Closed 01/08	Late on 01/08	Cards Open
<b>Plant Operations</b>	Chemistry/HP	0	2	0	41	0	0
	Maintenance	6	19	148	64	0	6
	Operations	7	12	312	5	0	1
	Outage/Plan	1	4	0	3	0	2
	<b>Subtotal</b>		<b>14</b>	<b>37</b>	<b>460</b>	<b>113</b>	<b>0</b>
<b>Plant Support</b>	Eng Support	2	12	110	20	0	6
	Plant Mods	0	3	0	0	0	0
	Plant Admin	1	4	0	0	0	0
	Security	1	1	0	0	0	0
	NSAC	0	2	10	6	0	32
	Training	4	6	0	0	0	0
<b>Subtotal</b>		<b>8</b>	<b>28</b>	<b>110</b>	<b>26</b>	<b>0</b>	<b>38</b>
<b>Other</b>	ISEG/SAER	0/0	2/1	0/0	0/0	0/0	0/0
	Pit Crew	0	0	0	0	0	0
	Management	0	1	0	0	0	0
	Corporate	4	10	2	0	0	0
<b>Total</b>		<b>26</b>	<b>79</b>	<b>572</b>	<b>139</b>	<b>0</b>	<b>47</b>

Distribution: JBB  
WFK  
JTG  
MS  
JLG  
file

**A.W. VOGTLE**  
OUTAGE RISK MANAGEMENT AND ASSESSMENT  
Safety Function Status Report

Outage: 1R6REV0 : 1R6 REFUELING OUTAGE

Model: 1R6B0111 : VEGP 1R6 pre-outage Model

