



**January 23, 1996**  
**United States Nuclear Regulatory Commission**  
**Washington, D.C. 20555**

**Attention:** Document Control Desk

**Subject:** LaSalle County Station, Units 1 and 2  
Surveillance Requirements for Static-O-Ring (SOR) Differential Pressure  
Switches. System Codes: RH(E12), LP(E21), HP(E22), LD(E31)

**Reference:** 1. Letter dated April 1, 1987, from R. M. Bernero (NRR) to D. L.  
Farrar transmitting a Safety Evaluation Report (SER) for supporting  
the continued use of SOR, Inc., differential pressure switches at LaSalle.  
NRC Docket Numbers 50-373 and 50-374.

**Reference:** 2. Letter dated August 2, 1995 from W. D. Reckley (NRR) to D. L.  
Farrar transmitting the Issuance of Technical Specification  
Amendments (TAC NOS. M91124 AND M91125)  
NRC Docket Numbers 50-373 and 50-374.

Enclosed is ComEd's supplemental response to the Safety Evaluation Report (SER)  
that was transmitted with the Reference 1 letter.

The surveillance requirements listed in the SER required each SOR DP switch to be  
functionally tested or calibrated each month when the switch was required to be operable.  
When the NRC accepted our long term action plan for continued use of SOR DP switches and  
issued the referenced SER, all previous Technical Specification surveillance requirements  
were replaced and superseded by the surveillance requirements specified in that document.  
These surveillance frequencies are no longer the same frequency requirements as currently  
specified in the LaSalle Technical Specifications.

The Technical Specification Amendments for Surveillance Test Intervals/Allowed Outage  
Times (STI/AOT), transmitted in the Reference 2 letter, decreased the surveillance  
frequencies of these SOR DP switches. LaSalle County Station will now be performing the  
surveillances of the SOR DP switches in accordance with the Technical Specification  
Amendments and also will no longer be documenting surveillance failures of these switches in  
the LaSalle Monthly Performance Report.

9601290194 960123  
PDR ADOCK 05000373  
P PDR

*Acc 1/30*

If there are any questions or comments concerning this letter, please refer them to me at (815) 357-6761, extension 3600.

Respectfully,



R. E. Querio  
Site Vice President  
LaSalle County Station

cc: H. J. Miller, Regional Administrator, Region III  
M.D. Lynch, Project Manager, NRR  
H. J. Simons, Acting Senior Resident Inspector, LaSalle  
D. L. Farrar, Nuclear Regulatory Services Manager, NORS  
Central file