



Public Service

Public Service
Company of Colorado

16805 WCR 19 1/2, Platteville, CO 80651

June 12, 1992
Fort St. Vrain
Unit No. 1
P-92230

U. S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, D. C. 20555

Docket No. 50-267

SUBJECT: NPDES Non-Compliance Report

Gentlemen:

Enclosed is a copy of the Fort St. Vrain NPDES Non-Compliance Report dated May 14, 1992, which was sent to the Colorado Department of Health and the U.S. Environmental Protection Agency on May 19, 1992. A copy of this report is being sent in accordance with Appendix B of the Fort St. Vrain Technical Specifications, "Environmental Protection Plan", Section 3.2.

If you have any questions regarding this matter, please contact Mr. M. H. Holmes at (303) 620-1701.

Sincerely,

Donald W. Warembourg
Donald W. Warembourg
Manager, Nuclear Operations

DWW/JMG/lmg

Enclosure

9206240429 920612
PDR ADOCK 05000267
S PDR

ADD: NRP./DET/ES6B

ADD
Ltr. Encl.
1 1


P-92230
June 12, 1992
Page 2

cc: Regional Administrator, Region IV

Director, Division of Industrial and Medical Nuclear Safety
Office of Nuclear Material Safety and Safeguards
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

Robert M. Quillin, Director
Radiation Control Division
Colorado Department of Health
4210 East 11th Avenue
Denver, CO 80220

J. B. Baird
Senior Resident Inspector
Fort St. Vrain



Public Service
Company of Colorado
P.O. Box 540
Denver, CO 80201-0840

May 19, 1992

Ms. Anne Ihlenfeldt
Water Quality Control Division
Monitoring & Enforcement Section
Colorado Department of Health
4210 East 11th Avenue
Denver, CO 80220

RE: Fort St. Vrain Non-Compliance Report

Dear Anne:

Attached please find a non-compliance report for the Public Service Company of Colorado Fort St. Vrain Station. The non-compliance is in regard to the iron exceedance reported to you on May 13, 1992.

Please feel free to contact me at 294-2810 with any questions in this regard.

Sincerely,

A handwritten signature in cursive script that reads "Peter J. Cohlma".

Peter J. Cohlma
Unit Manager, Environmental Programs

PJC:tc

Attachment

cc: U.S. EPA
George Vonesh
Nuclear Licensing ✓

NPDES DISCHARGE PERMIT NONCOMPLIANCE REPORTING FORM

Date: 5/14/92

Applicable Permit No.: CO-0001121

Discharge No.: 01SB

I. GENERAL

A. Company: Public Service Company of Colorado

Mailing Address: 16805 19¹/₂ Weld County Road

Plant Name: Fort St. Vrain Station

Plant Location: Platteville, CO County: Weld

II. NONCOMPLIANCE REPORT

A. Description and Cause of Noncompliance:

One iron sample out of four on May 5-6, 1992, was out of compliance. Two analyses were performed on the 8:30 a.m. sample (5/6). Data revealed 0.98 mg/l iron but a duplicate analysis did not fall within our acceptable standard deviation. The analysis was therefore thrown out.

11:55 p.m. 5/5/92	0.526 mg/l iron	11:10 a.m. 5/6/92	0.456 mg/l iron
8:30 a.m. 5/6/92	1.38 mg/l iron	5:15 p.m. 5/6/92	0.506 mg/l iron

B. Noncompliance Period:

Started: 8:30 A.M. P.M. 5/6/92 Date

Ended: 11:10 A.M. P.M. 5/6/92 Date

C. Action Taken to Reduce, Eliminate, Prevent:

The iron sample integrity is questionable. However, data reveal the iron to have been out of compliance for a very short time. The Fort St. Vrain system is being monitored closely and analytical procedures are being reviewed.

D. Person Initiating Report: Peter J. Cohlma - Unit Manager, Environmental Programs

Signature: Peter J. Cohlma

E. Water Quality Control Division Notification Requirements:

Telephone (24 hrs.): 5/13/92 Date Ms. Anne Ihlenfeldt - CWQCD Notified

Written (5 days): 5/18/92 Date Ms. Anne Ihlenfeldt - CWQCD

SUBMIT REPORT TO:

Ms. Anne Ihlenfeldt
Colorado Department of Health
Water Quality Control Division
Monitoring & Enforcement Section
4210 East 11th Avenue
Denver, Colorado 80220

Regional Administrator
U.S. Environmental Protection Agency
One Denver Place, Suite 500
999 18th Street SWM-C
Denver, Colorado 80202-2405
Attn: Enforcement - Permit Program

Virginia Electric & Power
Company

2

JUN 08 1982

cc w/encl:

E. W. Harrell
Vice President - Nuclear Services
Virginia Electric & Power Company
5000 Dominion Boulevard
Glen Allen, VA 23060

J. P. O'Hanlon
Vice President - Nuclear Operations
Virginia Electric & Power Company
5000 Dominion Boulevard
Glen Allen, VA 23060

M. R. Kansler
Station Manager
Surry Power Station
P. O. Box 315
Surry, VA 23883

M. L. Bowling, Jr., Manager
Nuclear Licensing
Virginia Electric & Power Company
5000 Dominion Boulevard
Glen Allen, VA 23060

Sherlock Holmes, Chairman
Board of Supervisors of Surry County
Surry County Courthouse
Surry, VA 23683

Dr. W. T. Lough
Virginia State Corporation Commission
Division of Energy Regulation
P. O. Box 1197
Richmond, VA 23209

Michael W. Maupin
Hunton and Williams
P. O. Box 1535
Richmond, VA 23212

C. M. G. Buttery, M.D., M.P.H.
State Health Commissioner
Office of the Commissioner
Virginia Department of Health
P. O. Box 2448
Richmond, VA 23218

cc w/encl cont'd: See page 3