



UNITED STATES
NUCLEAR REGULATORY COMMISSION

REGION IV

611 RYAN PLAZA DRIVE, SUITE 400
ARLINGTON, TEXAS 76011-8064

JAN 23 1996

Union Electric Company
ATTN: Donald F. Schnell, Senior Vice
President - Nuclear
P.O. Box 149
St. Louis, Missouri 63166

SUBJECT: CHANGES TO THE CALLAWAY PLANT RADIOLOGICAL EMERGENCY RESPONSE PLAN


We have reviewed your letter dated July 5, 1995, and Change Notices dated September 18 (two) and October 13, 1995, and the enclosed changes to the Callaway Plant Radiological Emergency Response Plan, Revision 19 and Change Notices 95-02, 95-03, and 95-04, respectively. The revisions were submitted pursuant to 10 CFR 50.54(q). Revision 19 incorporated the following changes: (1) the threshold for emergency operations facility activation was changed from the site emergency (utility term) to the alert classification level, (2) reference to the operations support center/area was deleted due to the facility's collocation with the technical support center, (3) the emergency response organization was changed to support the combined operations support/technical support center and the merging of the public information and emergency operations facility emergency organizations, (4) the locations of the joint public information center and backup emergency operations facility were changed, (5) the letters of agreement review dates were updated, and (6) editorial changes were made to eliminate unnecessary detail and internal references, and to keep the plan current. Change Notice 95-02 modified the reference/information concerning emergency worker exposure limits. Change Notice 95-03 incorporated editorial changes for consistency with Revision 19. Change Notice 95-04 deleted reference to the construction siren.

Based on our review, we determined that the changes are acceptable and do not appear to degrade the effectiveness of your emergency planning at Callaway Plant. The results of our review were discussed with Mr. John Neudecker on January 9, 1996. Mr. Neudecker agreed to add the following information to the next revision to the emergency plan: (1) identify the non-delegable responsibilities of the recovery manager, (2) expand the description of the technical support center functions, and (3) identify the Notification and Coordination Line telephone locations. Mr. Neudecker also agreed to consider whether emergency response facility floor plans could be reinstated with a reduced level of detail without creating an updating burden.

9601290342 960123
PDR ADOCK 05000483
F PDR

Should you have any questions concerning this letter, please contact Ms. Gail M. Good of my staff at (817) 860-8215.

Sincerely,


Thomas P. Gwynn, Director
Division of Reactor Safety

Docket: 50-483
License: NPF-30

cc:
Professional Nuclear Consulting Inc.
19041 Raines Drive
Derwood, Maryland 20855

Shaw, Pittman, Potts & Trowbridge
ATTN: Gerald Charnoff, Esq.
Thomas A. Baxter, Esq.
2300 N. Street, N.W.
Washington, D.C. 20037

Union Electric Company
ATTN: H. D. Bono, Supervising
Engineer, Site Licensing
P.O. Box 620
Fulton, Missouri 65251

Union Electric Company
ATTN: G. L. Randolph, Vice President
Nuclear Operations
P.O. Box 620
Fulton, Missouri 65251

Union Electric Company
ATTN: J. V. Laux, Manager
Quality Assurance
P.O. Box 620
Fulton, Missouri 65251

Missouri Public Service Commission
ATTN: Manager - Electric Department
301 W. High
P.O. Box 360
Jefferson City, Missouri 65102

Ronald A. Kucera, Deputy Director
Department of Natural Resources
P.O. Box 176
Jefferson City, Missouri 65102

Wolf Creek Nuclear Operating Corporation
ATTN: Neil S. Carns, President and
Chief Executive Officer
P.O. Box 411
Burlington, Kansas 66839

Board of Directors Coalition
for the Environment
ATTN: Dan I. Bolef, President
Kay Drey, Representative
6267 Delmar Boulevard
University City, Missouri 65130

Federal Emergency Management Agency
ATTN: Robert G. Bissell
Region VII
2323 Grand Blvd., Suite 900
Kansas City, MO 64108-2670

bcc to DMB (IE35)

bcc distrib. by RIV:

L. J. Callan
Branch Chief (DRP/B)
Project Engineer (DRP/B)
Branch Chief (DRP/TSS)
MIS System

Resident Inspector
DRS-PSB
Leah Tremper (OC/LFDCB, MS: TWFN 9E10)
RIV File
T. Essig (NRR/PERB)

DRS AIs 95-014E and 95-022E

DOCUMENT NAME: G:\DRSLTRS\CWR19LTR.GMG

To receive copy of document, indicate in box: "C" = Copy without enclosures "E" = Copy with enclosures "N" = No copy

SEPA:PSB	E	C:PSB	D:DRS				
GMGood:cg	Gib	BMurray	TPGwynn				
01/22/96		01/22/96	01/23/96				

OFFICIAL RECORD COPY

bcc to DMB (IE35) *1/0*

bcc distrib. by RIV:

L. J. Callan
Branch Chief (DRP/B)
Project Engineer (DRP/B)
Branch Chief (DRP/TSS)
MIS System

Resident Inspector
DRS-PSB
Leah Tremper (OC/LFDCB, MS: TWFN 9E10)
RIV File
T. Essig (NRR/PERB)

DRS AIs 95-014E and 95-022E

DOCUMENT NAME: G:\DRSLTRS\CWR19LTR.GMG

To receive copy of document, indicate in box: "C" = Copy without enclosures "E" = Copy with enclosures "N" = No copy

SEPA:PSB	<input checked="" type="checkbox"/>	C:PSB	<input checked="" type="checkbox"/>	D:DRS	<input checked="" type="checkbox"/>				
GMGood:cg	<i>6/16</i>	BMurray	<i>1/0</i>	TPGwynn	<i>1/0</i>				
01/22/96		01/22/96		01/22/96					

OFFICIAL RECORD COPY

290058