

JC

January 18, 1996

Mr. E. Kraft, Site Vice President
Quad Cities Station
Commonwealth Edison Company
22710 206th Avenue North
Cordova, IL 61242

SUBJECT: NRC INTEGRATED INSPECTION REPORT NOS. 50-254/95009 and
50-265/95009

Dear Mr. Kraft:

From October 19 through December 8, 1995, C. Miller and others of this office, and R. Ganser of the Illinois Department of Nuclear Safety conducted an inspection of your facility. This inspection included a review of authorized activities for your Quad Cities Nuclear Power Station facility. At the conclusion of the inspection, we discussed the findings with those members of your staff identified in the enclosed report.

The areas examined during the inspection are identified in the report. Within these areas, the inspection consisted of a selective examination of procedures and representative records, interviews with personnel, and observation of activities in progress. Adverse performance and material condition problems were identified during testing of the Unit 2 high pressure coolant injection (HPCI) and standby diesel generator (SBDG) systems. We are concerned with the lack of depth in the initial root cause assessments and the plans for long term corrective actions for these systems.

In accordance with 10 CFR 2.790 of the NRCs "Rules of Practice," a copy of this letter and its enclosures will be placed in the NRC Public Document Room.

Sincerely,

Original Signed by P. L. Hiland

Patrick L. Hiland, Chief
Reactor Projects Branch 1

Docket Nos. 50-254, 50-265
License Nos. DPR-29, DPR-30

Enclosure: Inspection Report
No. 50-254/95009(DRP);
No. 50-265/95009(DRP)

9601290409 960118
PDR ADOCK 05000254
G PDR

IEO
11

cc w/encl: J. C. Brons, Vice President,
 Nuclear Support
 J. S. Perry, Vice President, BWR Operations
 L. W. Pearce, Station Manager
 N. Chrissotimos, Regulatory Assurance
 Supervisor
 D. Farrar, Nuclear Regulatory
 Services Manager
 Richard Hubbard
 Nathan Schloss, Economist
 Office of the Attorney General
 State Liaison Officer
 Chairman, Illinois Commerce
 Commission
 J. R. Bull, Vice President, General &
 Transmission, MidAmerican Energy Company

Distribution:

Docket File w/encl
 PUBLIC IE-01 w/encl
 OC/LFDCB w/encl
 SRI Quad Cities, Dresden,
 LaSalle w/encl

Project Manager, NRR w/encl
 DRP w/encl
 RIII PRR w/encl
 IPAS (E-Mail) w/encl
 RMB/FEES w/o encl

DOCUMENT NAME: R:\INSPRPTS\POWERS\QUAD\QUA95009.DRP

To receive a copy of this document, indicate in the box "C" = Copy without attach/encl "E" = Copy with attach/encl "N" = No copy

OFFICE	RIII	<input checked="" type="checkbox"/>	RIII		RIII	<input checked="" type="checkbox"/>	RIII	<input checked="" type="checkbox"/>
NAME	Hopkins/co <i>JA</i>		Creed (Section 4.1) <i>JA</i>		Caniano (Section 4.2) <i>JA</i>		Hiland <i>JA</i>	
DATE	1/18/96		1/18/96		1/16/96		1/18/96	

OFFICIAL RECORD COPY