



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
OFFICE OF INVESTIGATIONS FIELD OFFICE, REGION III  
799 ROOSEVELT ROAD  
GLEN ELLYN, ILLINOIS 60137

June 25, 1992

MEMORANDUM FOR: Kent E. Walker, Chairman, TSI Investigative Task Force  
FROM: Richard C. Paul, OI Senior Investigator, TSI Investigative  
Task Force Member *Richard C. Paul*  
Joseph M. Ulie, Reactor Inspector, TSI Investigative  
Task Force Member *Joseph M. Ulie*  
SUBJECT: TECHNICAL INFORMATION RELATED TO CPSES THERMO-LAG  
INSTALLATION

In a telephone discussion of June 25, 1992, the following information was received from OI-91-05 that relates to the ongoing Thermo-Lag installation at Unit 2 of CPSES:

- The acceptance criteria for the corner gap width of the Thermo-Lag fire barrier envelopes is 1/4 inch on installations ongoing at Unit 2.
- The acceptance criteria for these corner gaps at Unit 1 was one inch.
- The tested gap width used at Omega Point in the recent testing (June 1992) is .030 inch.

Since CPSES plans to utilize the Omega Point tests as qualification tests, we are recommending this information be provided to NRR because of the potential discrepancies.

9208280140XA

June 30, 1992

LOCATION HAS CHANGED

MEMORANDUM FOR: Ashok C. Thadani, Director  
 Division of Systems Technology

FROM: Conrad E. McCracken, Chief  
 Plant Systems Branch

SUBJECT: FORTHCOMING MEETING WITH NUCLEAR MANAGEMENT  
 AND RESOURCES COUNCEL (NUMARC)

DATE & TIME: Tuesday, July 7, 1992  
 9:30 a.m. - 12:30 p.m.

LOCATION: Crowne Plaza  
 Plaza III Ballroom  
 1750 Rockville Pike  
 Rockville, MD

PURPOSE: To discuss Thermo-Lag fire barrier  
 issues and the proposed generic letter

\*PARTICIPANTS

<u>NRC</u>	<u>NUMARC</u>
A. Thadani	A. Marion
G. Holahan	(et. al.)
C. McCracken	
R. Architzel	
P. Madden	
P. Gill	

Original signed by

Conrad E. McCracken, Chief  
 Plant Systems Branch  
 Division of Systems Technology

cc: See next page

\*Meetings between NRC technical staff and applicants or licensees are open for interested members of the public, petitioners, intervenors, or other parties to attend as observers pursuant to "Open Meeting Statement of NRC Staff Policy," 43 Federal Register 28058, 6/28/78.

RETURN TO REGULATORY CENTRAL FILES

9207060057 920630  
 PDR REVOP ERONUMRC  
 PDR

2222  
 see attached distributed  
 4/2/9