NRC FOT (9/83)

U.S. NUCLEAR REGULATORY COMMISSION
APPROVED OMB NO. 3150-0104
EXPLOSE: 8/21/85

•								LICE	NSEE	EVEN	IT RE	PORT	(L	ER)			RES			3150-01	
PACILITY NAME (1)														0	OCKET	NUMB	ER (2))	PA	GE (3)		
SAN ONOFRE NUCLEAR GENERATING STATION, UNIT 2													0	1510	101	013	16 1	1 0	F U II			
TITLE (4)		ILL	1400	LLA	, uL	HENNII	THU.	JIMIL	014,	11421 2	-		-			- 10	1010	1-1	0 10	10 11	1.10	101
		co	NTR	OI F	МООМ	ISOLA	TIO	N SYS	TEM A	CTHAT	ZIONS											
-	T DA		-	1		RNUMBE			-	RT DA		T	7	-	OTHE	RFAC	ILITIE	SIN	VOLV	ED ()	
MONTH DAY			EAR	SEQ.			REV.				YEAR	PACIL	PACILITY NAMES							DOCKET NUMBER(S)		
MUNIN	UAT	+	1		-	NUMBER	-	NUMBER		-	1	SONGS				S Un	Unit 3			5 10	0 10 1	3 16 12
				188								0000			0 011			-		-1-1	10 1-	
810	1 11	8	14	814		0 14 17	-	010	019	017	814								01	5 10	0101	1.1
-		1-	+			RT IS SUB!	MITTI		1010	1 4 1	10	-	OF 1	e cr	R &: (Check	one or	more	of th	ne follo	owing)	(11)
MODE (9)					20.402(b)				20.405(c)			1 57	X 50.73(a)(2)(iv)					73.71(b)				
POWER			-		20.405(a)(1)(i)				50.36(c)(1)				-	50.73(a)(2)(v)				73.71(c)				
LEVE (10)	1 10 10		20.405(a)(1)(ii)				50.36(c)(2) 50.73(a)(2)(i) 50.73(a)(2)(ii)				50.73(a)(2)(vii) 50.73(a)(2)(viii)(A)					OTHER (Specify in Abstract below and in Text, NRC Form 366A)						
					20.405(a)(1)(iii) 20.405(a)(1)(iv))							
											50.73(a)(2)(viii)(B)					-						
				20.405(a)(1)(v)					50.73(a)(2)(iii)				50.73(a)(2)(×)					113				
		-						LICE	NSEE C	ONTAC	TFOR	THIS LE	R	12)								
NAME																		TE	LEPH	ONE	NUMBE	R
													AREA CODE									
		J	. G	. HA	YNE	S, STA	TIO	N MAN	AGER								711	14	4 1	9 2	- 7	7 10 10
					сом	PLETE ON	E LI	NE FOR	EACH CO	MPONEN	T FAIL	URE DES	SCRI	BED	IN THE	S REPO	ORT (13	3)				
AUSE	STEM	cor	PONE	ENT		UPAC-		RTABLE			CAUSE	SYSTEM	ce	COMPONENT		MANUFAC- TURER			PORTA			
	1		1		1	11						,			1	1	1.1	T				
		-		1									-	1		-	1	+	-			
	1		1		1							1		L			11					
				,	SUPPL	LEMENTA	LR	EPORT	EXPECT	ED (14)										HTHO	DAY	YEAR
YE	s (If	yes, c	ompl	ete EX	PECTE	ED		X	NO							SU	SUBMISSION DATE (15)			1		1

Abstract (Limit to 1400 spaces, i.e., approximately fifteen single-space typewritten lines) (16)

On August 11, 1984, at 1141 and 1144, with both Units 2 and 3 in Mode 1 at 100% power, the Control Room Isolation System (CRIS) (EIIS System Code VA) Train 'A' spuriously actuated apparently from noise spikes on Control Room Airborne Radiation Monitor 2/3 RE-7824 (EIIS Component Code RIT). Also on August 11, 1984, at 1302 and again at 2242, CRIS Train 'B' spuriously activated from apparent noise spikes on Control Room Airborne Radiation Monitor 2/3 RE-7825. In each instance the Control Room Emergency Air Cleanup System (CREACUS) (EIIS System Code VI) was already actuated due to a normal chiller being out of service. Operators used air grab samples to verify that actual Control Room radiation levels were below the CRIS actuation setpoints before resetting the CRIS.

The cause of the electrical noise spikes is of unknown origin. Similar events were previously reported in LER's 84-022, 84-023, and 84-038 (all Docket No. 50-361). As reported in LER 84-023, an engineering evaluation is being performed to determine the cause of the spikes. The results of the evaluation and any planned corrective action will be reported in a revision to LER 84-023.

There are no reasonable or credible circumstances that would have increased the severity of this incident. Neither the health and safety of plant personnel nor the public were affected.

8409210051 840907 PDR ADDCK 05000361 PDR 型

Southern California Edison Company

SCE

SAN ONOFRE NUCLEAR GENERATING STATION

P.O. BOX 128

SAN CLEMENTE, CALIFORNIA 92672

J. G. HAYNES
STATION MANAGER
September 7, 1984

TELEPHONE (714) 492-7700

U.S. Nuclear Regulatory Commission Document Control Desk Washington, D.C. 20555

Subject: Docket No. 50-361

30-Day Report

Licensee Event Report No. 84-047

San Onofre Nuclear Generating Station, Units 2 and 3

Pursuant to 10 CFR 50.73(a)(2)(iv), this submittal provides the required 30-day written Licensee Event Report (LER) for an occurrence involving spurious actuation of the Control Room Isolation System (CRIS). Since this event involved components common to Units 2 and 3, a single report is being submitted in accordance with NUREG-1022.

If you require any additional information, please so advise.

Sincerely,

JaHaynes/sen

Enclosure: LER 84-047

cc: A. E. Chaffee (USNRC Resident Inspector, Units 1, 2 and 3)

J. P. Stewart (USNRC Resident Inspector, Units 2 and 3)

J. B. Martin (Regional Administrator, USNRC Region V)

Institute of Nuclear Power Operations (INPO)

IEZZ