

APPENDIX A

NOTICE OF VIOLATION

Nebraska Public Power District  
Cooper Nuclear Station

Docket: 50-298/84-12  
License: DPR-46  
EA 84-76

Based on the results of an NRC inspection conducted during the period of June 4-8, 1984, and in accordance with the NRC Enforcement Policy (10 CFR Part 2, Appendix C), 49 FR 8583, dated March 8, 1984, the following violation was identified:

Transportation of Licensed Material

10 CFR Part 71.5(a), "Transportation of Licensed Material," requires that no licensed material shall be transported outside of the confines of the licensee's plant unless the requirements of the regulations appropriate to the mode of transportation of the Department of Transportation in 49 CFR Parts 170 through 189 are met. 49 CFR Part 173.441(b)(3) states that the radiation dose rate shall not exceed 10 millirem per hour at any point 2 meters (6.6 feet) from the vertical planes represented by the outer lateral surfaces of the vehicle.

Contrary to the above, on May 10, 1984, a shipment of licensed material received at the Beatty, Nevada, low-level waste site was found by a state of Nevada inspector to have a radiation dose rate at 2 meters from either side of the trailer in excess of 10 millirem per hour.

This is a Severity Level III Violation. (Supplement V)

Pursuant to the provisions of 10 CFR 2.201, Nebraska Public Power District is hereby required to submit to this office, within 30 days of the date of this Notice, a written statement or explanation in reply, including: (1) the corrective steps which have been taken and the results achieved; (2) the corrective steps which will be taken to avoid further violations; and (3) the date when full compliance will be achieved. Consideration may be given to extending your response time for good cause shown.