



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

ENERGY OPERATIONS, INC.

DOCKET NO. 50-382

WATERFORD STEAM ELECTRIC STATION, UNIT 3

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 104
License No. NPF-38

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Entergy Operations, Inc. (the licensee) dated August 5, 1993, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.

2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.C(2) of Facility Operating License No. NPF-38 is hereby amended to read as follows:

(2) Technical Specifications and Environmental Protection Plan

The Technical Specifications contained in Appendix A, as revised through Amendment No. 104, and the Environmental Protection Plan contained in Appendix B, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications and the Environmental Protection Plan.

3. This license amendment is effective as of its date of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION

Chandu P. Patel

Chandu P. Patel, Project Manager
Project Directorate IV-1
Division of Reactor Projects - III/IV
Office of Nuclear Reactor Regulation

Attachment: Changes to the
Technical Specifications

Date of Issuance: April 20, 1995

ATTACHMENT TO LICENSE AMENDMENT NO. 104
TO FACILITY OPERATING LICENSE NO. NPF-38
DOCKET NO. 50-382

Replace the following pages of the Appendix A Technical Specifications with the attached pages. The revised pages are identified by Amendment number and contain vertical lines indicating the areas of change. The corresponding overleaf page is also provided to maintain document completeness.

<u>REMOVE PAGES</u>	<u>INSERT PAGES</u>
V	V
3/4 3-49	3/4 3-49
3/4 3-54	-
3/4 3-55	-
B 3/4 3-3a	B 3/4 3-3a

INDEX

LIMITING CONDITION FOR OPERATION AND SURVEILLANCE REQUIREMENTS

<u>SECTION</u>	<u>PAGE</u>
<u>3/4.2 POWER DISTRIBUTION LIMITS</u>	
3/4.2.1 LINEAR HEAT RATE.....	3/4 2-1
3/4.2.2 PLANAR RADIAL PEAKING FACTORS.....	3/4 2-3
3/4.2.3 AZIMUTHAL POWER TILT.....	3/4 2-4
3/4.2.4 DNBR MARGIN.....	3/4 2-6
3/4.2.5 RCS FLOW RATE.....	3/4 2-10
3/4.2.6 REACTOR COOLANT COLD LEG TEMPERATURE.....	3/4 2-11
3/4.2.7 AXIAL SHAPE INDEX.....	3/4 2-12
3/4.2.8 PRESSURIZER PRESSURE.....	3/4 2-13
 <u>3/4.3 INSTRUMENTATION</u>	
3/4.3.1 REACTOR PROTECTIVE INSTRUMENTATION.....	3/4 3-1
3/4.3.2 ENGINEERED SAFETY FEATURES ACTUATION SYSTEM INSTRUMENTATION.....	3/4 3-13
3/4.3.3 MONITORING INSTRUMENTATION	
RADIATION MONITORING INSTRUMENTATION.....	3/4 3-28
SEISMIC INSTRUMENTATION.....	3/4 3-35
METEOROLOGICAL INSTRUMENTATION.....	3/4 3-38
REMOTE SHUT-DOWN INSTRUMENTATION.....	3/4 3-41
ACCIDENT MONITORING INSTRUMENTATION.....	3/4 3-44
CHEMICAL DETECTION SYSTEMS.....	3/4 3-47
EXPLOSIVE GAS MONITORING INSTRUMENTATION.....	3/4 3-60
3/4.3.4 DELETED.....	3/4 3-68

INDEX

LIMITING CONDITION FOR OPERATION AND SURVEILLANCE REQUIREMENTS

<u>SECTION</u>	<u>PAGE</u>
<u>3/4.4 REACTOR COOLANT SYSTEM</u>	
3/4.4.1 REACTOR COOLANT LOOPS AND COOLANT CIRCULATION	
STARTUP AND POWER OPERATION.....	3/4 4-1
HOT STANDBY.....	3/4 4-2
HOT SHUTDOWN.....	3/4 4-3
COLD SHUTDOWN - LOOPS FILLED.....	3/4 4-5
COLD SHUTDOWN - LOOPS NOT FILLED.....	3/4 4-6
3/4.4.2 SAFETY VALVES	
SHUTDOWN.....	3/4 4-7
OPERATING.....	3/4 4-8
3/4.4.3 PRESSURIZER	
PRESSURIZER.....	3/4 4-9
AUXILIARY.....	3/4 4-9a
3/4.4.4 STEAM GENERATORS.....	3/4 4-10
3/4.4.5 REACTOR COOLANT SYSTEM LEAKAGE	
LEAKAGE DETECTION SYSTEMS.....	3/4 4-17
OPERATIONAL LEAKAGE.....	3/4 4-18
3/4.4.5 CHEMISTRY.....	3/4 4-21
3/4.4.7 SPECIFIC ACTIVITY.....	3/4 4-24
3/4.4.8 PRESSURE/TEMPERATURE LIMITS	
REACTOR COOLANT SYSTEM.....	3/4 4-28
PRESSURIZER HEATUP/COOLDOWN.....	3/4 4-33
OVERPRESSURE PROTECTION SYSTEMS.....	3/4 4-34
3/4.4.9 STRUCTURAL INTEGRITY.....	3/4 4-36
3/4.4.10 REACTOR COOLANT SYSTEM VENTS.....	3/4 4-37
<u>3/4.5 EMERGENCY CORE COOLING SYSTEMS (ECCS)</u>	
3/4.5.1 SAFETY INJECTION TANKS.....	3/4 5-1
3/4.5.2 ECCS SUBSYSTEMS - Modes 1, 2, and 3	3/4 5-3
3/4.5.3 ECCS SUBSYSTEMS - Modes 3 and 4	3/4 5-8
3/4.5.4 REFUELING WATER STORAGE POOL.....	3/4 5-9

Pages 3/4 3-49 through 3/4 3-59 have been deleted.

INSTRUMENTATION

BASES

for the system is thus based on testing and operating experience, and the setpoint is set at the lowest achievable IDLH gas concentration providing reliable operation and the optimum detection of toxic gases. The setpoint is therefore subject to change wherein necessitated by operating experience such as a result of changes in the Waterford 3 area chemical atmospheric profile. The setpoint is established and controlled by procedure.

3/4.3.3.8 This section deleted

3/4.3.3.9 This section deleted