

APPENDIX A
NOTICE OF VIOLATION

Rochester Gas and Electric Corporation
R. E. Ginna Nuclear Power Plant

Docket No. 50-244
License No. DPR-18

As a result of the inspection conducted on June 9, 1984 through July 31, 1984, and in accordance with the NRC Enforcement Policy, (10 CFR 2, Appendix C) published in the Federal Register on March 8, 1984 (49 FR 8583) the following violation was identified:

Technical Specification 6.8, "Procedures" requires written procedures be established, implemented, and maintained covering activities referenced in Appendix 'A' of Regulatory Guide 1.33, November 1972.

Ginna Station Administrative Procedure (A)-52.4, "Control of Limiting Conditions for Operating Equipment", Revision No. 45, June 19, 1984, written pursuant to Technical Specification 6.8, requires Attachment I to A-52.4 to be utilized to document safeguards equipment which is removed from and restored to service, and to ensure the Operations Department is aware of the Limiting Conditions for Operation imposed by Technical Specifications to meet minimum system operability requirements.

Contrary to the above, on July 25, 1984, Attachment I to A-52.4 was not utilized to identify the inoperability of Automatic Deluge System S-29.

This is a Severity Level V Violation (Supplement 1).

Pursuant to the provisions of 10 CFR 2.201, Rochester Gas and Electric Corporation is hereby required to submit to this office within thirty days of the date of this Notice, a written statement or explanation in reply, including: (1) the corrective steps which have been taken and the results achieved; (2) corrective steps which will be taken to avoid further violations; and (3) the date when full compliance will be achieved. Where good cause is shown, consideration will be given to extending the response time.

OFFICIAL RECORD COPY

50-244/84-16 - 0003.0.0
08/23/84

8409210360 840829
PDR ADOCK 05000244
Q PDR