

July 5, 1995

Dresden 2 and 3

**Technical Evaluation Report
on the Individual Plant Examination
Front End Analysis**

NRC-04-91-066, Task 19

John L. Darby, Analyst
James R. Lynch, Editor
Willard R. Thomas, Editor

Science and Engineering Associates, Inc.

Prepared for the
Nuclear Regulatory Commission

TABLE OF CONTENTS

E. Executive Summary	1
E.1 Plant Characterization	1
E.2 Licensee's IPE Process	2
E.3 Front-End Analysis	2
E.4 Generic Issues	6
E.5 Vulnerabilities and Plant Improvements	6
E.6 Observations	7
1. INTRODUCTION	9
1.1 Review Process	9
1.2 Plant Characterization	9
2. TECHNICAL REVIEW	11
2.1 Licensee's IPE Process	11
2.1.1 <u>Completeness and Methodology</u>	11
2.1.2 <u>Multi-Unit Effects and As-Built, As-Operated Status</u>	12
2.1.3 <u>Licensee Participation and Peer Review</u>	12
2.2 Accident Sequence Delineation and System Analysis	13
2.2.1 <u>Initiating Events</u>	13
2.2.2 <u>Event Trees</u>	14
2.2.3 <u>Systems Analysis</u>	18
2.2.4 <u>System Dependencies</u>	18
2.3 Quantitative Process	19
2.3.1 <u>Quantification of Accident Sequence Frequencies</u>	19
2.3.2 <u>Point Estimates and Uncertainty/Sensitivity Analyses</u>	19
2.3.3 <u>Use of Plant-Specific Data</u>	19
2.3.4 <u>Use of Generic Data</u>	21
2.3.5 <u>Common-Cause Quantification</u>	21
2.4 Interface Issues	23
2.4.1 <u>Front-End and Back-End Interfaces</u>	23
2.4.2 <u>Human Factors Interfaces</u>	23
2.5 Evaluation of Decay Heat Removal and Other Safety Issues	24
2.5.1 <u>Examination of DHR</u>	24
2.5.2 <u>Diverse Means of DHR</u>	24
2.5.3 <u>Unique Features of DHR</u>	24
2.5.4 <u>Other GSI/USIs Addressed in the Submittal</u>	25
2.6 Internal Flooding	25
2.6.1 <u>Internal Flooding Methodology</u>	25
2.6.2 <u>Internal Flooding Results</u>	26
2.7 Core Damage Sequence Results	26
2.7.1 <u>Dominant Core Damage Sequences</u>	26

2.7.2 <u>Vulnerabilities</u>	33
2.7.3 <u>Proposed Improvements and Modifications</u>	33
3. CONTRACTOR OBSERVATIONS AND CONCLUSIONS	35
4. DATA SUMMARY SHEETS	37
REFERENCES	40

LIST OF TABLES

Table 2-1.	Plant-Specific Data	20
Table 2-2.	Common Cause β Factors for 2-of-2 Components	22
Table 2-3.	CDF by Initiating Event	27
Table 2-4.	Top 5 Systemic Core Damage Sequences	28
Table 2-5.	Offsite Power Recovery Data used in Quad Cities IPE Compared to Data Used in Surry Shutdown PRA	31

LIST OF FIGURES

Figure 2-1. Comparison of Data for Recovery of Offsite Power

30

E. Executive Summary

This report summarizes the results of our review of the front-end portion of the Individual Plant Examination (IPE) for Dresden units 2 and 3. This review is based on information contained in the IPE Submittal along with the licensee's responses to Requests for Additional Information (RAI).

E.1 Plant Characterization

The Dresden site consists of two operating nuclear units, 2 and 3, located near Morris, Illinois. General Electric was the nuclear steam system supplier and the turbine generator supplier, Sargent and Lundy (S&L) was the architect engineer, and United Engineers and Constructors was the constructor.

Each unit is a boiling water reactor (BWR) 3 design with a Mark I containment. Both units are currently operating. Each unit has a design power of 2600 megawatts thermal (MWt), a rated power of 2527 MWt, and a net output of 809 megawatts electric (MWe). The two units began commercial operation in 1970 and 1971, respectively for units 2 and 3.

Design features at Dresden that impact the core damage frequency (CDF) are as follows:

- Isolation condenser for shutdown cooling with secondary makeup available from diesel-driven pumps. The isolation condenser has makeup water provided by diesel-driven pumps thereby not requiring DC power for pumping as does a typical Reactor Core Isolation Cooling (RCIC) system; this tends to decrease the CDF from station blackout.
- Automatic isolation of the isolation condenser after loss of 125 V DC power at one unit. The isolation condenser at Dresden automatically isolates on loss of DC power; this tends to increase the CDF from loss of DC power. The licensee has instituted a procedural change to allow continued operation of the isolation condenser after station blackout; this tends to decrease the CDF from station blackout but has no impact on the CDF from loss of DC power.
- Ability to crosstie AC power between the two units. AC power can be crosstied between the two units thereby reducing the CDF from station blackout.
- Shared DC power between the two units. Loss of DC power at one unit results in automatic loss of the isolation condenser. This tends to increase the CDF; loss of DC power at one unit dominated the total CDF. (It is noted that each unit has one train of 125-V DC power that serves both units. Loss of 125-V DC power at one unit causes partial loss of DC power at both units.)

- Net positive suction head (NPSH) margin for low-pressure emergency core cooling system (ECCS) pumps using the suppression pool. The low pressure ECCS pumps lose adequate NPSH from the suppression pool if containment cooling is lost even if containment venting is successful; this tends to increase the CDF.

E.2 Licensee's IPE Process

The IPE is a level 2 probabilistic risk assessment (PRA). The PRA was initiated in response to Generic Letter 88-20. The freeze date for the IPE model was January, 1991.

Commonwealth Edison Company (CECo) established a management structure for all 6 IPE projects at its various plants. The Submittal indicates that personnel from the Individual Plant Evaluation Partnership (IPEP) performed the basic modeling and analysis while CECo personnel performed success criteria analysis using the Modular Accident Analysis Program (MAAP) and conducted reviews of the models, input assumptions, and results. The IPEP contractor team was comprised of Westinghouse, TENERA, and Fauske and Associates.

Plant walkdowns were performed to develop an appreciation for the potential environmental impact on equipment that is difficult to discern from drawings. During the walkdowns, the design descriptions and drawings were checked for accuracy and completeness.

Major documentation used in the IPE included: the Final Safety Analysis Report, Technical Specifications, system descriptions, plant drawings, simulator runs, procedures, and calculations.

The following PRA studies of other plants were reviewed: the Reactor Safety Study (NUREG-1220), and the NUREG-1150 and NUREG/CR-4550 studies.

The following reviews of the level 1 PRA were performed. The contractors performed internal independent reviews of their work and CECo personnel reviewed information submitted by the contractors. Important results and products were reviewed by the senior management support team. A final review of the overall study was performed by CECo senior management.

The Submittal states that Dresden intends to maintain a "living" PRA.

E.3 Front-End Analysis

The front-end portion of the IPE is a level 1 PRA; the specific technique used for the level 1 PRA was the large event tree/small fault tree technique with support state modeling. Quantification was performed with the GRAFTER code.

The IPE evaluated the following nine groups of initiating events:

- Five loss of coolant accidents (LOCAs)
- One anticipated transient
- Two loss of offsite power transients (single and dual unit)
- Loss of 125-V DC power in one unit

The IPE developed event trees to model all of these initiating events.

The success criteria chosen for core cooling was maintaining fuel temperature below 4040 degrees F.

System success criteria for accident sequences were developed based on thermal hydraulic analyses performed with MAAP, the Updated Final Safety Analysis Report (UFSAR), and engineering judgment. Overall, the success criteria used in the Dresden IPE are optimistic compared to the success criteria used in typical IPE/PRA's. For example, the Dresden IPE assumed that depressurization can be successfully accomplished with only one Safety Relief Valve (SRV), while most IPE/PRA's for similar plants require 2 or 3 SRVs for successful depressurization.

Loss of instrument air was not considered as a special plant-specific initiating event. Loss of heating, ventilation, and air-conditioning (HVAC) was not considered to be an initiating event based on plant-specific analyses that were performed.

Major support systems were modeled in a support system event tree.

Plant-specific data were used based on the time period January 1, 1984, through December 31, 1990. Data from both units were combined into one database. Generic data were used when insufficient plant-specific data were available for quantification. Plant-specific data were used to quantify test and maintenance unavailabilities. Based on a spot check of the plant-specific data, the values in the Dresden IPE for component failures are comparable to those values used in other PRA's.

The Multiple Greek Letter (MGL) method was used to model common cause failures. The data for common cause failures were taken from EPRI NP-3967.

The Submittal implies that a Dresden-specific evaluation of common cause failure events was performed for certain types of components, and generic common cause failure data was applied to other components. Based on the discussion of this evaluation provided in the Submittal, this evaluation involved screening generic data for applicability and reducing the failure values based on a qualitative assessment of Dresden-specific programs and practices. Based on the information from Table 2-2 of this report, the common cause failure factors used in the Dresden IPE are lower than the values typically used in other IPE/PRA's.

The total CDF in the IPE from internal initiating events was $1.85E-5$ /year. Internal flooding was screened from consideration as an important contributor to CDF in the original IPE analysis. Additional information from the licensee stated that the estimated CDF for Dresden has changed since the date of the Submittal. With the inclusion of failure of DC power due to water spray effects, the total CDF for Unit 3 increased by 48% but the total CDF for Unit 2 did not change.

The Submittal reported core damage sequences consistent with the systemic reporting criteria of NUREG 1335. The top 100 core damage sequences were reported.

The dominant initiating events contributing to CDF were as follows:

Initiating Event (IE)	IE Frequency (1/year)	CDF (1/year)	Percent of CDF
Loss of 125-V DC Power at One Unit	$8.7E-4$	$1.1E-5$	60.2
Loss of Offsite Power to a Single Unit	$9.6E-2$	$3.7E-6$	19.9
Medium LOCA	$8.0E-4$	$1.4E-6$	7.5
Loss of Offsite Power to a Both Units	$1.6E-2$	$1.2E-6$	6.9
Anticipated Transient without Scram (ATWS)	$2.3E-4$	$5.3E-7$	2.9
General Transient	7.4	$2.7E-7$	1.4
Inadvertent Open Relief Valve	$7.1E-2$	$1.8E-7$	1.0
Large LOCA	$3.0E-4$	$3.7E-8$	0.2
Small LOCA	$3.0E-3$	$6.2E-9$	<0.1
Interfacing Systems LOCA	$1.1E-4$	$4.3E-4$	<<0.1

The CDF by accident class was as follows:

- The plant-specific transient "loss of 125-V DC power" contributed about 60% to the total CDF
- Loss of offsite power (single or dual) without station blackout contributed about 20% to the total CDF
- LOCAs contributed about 7% to the CDF
- Station blackout contributed about 5% to the CDF
- ATWS contributed about 2% to the CDF
- General transients contributed about 1% to the total CDF.

Based on the discussions of the dominant core damage sequences, important failures in mitigating systems were: failures of Motor Operated Valves (MOVs), operator failure to initiate suppression pool cooling, failure of Diesel Generator (DG) 2/3, operator failure to align to bus 24-1, operator failure to provide makeup to the isolation condenser, operator failure to depressurize, and failure of the High Pressure Coolant Injection (HPCI) pump.

The IPE used Plant Response Trees (PRTs) that model both the front and back end portions of the accident sequences. Therefore, traditional plant damage states (PDSs) that bin front-end core damage sequences for subsequent back-end analyses were not used.

On the basis of our review, the following aspects of the modeling process have an impact on the overall CDF:

- Quantification of only one plant-specific initiating event. If more plant-specific initiating events had been quantified for core damage- as is typically the case in other IPE/PRA- the CDF might have been increased.
- Negligible leakage from recirculation pump seals during station blackout. The CDF from station blackout could be higher if the IPE had considered leakage from the recirculation pump seals; seal leakage cannot be isolated during station blackout and cooling with the isolation condenser does not provide makeup to the vessel.
- Credit for maintaining adequate NPSH from the suppression pool after loss of suppression pool cooling by either injecting water to the suppression pool to allow continued use of low-pressure ECCS pumps or by realigning low-pressure ECCS pumps to inject from the Condensate Storage Tank (CST). The CDF was significantly reduced by crediting these compensatory actions to maintain the use of low pressure ECCS systems following loss of suppression pool cooling.
- The low common cause failure factors used. The use of common cause failure factors lower than typically assumed in other IPE/PRA studies lowered the CDF.

E.4 Generic Issues

The IPE specifically addressed loss of Decay Heat Removal (DHR), considering DHR as both core cooling and ultimate heat removal. The IPE evaluated the diverse means for DHR, including: use of the power conversion system, the isolation condenser, and ECCS.

About 69% of the total CDF involved failure of suppression pool cooling: 55% due to hardware failure and 14% due to operator error. With the change to allow for long term alignment of Low Pressure Coolant Injection (LPCI) and core spray to the CST if suppression pool cooling is lost, the contribution of loss of suppression pool cooling to the overall CDF decreased to about 8%. No vulnerabilities associated with DHR were identified as a result of the IPE.

The licensee does not propose to resolve any other generic issues other than DHR.

E.5 Vulnerabilities and Plant Improvements

No definition of "vulnerability" was provided in the Submittal. The Submittal states that there are no vulnerabilities based on the low overall CDF.

Two modifications scheduled after the freeze date were credited in the IPE model, these being:

- a torus/drywell hardened containment vent
- diesel-driven isolation condenser makeup pumps.

As a result of the IPE, 130 insights were developed and evaluated using the Nuclear Management and Resource Council (NUMARC) Severe Accident Closure Guidelines. The evaluation indicated that the greatest reduction in plant risk could be achieved by implementing a procedural change for realignment of core spray or LPCI to the condensate storage tank, to prevent loss of adequate NPSH for the pumps when pulling from the suppression pool without suppression pool cooling. CECo has decided to implement this procedure at Dresden. This change was also implemented at Quad Cities. The CDF was recalculated with this change in procedure. This change lowered the CDF from 1.85E-5 to 3.75E-6 per reactor year [IPE submittal Table 6.2-1].

The CECo cover letter attached to the Submittal indicates that CECo plans to implement a procedural change that is directed at ensuring operability of the isolation condenser during station blackout. The change is operator action to open circuit breakers for the 250 V DC operated valves in the isolation condenser piping prior to depletion of DC batteries under station blackout conditions.

Additional information from the licensee indicates that both of these procedural changes have now been implemented at Dresden, resulting in a decrease in the CDF for both units. With credit for these changes and considering the loss of DC power in Unit 3 due to water spray, the total CDF for Unit 2 is $3.76E-6$ /reactor-year and the total CDF for Unit 3 is $4.36E-6$ /reactor-year.

E.6 Observations

We believe that the licensee analyzed the plant design and operations of Dresden to discover instances of particular vulnerability to core damage, with three exceptions as subsequently discussed. The licensee has developed an overall appreciation of severe accident behavior, understands the most likely severe accidents at Dresden with the three exceptions as subsequently noted, has gained a quantitative understanding of the overall frequency of core damage, and has implemented changes to the plant to help prevent and mitigate severe accidents.

Strengths of the IPE are as follows. The model did recognize the design characteristic of the NPSH margin for the low pressure ECCS pumps such that adequate Net Positive Suction Head Available (NPSHA) is lost for these pumps pulling from the suppression pool if suppression pool cooling is lost and no compensatory actions are taken.

Shortcomings of the IPE are as follows. (1) The common cause failure factors are much lower than those typically used in IPE/PRA's based on the plant-specific screening evaluation employed. Common cause failures are subtle and it is possible that the licensee has underestimated the potential for common cause failures. (2) Only one plant-specific initiating event was evaluated (loss of 125-V DC power at one unit) and that initiating event dominated the CDF. Other IPE/PRA's address plant-specific initiating events in more detail and retain more than one such event for quantification. The licensee has not demonstrated that all potentially important plant-specific initiating events were evaluated. (3) The Dresden IPE assumed that leakage from recirculation pump seals is a negligible effect during station blackout. A recent IPE for a similar plant addressed leakage from recirculation pump seals and it dominated the CDF for that plant. For BWRs with isolation condensers, shutdown cooling can be provided without injection to the vessel, but leakage from failed seals can negate the effectiveness of the isolation condenser.

Significant level-one IPE findings are as follows:

- Loss of 125-V DC power at one unit dominates the CDF.
- Station blackout is a low contributor to the CDF.
- Realigning the low pressure ECCS pumps to the CST over the long term after loss of suppression pool cooling substantially decreases the total CDF.

Loss of 125 V DC at one unit results in loss of the ability to use the isolation condenser for core cooling. Station blackout is a low contributor to the total CDF due to the ability to cross tie power between the units, due to the high probability for recovery of offsite power, and due to the low common cause failure factors used for Diesel Generators (DGs). Credit for realigning the low pressure ECCS pumps to the CST over the long term after loss of suppression pool cooling decreases the total CDF by a factor of 5.

1. INTRODUCTION

1.1 Review Process

This report summarizes the results of our review of the front-end portion of the IPE for Dresden units 2 and 3. This review is based on information contained in the IPE Submittal along with the licensee's responses to RAI. [IPE] [IPE Responses] [IPE Responses 2]

1.2 Plant Characterization

The Dresden site consists of two operating nuclear units, 2 and 3, located near Morris, Illinois. The water source is the Kanakee River, and a cooling lake provides the ultimate heat sink. (Unit 1, an earlier generation BWR, is defueled and permanently inoperable.) The systems at the two units are similar, with numerous shared systems and structures. The only differences between the two units are equipment locations and sources of auxiliary power. General Electric was the Nuclear Steam System Supplier and the turbine generator supplier, Sargent and Lundy (S&L) was the architect engineer, and United Engineers and Constructors was the constructor.

Each unit is a BWR 3 design with a Mark I containment. Both units are currently operating. Each unit has a design power of 2600 MWt, a rated power of 2527 MWt, and a net output of 809 MWe. The two units achieved commercial operation in 1970 and 1971, respectively for units 2 and 3.

Design features at Dresden that impact the Core Damage Frequency (CDF) are as follows:

- Isolation condenser for shutdown cooling with secondary makeup available from diesel-driven pumps. The isolation condenser has makeup water provided by diesel-driven pumps thereby not requiring DC power for pumping as does a typical Reactor Core Isolation Cooling (RCIC) system; this tends to decrease the CDF from station blackout.
- Automatic isolation of the isolation condenser after loss of 125 V DC power at one unit. The isolation condenser at Dresden automatically isolates on loss of DC power; this tends to increase the CDF from loss of DC power. The licensee has instituted a procedural change to allow continued operation of the isolation condenser after station blackout; this tends to decrease the CDF from station blackout but has no impact on the CDF from loss of DC power.
- Ability to cross tie AC power between the two units. AC power can be cross tied between the two units thereby reducing the CDF from station blackout.

- Shared DC power between the two units. Loss of DC power at one unit results in automatic loss of the isolation condenser. This tends to increase the CDF; loss of DC power at one unit dominated the total CDF. (It is noted that each unit has one train of 125-V DC power that serves both units. Loss of 125-V DC power at one unit causes partial loss of DC power at both units.)
- Net positive suction head (NPSH) margin for low-pressure emergency core cooling system (ECCS) pumps using the suppression pool. The low pressure ECCS pumps lose adequate NPSH from the suppression pool if containment cooling is lost even if containment venting is successful; this tends to increase the CDF.

2. TECHNICAL REVIEW

2.1 Licensee's IPE Process

We reviewed the process used by the licensee with respect to: completeness and methodology; multi-unit effects and as-built, as-operated status; and licensee participation and peer review.

2.1.1 Completeness and Methodology

The Dresden IPE is a level 2 PRA. The IPE is complete with respect to the type of information requested by Generic Letter 88-20 and NUREG 1335.

The front-end portion of the IPE is a level 1 PRA. The specific technique used for the level 1 PRA was the large event tree/small fault tree technique with support state modeling.

The Submittal described the details of the technique. Internal initiating events and internal flooding were considered. Event trees were developed for all classes of initiating events. Plant Response Trees (PRT) were developed for each class of initiating event. The PRTs model both the front-end and the back-end portions of the analysis, and they are larger in scope than the standard event trees that model the front-end portion of the accident sequences. The development of component level system fault trees was summarized, and system descriptions were provided.

The IPE did not include an uncertainty analysis. The Submittal did include a limited sensitivity analysis.

The licensee provided a summary of how dependencies were accounted for in the IPE. The licensee discussed three types of dependencies: (1) intra-system dependencies involving support systems, (2) intra-system dependencies between front line systems, and (3) inter-system dependencies. The first type of dependency is accounted for using support state modeling. The second type of dependency is accounted for in the structure of the event trees. The third type of dependency is modeled by using more than one fault tree to reflect success of an event in which the system is only partially successful; this allows the state of failed components to be retained for quantification of later events involving systems using the same components.

The PRA upon which the IPE is based was initiated in response to Generic Letter 88-20.

2.1.2 Multi-Unit Effects and As-Built, As-Operated Status

Dresden is a dual unit site and the two units share some systems, such as the swing DG and DC electrical power. The IPE modeled Unit 2 and concluded that the results of the analysis are applicable to Unit 3 as well. [IPE submittal, Sections 2.5 and 4.1.3.4]

The licensee provided additional information that estimates that the dual unit CDF from the initiating event dual unit loss of offsite power is $1.77E-7$ /year.

Plant walkdowns were performed to develop an appreciation for the potential environmental impact on equipment that is difficult to discern from drawings. [IPE submittal, Section 2.4] During the walkdowns, the design descriptions and drawings were checked for accuracy and completeness.

Major documentation used in the IPE included: the UFSAR, technical specifications, system descriptions, plant drawings, simulator runs, procedures, and calculations. [IPE submittal, Table 2-1]

PRA studies of other plants that were reviewed include: the Reactor Safety Study, and the NUREG 1150 and NUREG/CR 4550 studies. The freeze date for the IPE model was January 1991. Two modifications scheduled after the freeze date were credited in the IPE model, these being:

- (1) a torus/drywell hardened containment vent
- (2) diesel-driven isolation condenser makeup pumps.

2.1.3 Licensee Participation and Peer Review

CECo established a management structure for all 6 IPE projects at its various plants. The Submittal indicates that IPEP (contractor) personnel performed the basic modeling and analysis while CECo personnel performed success criteria analysis using MAAP and conducted reviews of the models, input assumptions, and results. [IPE submittal, Section 3.1] The IPEP contractor team consisted of: Westinghouse, TENERA, and Fauske and Associates. The licensee provided additional information as to the involvement of Dresden plant operations and maintenance personnel in the development and review of the PRTs, and fault trees.

The Submittal states that Dresden intends to maintain a "living" PRA.

The process used by the licensee to review the IPE was assessed. Several reviews of the level 1 PRA were performed. [IPE submittal, Section 3.2] CECo contractors performed internal independent reviews of their work, and CECo personnel reviewed information submitted by the contractors. Important results and products were

reviewed by the Senior Management Support Team. A final review of the overall study was performed by CECo senior management.

2.2 Accident Sequence Delineation and System Analysis

This section of the report documents our review of both the accident sequence delineation and the evaluation of system performance and system dependencies provided in the Submittal.

2.2.1 Initiating Events

The IPE evaluated nine groups of initiating events. [IPE submittal, Table 4.1.1-1] These events can be categorized as follows:

- Five LOCAs
- One anticipated transient
- Two loss of offsite power transients (single and dual unit)
- Loss of 125-V DC power in one unit.

The IPE developed PRTs to model all of these initiating events. [IPE submittal, Volume 2]

Plant-specific data were used to quantify high frequency transient initiating events. [IPE submittal, Section 4.0] Generic data for transient initiating events were taken from NUREG/CR-3862. LOCA initiating frequencies were taken from WASH-1400. Interfacing system LOCA initiating events were quantified by a plant-specific calculation. Loss of 125 V DC power was quantified by fault tree analysis.

The IPE used one 'global' event tree to evaluate all transient initiating events except for the following events for which specific event trees were developed: ATWS, loss of offsite power, station blackout, and loss of DC power. The following four categories were included in the general ('global') transient category:

- T1- General Transient with feedwater (FW) and main condenser (MC) Available
- T2- General Transient with FW Available and MC Unavailable
- T3- General Transient with FW Unavailable and MC Available
- T4- General Transient with FW and MC Unavailable.

Only one plant-specific initiating event was specifically evaluated, that being loss of DC power; typically, IPE/PRA's quantify the CDF from numerous plant-specific initiating events. The licensee does not address how plant-specific transient initiating events were considered as initiating events. Most PRA's discuss how plant-specific failures were analyzed as potential initiating events, and most PRA's include a number of plant-specific failures as initiating events. The licensee only addressed 'generic' initiating events and initiating events based on the plant history.

For those initiating events considered, the frequencies assigned to the events are comparable to values used in other IPE/PRA's, except for the frequency assigned to a small LOCA initiating event. [IPE submittal, Table 4.1.1-1] The Submittal does not specify whether or not recirculation pump seal LOCAs were included in the small LOCA initiating event.

The licensee states that the leakage expected from a seal LOCA is sufficiently small so that the event can be classified as a transient rather than a small LOCA. This assumption is in contrast to the assumption made in most IPE/PRA's for BWRs and it results in a significantly smaller frequency for a small/small-small LOCA in the Dresden IPE than in other IPE/PRA's. The frequency of a small LOCA in the Dresden IPE is $3.0E-3$ /year; NUREG/CR 4550 for Peach Bottom used a frequency of $3.0E-2$ /year for a seal LOCA, designated as a small-small LOCA. [NUREG/CR 4550 Peach Bottom] The licensee pointed out that a seal LOCA can be isolated; this is true if AC power is available.

Because the IPE treated a seal LOCA initiating event as a transient, the model for mitigation of the seal LOCA in the IPE assumes that successful core cooling following a seal LOCA can be achieved using the isolation condenser without any makeup to the vessel.

The IPE does distinguish between single and dual unit loss of offsite power as initiating events. Single unit loss of offsite power does not automatically result in a requirement to use the DGs since offsite power can be crosstied between the two units.

2.2.2 Event Trees

The success criteria chosen for core cooling was maintaining fuel temperature below 4,040 F. [IPE submittal, Section 4.1.4.1] This definition of success criteria for core cooling does not contain any consideration the Peak Cladding Temperature (PCT) which is the limiting parameter following a large LOCA. The licensee states that PCT was considered in development of the success criteria but was not explicitly quantified since MAAP was used to evaluate success criteria, and MAAP does not calculate PCT.

The system success criteria in the IPE differ from the system/function success criteria in the UFSAR for mitigation of a large LOCA; for example, the IPE credits one LPCI pump alone as adequate for core cooling. The licensee states that the large LOCA success criteria were based on MAAP calculations. The calculation did not consider leakage out the jet pump joints. The licensee stated that the UFSAR (for Quad Cities) indicates that one LPCI pump is adequate to provide core cooling during a large LOCA; the UFSAR information referred to is Table 6.3-11 of the UFSAR. It is not clear how the information in this table supports the assumption that one LPCI pump can provide core cooling since this table is based on the ECCS failures indicated in

Tables 6.3-7 and 6.3-9 of the UFSAR, in which at least one train of core spray and at least 2 LPCI pumps are available, or both core spray trains are available. In our opinion, MAAP should not be used to support significant deviations from the licensing success criteria for large break LOCAs. On the other hand, the success criteria used in the Dresden IPE for a large LOCA are similar to those used for other BWR IPE/PRA's. During our review of an IPE for a similar plant, the licensee provided additional information stating that GE's SAFER/GESTR methodology was used to establish the large LOCA success criteria and that this methodology did include delayed neutron fission energy and implicitly accounted for jet pump leakage by using conservative ECCS injection rates. [TER, Hatch] Therefore, the success criteria for a large LOCA used in the Dresden IPE in terms of the number and types of ECCS pumps required, may be valid, based on the more comprehensive analyses performed for similar plants.

The systems/sequences success criteria in the IPE for preventing core damage have numerous differences from the success criteria used in other PRA/IPE studies of BWRs as discussed in the following topics:

- The IPE assumes that only one relief valve is required to depressurize so that LPCI or CS can be used. Typically, PRA's assume more than one valve is required; for example, the NUREG/CR 4550 study for Peach Bottom assumed that 3 are required. The licensee states that MAAP calculations were used to demonstrate that core damage will not occur. The model assumed that an electromagnetic relief valve would relieve 625,000 lbm/hr at 1117 psig. Based on information available to us (timing of critical events and the maximum core temperature reached), the size of the relief valve used in the Dresden analysis may be too large. Since IPE/PRA's typically require more than one relief valve to depressurize, and the ability to depressurize is a key aspect of the mitigation strategy for transients in a BWR upon loss of high pressure makeup/injection systems, we believe that additional information is needed to support the IPE assumption that only one valve is needed to successfully depressurize.
- The IPE models containment venting for the back-end analysis, but the front-end success criteria do not address containment venting. If the containment is vented with a hot suppression pool, adequate NPSHA can be lost for ECCS pumps pulling from the suppression pool; this was the assumption in the NUREG/CR 4550 analysis of Peach Bottom. The licensee states that venting is initiated at about 60 psig, and that the low pressure ECCS pumps would have lost adequate NPSHA from the suppression pool prior to the conditions for venting.
- Credit is taken for supplying containment with water from the Standby Coolant System (SBCS) following a large LOCA if suppression pool cooling is lost. This system involves using feedwater to supply water to the containment from the condenser hotwell with the hotwell makeup supplied from service water. This

preserves adequate NPSHA for the LPCI and Core Spray (CS) pumps. The licensee states that the following support systems are needed to effect use of Standby Coolant System (SBCS): Turbine Building Component Cooling Water (TBCCW), instrument air, and various 4160 V AC, 480 V AC, and 125 V DC buses. Operator actions required to implement the option are discussed in the licensee response. Control of containment overfill was not specifically modeled due to the relatively little amount of injection required to provide for long term adequate NPSHA; the model implicitly assumed that operator action to control overfill would be taken.

- The IPE success criteria for a large LOCA do not address the need to close the recirculation discharge isolation valve in the intact recirculation loop to prevent loss of LPCI injected water out the break. However, the licensee states that closure of the discharge valve in the intact recirculation loop should have been required in the IPE model to successfully mitigate a large LOCA. This change is expected to increase the CDF by about only 0.2%.
- LOCAs outside containment were screened from consideration. Therefore, the success criteria for LOCAs do not address LOCAs outside containment in steam and feedwater lines, and the need to isolate such breaks to prevent loss of suppression pool inventory from ECCS recirculation out the break.
- The success criteria for ATWS do not discuss operator action to inhibit depressurization to prevent reactivity increase due to the injection of large quantities of cold water. The licensee states that the model assumed the operators would inhibit ADS. The IPE model would be more complete if the modeling explicitly included failure of the operator to inhibit ADS in response to an ATWS.
- The IPE success criteria indicate that if the core is cooled using feedwater, containment failure has no impact on the ability to maintain core cooling. It was assumed that containment failure has no impact on the ability to use the feedwater system to cool the core due to the location of components in the feedwater system.
- HVAC was modeled as required for the containment cooling service water (CCSW) pumps B and C. HVAC was assumed to not be required for other areas, specifically the electrical switchgear rooms, battery rooms, CCSW rooms, and the control room. The basis for not requiring HVAC for the other areas was not further clarified.
- The IPE success criteria do not require containment cooling to support operation of HPCI. MAAP calculations indicate that cyclical operation of HPCI without containment cooling would not result in loss of HPCI during the 24 hour mission time. Specifically, the calculation indicated that: the turbine

backpressure would not exceed 100 psig, the area temperature would not exceed 200 F, and sufficient NPSH would be maintained for the HPCI booster pump.

- The IPE assumed that no safety or relief valves open during a station blackout before operator action can successfully establish cooling with the isolation condenser. At least 10 minutes are available for operator action to initiate cooling with the isolation condenser following loss of offsite power, before valves are challenged to open. We believe that his operator action should be evaluated by the human factors review of the IPE, as discussed in Section 2.4.2 of this report.

The event trees do not require cooling for the recirculation pump seals during a transient to prevent the accident from evolving to a small LOCA. This is an important point for the Dresden design as isolation condensers are used to provide shutdown cooling during station blackout and the use of the isolation condensers does not involve makeup to the vessel. The IPE assumes that even though seal cooling is lost during station blackout, cooling with the isolation condensers is sufficient to prevent core damage and no long term makeup to the vessel is required. The licensee expects that the impact of seal leakage on use of the isolation condenser should be minimal due to the low seal leakage flow rates expected. However, in our assessment, seal leakage, especially during station blackout, should be considered; leakage from the vessel dominated the CDF in the IPE for a similar plant.

The IPE uses the following modeling for an ATWS: OSL1 is operator action to use 1 of 2 Standby Liquid Control (SLC) pumps to borate, and the PRT indicates that if OSL1 is not successful, OSL2 can successfully provide boration, and OSL2 is operator action to use 2 of 2 SLC pumps. OSL1 is early operator action and requires 1 of 2 SLC pumps for success. OSL2 is late operator action and requires 2 of 2 SLC pumps for success. No hardware failures are included in OSL1 and OSL2; these are purely operator action events.

The IPE success criteria do not address containment venting. [IPE submittal, Table 4.1.4-1] For many BWR IPEs, if suppression pool cooling is lost containment venting is assumed to not to cause loss of core cooling by using low pressure ECCS pumps pulling from the suppression pool, and containment venting has an important impact on reducing the CDF. As previously discussed in this report, for Dresden, without suppression pool cooling, adequate NPSHA for the LPCI and core spray pumps is lost prior to reaching the pressure for venting (60 psig). Therefore, containment venting has little impact on reducing the CDF for Dresden. This is a reflection of the NPSH margin for these pumps inherent in the plant design; Quad Cities has the same design feature.

2.2.3 Systems Analysis

System descriptions are included in Section 4.2 of the Submittal; system schematics are included in Volume 2 of the Submittal.

The system description for the Isolation Condenser does not discuss a major design feature of the system that impacts the CDF. The loss of 125 V DC power at a unit causes automatic closure of 250 V DC valves in the system piping resulting in loss of the isolation condenser. [IPE submittal, Sections 1.6.3 and 7.2] Therefore, the isolation condenser is lost following the initiating event "Loss of 125-V DC Power at One Unit". Also, during station blackout long term core cooling via the isolation condenser is lost after the 125 V DC batteries deplete even though diesel-driven pumps are available to provide makeup to the secondary of the isolation condenser. As discussed in Section 2.7 of this report, the licensee has instituted a change in procedures to prevent loss of the isolation condenser due to long term loss of DC power during station blackout.

No discussion of cooling for the recirculation pump seals is provided in the Submittal. Details are not provided that address cooling for these seals to prevent a transient from evolving into a small LOCA.

For loss of all AC power at one unit, credit is taken for supply of power by crosstie from the other unit via the 24-1 and 34-1 buses. The IPE model required either suppression pool cooling or injection of external water to the suppression pool to maintain adequate NPSH for the low pressure ECCS pumps, and failure to isolate containment would not alter the model. The licensee also states that containment isolation does not isolate Reactor Building Component Cooling Water (RBCCW) cooling to the recirculation pump seals.

2.2.4 System Dependencies

The Submittal provides tables that delineate system dependencies, and each figure has an accompanying table of notes. [IPE submittal, Tables 4.2.2-1 through 4.2.2-9]

Important asymmetries in train-level system dependencies are indicated. The following types of dependencies were considered: shared component, instrumentation and control, isolation, motive power, direct equipment cooling, area HVAC, operator actions, and environmental and phenomenological effects.

We found the dependency tables and accompanying notes to be useful in our review of the IPE.

2.3 Quantitative Process

This section of the report summarizes our review of the process by which the IPE quantified core damage accident sequences. It also summarizes our review of the data base, including consideration given to plant-specific data, in the IPE. The uncertainty and/or sensitivity analyses that were performed, if any, were reviewed.

2.3.1 Quantification of Accident Sequence Frequencies

The Dresden IPE used the large event tree/small fault tree technique with support state event trees. A mission time of 24 hours was used. Support states were quantified prior to quantification of the PRTs. The PRTs are event trees that model both the front-end and back-end response to a class of accident initiating events. The PRTs are systemic. The fault trees were developed and quantified with the Westinghouse GRAFTER computer code system. [IPE submittal, Section 3.3.5] The truncation limit for sequence quantification was 1E-15.

2.3.2 Point Estimates and Uncertainty/Sensitivity Analyses

Mean values were used for point estimate failure frequencies and probabilities. No uncertainty analyses were performed, but sensitivity analyses were performed for the following three operator actions: [IPE submittal, Section 4.5.4]

- Operator action to supply makeup to the secondary of the isolation condenser,
- Operator action to establish suppression pool cooling, and
- Operator action to depressurize the reactor vessel.

Based on the sensitivity analyses, CDF was shown to be sensitive to increases in failure probabilities for any of these three operator actions.

2.3.3 Use of Plant-Specific Data

The Submittal states that plant-specific data were used based on the time period January 1, 1984 through December 31, 1990. [IPE submittal, Section 4.4.1] Data from both units were combined into one database. Generic data were used when insufficient plant-specific data were available for quantification. Plant-specific data were used to quantify test and maintenance unavailabilities.

A spot check of the plant-specific data from Table 4.4.1-3 of the Submittal was conducted. These data were compared to data used in NUREG/CR 4550 for Peach Bottom. Table 2-1 summarizes the comparison. (Since Quad Cities and Dresden are similar plants operated by the same utility, data from the Quad Cities IPE Submittal are also included in this table.)

Table 2-1. Plant-Specific Data

Component and Failure Mode	Dresden Value ^{(1),(2)} IPE Submittal Table 4.4.1-3	Quad Cities Value ^{(1),(2)} IPE Submittal Table 4.4.1-3	NUREG/CR 4550 Value ^{(1),(2)} Peach Bottom Table 4.9-1
Diesel Generator Fail to Start	1.6E-2/D DG2 5.1E-2/D DG3 3.4E-2/D DG2/3	1.6E-2/D DG1 1.4E-2/D DG2 9.9E-3/D DG ½	3.0E-3/D
Diesel Generator Fail to Run	1.3E-2/H DG2 1.1E-2/H DG3 3.1E-3/H DG2/3	4.3E-3/H DG1 1.8E-3/H DG2 3.2E-3/H DG1/2	2.0E-3/H
HPCI Turbine Fail to Start	6.9E-3/D	1.4E-2/D	3E-2/D
HPCI Turbine Fail to Run	2.2E-4/H ⁽³⁾	2.2E-4/H ⁽³⁾	5E-3/H
LPCI Pump Fail to Start	2.4E-3/D	4.0E-4/D	3E-3/D
LPCI Pump Fail to Run	2.4E-4/H	7.2E-4/H	3E-5/H
Core Spray Pump Fail to Start	3.1E-3/D	3.4E-3/D	3E-3/D
Core Spray Pump Fail to Run	2.4E-4/H	1.8E-3/H	3E-5/H
MOV Fail to Change State (Open/Close)	1.9E-3/D	1.4E-3/D	3E-3/D
Air Operated Valve (AOV) Fail to Change State (Open/Close)	9.4E-4/D	2.0E-3/D	1E-3/D
RCIC Pump Fail to Start	No RCIC System at Dresden	1.7E-2/D	3E-2/D
RCIC Pump Fail to Run	No RCIC System at Dresden	2.2E-4/H ⁽³⁾	5E-3/H

- (1) D is per demand; these values are probabilities.
(2) H is per hour; these values are frequencies.
(3) Generic Data from IEEE- Std. 500.

Based on this spot check of the plant-specific data, the values in the Dresden IPE for component failures are comparable to those values used in other PRAs.

2.3.4 Use of Generic Data

The primary sources used for generic data were: NUREG/CR-2815, NUREG/CR-4550, IEEE Std. 500-1984, and NUREG/CR-2728.

The generic data used in the Dresden IPE are comparable to the data used in other IPE/PRAs.

2.3.5 Common-Cause Quantification

The MGL method was used to model common cause failures. [IPE submittal, Section 3.3.4] The data for common cause failures were taken from EPRI NP-3967.

The Submittal implies that a Dresden-specific evaluation of common cause failure events was performed for certain types of components, and generic common cause failure data were applied to other components. Based on the discussion of this evaluation provided in the Submittal, this evaluation involved screening generic data for applicability and reducing the failure values based on a qualitative assessment of Dresden-specific programs and practices.

The values assigned to common cause failures were reviewed. Table 4.4.3-1 of the Submittal lists the common cause failure data MGL factors. We compared selected beta factors from this table in the Submittal to those used in other IPE/PRAs; Table 2-2 of this report summarizes the comparison. (Quad Cities common cause factors are also included in the table.)

Based on the information from Table 2-2 of this report, the common cause failure factors used in the Dresden IPE are significantly lower than the values used in typical IPE/PRAs.

The licensee stated that the common cause database was screened to make it plant specific, using expert opinion. In our opinion, the licensee has not provided a complete basis for using significantly lower common cause failure values for many important components in the plant, than the values used in almost every other IPE and PRA.

Table 2-2. Common Cause β Factors for 2-of-2 Components

Component	Dresden Value IPE Submittal Table 4.4.3-1	Quad Cities Value IPE Submittal Table 4.4.3-1	Value form Source as Indicated in Footnote
Diesel Generator	0.004	0.002	0.04 ^{(2), (3)} 0.03 ⁽⁴⁾ fail to run {0.006 for fail to start}
MOV	0.01	0.01	0.05 ⁽¹⁾ 0.09 ^{(2), (3)} 0.05 ⁽⁴⁾
Residual Heat Removal (RHR) Pump	Not Provided	0.009	0.1 ^{(1), (2)} 0.2 ⁽³⁾ 0.1 ⁽⁴⁾ fail to start {0.02 for fail to run}
Electromagnetic Relief Valve	0.2	-----	
Safety Relief Valve	0.06	-----	
Safety/Relief Valve	-----	0.2	0.1 ⁽¹⁾ 0.2 ⁽³⁾ 0.3 ⁽⁴⁾ fail to open on pressure {0.1 fail to open on signal}
High Head Pump	0.032	0.009	0.2 ^{(1), (3)}
Core Spray Pump	0.072	0.009	0.2 ⁽³⁾ 0.2 fail to start {0.02 for fail to run}
Service Water Pump	0.0011	0.009	0.03 ^{(1), (3)}
Circuit Breaker	0.054	0.04	0.2 ⁽⁴⁾ for 480 V and higher 0.07 ⁽⁴⁾ for less than 480 V
HPCI/RCIC Turbine Pump	Not Applicable	Not Provided	0.02 fail to start ⁽⁴⁾ {0.009 for fail to run}

(1) NUREG/CR 4550 Peach Bottom, Table 4.9-1.

(2) NUREG/CR 4550 Grand Gulf, Table 4.9-29

(3) NRC IPE Review Guidance, Rev 1, November 1993

(4) PLG Generic Data in Brown Ferry IPE submittal Table 3.3.4-10.

2.4 Interface Issues

This section of the report summarizes our review of the interfaces between the front-end and back-end analyses, and the interfaces between the front-end and human factors analyses. The focus of the review was on significant interfaces that affect the ability to prevent core damage.

2.4.1 Front-End and Back-End Interfaces

If main feedwater is being used to cool the core, then the IPE assumed that loss of containment cooling, failure of containment venting, and containment failure by overpressurization does not impact core cooling with main feedwater.

Without suppression pool cooling and without injection with the SBCS, low pressure ECCS pumps pulling from the suppression pool will lose adequate NPSH before venting pressure is reached. The Submittal states that a procedural change is being implemented to allow long term transfer of LPCI or core spray from the suppression pool to the CST to allow for continued operation of these systems for core cooling with loss of containment cooling. [IPE submittal, Section 4.6.4] The Submittal states that this change will lower the overall CDF by a factor of 5. Additional information provided by the licensee indicates that this change has been implemented at Dresden.

As previously discussed, containment isolation does not result in loss of cooling to the recirculation pump seals.

The PRTs modeled both the front and back end aspects of accident sequences thereby negating the need for binning of core damage sequences into Plant Damage States (PDS) for back end quantification.

2.4.2 Human Factors Interfaces

Based on the front-end review, the following operator actions were noted for possible consideration in the review of the human factors aspects of the IPE:

- Initiation of Suppression Pool Cooling
- Use of SBCS to preserve NPSH from Suppression pool
- Crosstie of AC Power between the two Units
- Initiation of Isolation Condenser mode of cooling
- Manual Depressurization of the Vessel
- Inhibition of ADS and Initiation of Standby Liquid Control during an ATWS.

2.5 Evaluation of Decay Heat Removal and Other Safety Issues

This section of the report summarizes our review of the evaluation of Decay Heat Removal (DHR) provided in the Submittal. Other generic safety issues/unresolved safety issues (GSI/USIs), if they were addressed in the Submittal, were also reviewed.

2.5.1 Examination of DHR

About 69% of the total CDF involved failure of suppression pool cooling: 55% due to hardware failure and 14% due to operator error. With the change to allow for long term alignment of LPCI and core spray to the CST if suppression pool cooling is lost, the contribution of loss of suppression pool cooling to the overall CDF decreases to about 8%.

No vulnerabilities associated with DHR were identified as a result of the IPE.

2.5.2 Diverse Means of DHR

The IPE evaluated the diverse means for DHR, including: use of the power conversion system, the isolation condenser, and ECCS.

Section 4.6.4 of the Submittal provides a description of the ways for providing DHR at the Dresden plant. The Submittal points out that long term use of the isolation condenser requires 125 V DC power. As discussed in Section 2.7 of this report, the licensee has implemented a procedural change which removes the long term dependence of use of the isolation condenser on 125 V DC power. The SBCS system can be used to inject water to maintain adequate NPSHA for low pressure ECCS pumps pulling from the suppression pool if suppression pool cooling is lost. As discussed in Section 2.7 of this report, the licensee has implemented a procedural change to allow long term switchover of LPCI and core spray pumps from the suppression pool to the CST to preserve use of these core cooling systems with loss of adequate NPSHA from the suppression pool.

2.5.3 Unique Features of DHR

Design features at Dresden that impact the Core Damage Frequency (CDF) from loss of DHR are as follows:

- Isolation condenser for shutdown cooling with secondary makeup available from diesel-driven pumps. The isolation condenser has makeup water provided by diesel-driven pumps thereby not requiring DC power for pumping as does a typical Reactor Core Isolation Cooling (RCIC) system; this tends to decrease the CDF from station blackout.

- Automatic isolation of the isolation condenser after loss of 125 V DC power at one unit. The isolation condenser at Dresden automatically isolates on loss of DC power; this tends to increase the CDF from loss of DC power. The licensee has instituted a procedural change to allow continued operation of the isolation condenser after station blackout; this tends to decrease the CDF from station blackout but has no impact on the CDF from loss of DC power.
- Ability to crosstie AC power between the two units. AC power can be crosstied between the two units thereby reducing the CDF from station blackout.
- Shared DC power between the two units. Loss of DC power at one unit results in automatic loss of the isolation condenser. This tends to increase the CDF; loss of DC power at one unit dominated the total CDF. (It is noted that each unit has one train of 125-V DC power that serves both units. Loss of 125-V DC power at one unit causes partial loss of DC power at both units.)
- Net positive suction head (NPSH) margin for low-pressure emergency core cooling system (ECCS) pumps using the suppression pool. The low pressure ECCS pumps lose adequate NPSH from the suppression pool if containment cooling is lost even if containment venting is successful; this tends to increase the CDF.

2.5.4 Other GSI/USIs Addressed in the Submittal

No other GSI/USIs are addressed by the IPE Submittal for Dresden. [IPE submittal, Section 2.6]

2.6 Internal Flooding

This section of the report summarizes our reviews of the process used to model internal flooding and of the results of the analysis of internal flooding.

2.6.1 Internal Flooding Methodology

Much of the analysis for internal flooding was based on the Appendix R Safe Shutdown Report.

The Submittal states that the only flood source which survived qualitative screening is in the units 2 and 3 condensate pump rooms, and that the frequency of this flood is 1.2×10^{-2} per reactor year. This flood was screened from analysis since the Submittal contends that it has the same effect on mitigating systems as does the much more likely initiating event, loss of feedwater. Therefore, no further analysis of flood mitigation was performed.

The methodology for internal flooding evaluated detrimental effects other than submergence; that is, it considered spray induced failures.

2.6.2 Internal Flooding Results

The IPE screened internal flooding from further consideration and did not quantify the CDF from internal flooding.

The licensee states that because of failures due to water spray identified in the Quad Cities IPE, further consideration was given to the effects of water spray in the Dresden IPE. [TER Quad Cities] The additional information states that the re-evaluation indicates that water spray can increase the frequency of the loss of DC power initiating event for Unit 3 but not for Unit 2, thereby increasing the CDF due to loss of DC power for Unit 3 but not for Unit 2. The response states that consideration of loss of DC power at Unit 3 from water spray increases the overall CDF by 48% for Unit 3.

The licensee also discusses the improvements implemented since the date of the Submittal as discussed in Section 2.7 of this report, namely: (1) a procedure to transfer LPCI or core spray from the suppression pool to the CST over the long term if containment cooling is lost, and (2) operator action to prevent automatic isolation of the isolation condenser during station blackout. With these changes, the CDF for Unit 2 is estimated as $3.67E-6$ /year and the CDF for Unit 3 is estimated as $4.36E-6$ /year, the difference being the susceptibility of Unit 3 to loss of DC power from water spray.

2.7 Core Damage Sequence Results

This section of the report reviews the dominant core damage sequences reported in the Submittal. The reporting of core damage sequences- whether systemic or functional- is reviewed for consistency with the screening criteria of NUREG-1335. The definition of vulnerability provided in the Submittal is reviewed. Vulnerabilities, enhancements, and plant hardware and procedural modifications, as reported in the Submittal, are reviewed.

2.7.1 Dominant Core Damage Sequences

The IPE utilized systemic event trees, and reported results using the screening criteria from NUREG 1335 for systemic sequences. [IPE submittal, Section 4.6] Table 4.5.3-1 of the Submittal lists the top 100 core damage sequences.

The total CDF from internal initiating events was $1.85E-5$ /year. Internal flooding was screened from quantification in the original IPE; section 2-7 of this report summarizes the updates to the IPE.

Table 2-3 of this report summarizes the CDF by initiating event.

Table 2-3. CDF By Initiating Event

Initiating Event (IE)	IE Frequency (1/year)	CDF (1/year)	Percent of CDF
Loss of 125-V DC Power at One Unit ¹	8.7E-4	1.1E-5	60.2
Loss of Offsite Power to a Single Unit	9.6E-2	3.7E-6	19.9
Medium LOCA	8.0E-4	1.4E-6	7.5
Loss of Offsite power to Both Units	1.6E-2	1.2E-6	6.9
ATWS	2.3E-4	5.3E-7	2.9
General Transient	7.4	2.7E-7	1.4
Inadvertent Open Relief Valve	7.1E-2	1.8E-7	1.0
Large LOCA	3.0E-4	3.7E-8	0.2
Small LOCA	3.0E-3	6.2E-9	<0.1
Interfacing Systems LOCA	1.1E-4	4.3E-4	<<0.1

¹ Loss of 125 V DC power at one unit causes partial loss of DC power at both units, but does not cause total loss of DC power to either unit since each unit has one train of 125 V DC power that serves both units. However, loss of DC power at one unit results in automatic loss of the isolation condenser. [IPE submittal, Figure 4.2.1.7-6]

The Submittal does not specifically provide the CDF by accident class, but information in Table 1.5.1-2 of the Submittal indicates:

- The plant-specific transient loss of 125-V DC power contributes about 60% to the total CDF
- Loss of offsite power (single or dual) without station blackout contributes about 20% to the total CDF
- LOCAs contribute about 7% to the CDF
- Station blackout contributes about 5% to the CDF

- ATWS contributes about 2% to the CDF
- General transients contribute about 1% to the total CDF.

The top five sequences are summarized in Table 2-4 of this report.

Table 2-4. Top 5 Systemic Core Damage Sequences

Initiating Event and Failures Due to Initiating Event	Subsequent Failures	Sequence Frequency 1/year and CDF Percent
Loss of 125-V DC Power at One Unit [Automatic Isolation of Isolation Condenser]	Suppression Pool Cooling Hardware Fails	8.2E-6 44%
Loss of 125-V DC Power at One Unit [Automatic Isolation of Isolation Condenser]	Operator fails to Initiate Suppression Pool Cooling	1.7E-6 9.0%
Medium LOCA	Operator fails to Initiate Suppression Pool Cooling	5.0E-7 2.7%
Loss of Offsite Power to a Single Unit	Loss of Swing DG and Loss of Bus 24-1 (Station Blackout), Operator fails to provide Makeup to Isolation Condenser	4.3E-7 2.3%
Medium LOCA	HPCI Fails, Operator Fails to Depressurize	3.9E-7 2.1%

Based on the discussions of the dominant core damage sequences, important failures in mitigating systems were: failures of MOVs, operator failure to initiate suppression pool cooling, failure of DG 2/3, operator failure to align to bus 24-1, operator failure to provide makeup to the isolation condenser, operator failure to depressurize, and failure of the HPCI pump.

The IPE calculated that station blackout contributes 5% to the overall CDF of 1.85E-5/year. [IPE submittal, Table 1.5.1-2 and Table 1.6.2-1] This is a low contribution from station blackout compared to that calculated in most BWR IPE/PRA's.

Since the IPE modeled the isolation condenser as being lost during station blackout after the 125-V DC batteries deplete, which was after 4 to 6 hours, the obvious question is "Why is the CDF from station blackout so low in the IPE?". The answer can be deduced by evaluating the major sequences contributing to core damage from station blackout where core damage was due to loss of DC power prior to recovery of offsite power resulting in loss of the isolation condenser. Table 1.6.2-1 of the Submittal lists the dominant station blackout sequences, which in total contribute 5% to the total CDF. Table 4.5.3-1 tabulates the events for these sequences. These dominant sequences can be divided into two classes based on the initiating event: (1) those initiated by dual unit loss of offsite power (LOSP), and (2) those initiated by single unit LOSP. The top three station blackout sequences- 7, 14, and 15- contribute about 4% to the total CDF. Sequences 7 and 14 are both initiated by dual unit LOSP and sequence 15 is initiated by single unit LOSP. (Note that all these sequences include a probability of 1.0 for operators failing to open circuit breakers to prevent loss of the isolation condenser after the batteries deplete; this is event OIC2 in the sequence event listings.) The frequency for dual unit LOSP is lower than that for single unit LOSP ($1.6\text{E-}2/\text{year}$ compared to $9.6\text{E-}2/\text{year}$), but with single unit LOSP the unit with the loss of power can be powered by crosstie of offsite power from the other unit. As indicated in sequence 15, for single unit LOSP the probability for failure to crosstie offsite power from the other unit is $8.78\text{E-}3$. Therefore, the frequency of total LOSP to a unit for the two cases is: (1) $1.6\text{E-}2/\text{year}$ for dual unit LOSP, and (2) about $8.4\text{E-}4/\text{year}$ for single unit LOSP considering crosstie from the other unit. The frequency for LOSP used in other IPEs is higher, typically about $0.05/\text{year}$, due to either: a 1 unit site, inability to crosstie power among units at a multi-unit site, or conservatively modeling LOSP at a multi-unit site as LOSP to all units. The distinction between single and dual unit LOSP and credit for crosstie of power between units for single unit LOSP reduced the contribution of station blackout to overall CDF by about a factor of 3 ($0.05/0.016$). This distinction reflects the plant design.

Another factor that reduces the contribution of station blackout to overall CDF is the relatively low probability used for non-recovery of offsite power within 4 hours. As indicated in the listing of sequences in Table 4.5.3-1 and in the data of Table 4.5.2-1, the probability of non-recovery of offsite power within 4 hours was taken as 0.0205; this is about a factor of 6 lower than the probability used in many PRA/IPEs. [NUREG/CR 6144] [NSAC-147] Figure 2-1 of this report compares the data used for non-recovery of offsite power in the Dresden IPE to typical data. For comparison purposes, the Nine Mile Point 1 IPE used a probability for non-recovery of offsite power of 0.07 at 4 hours. [TER Nine Mile Point 1] The licensee provided the values given in Table 2-5 of this report: [TER, Quad Cities]

Note that the probability of non-recovery by 4 hours used in the Quad Cities IPE is 0.067, a factor of 3.3 higher than that used in the Dresden IPE. Compared to typical data used, the data used in the Dresden IPE for recovery of offsite power results in a lower CDF from station blackout by about a factor of 3 to 6.

Comparison of Data for Recovery of Offsite Power




Figure 2-1. Comparison of Data for Recovery of Offsite Power

Table 2-5. Offsite Power Recovery Data used in Quad Cities IPE Compared to Data in Surry Shutdown PRA

Duration (hrs)	Probability of Not Recovering Offsite Power IPE Value	Probability of Not Recovering Offsite Power [NUREG/CR 6144]
0	1.0	1.0
0.5	0.61	0.61
1	0.37	0.45
2	0.14	0.28
3	0.096	0.18
4	0.067	0.13
5	0.058	0.10
6	0.051	0.08
7	0.044	0.06
8	0.038	0.05
9	0.036	0.04
10	0.033	0.03
11	0.031	-----
12	0.028	-----
13	0.026	-----
14	0.024	-----
15	0.023	0.02
16	0.021	0.02

The licensee provided information with regard to the basis for the relatively low values used for failure to recover offsite power during station blackout. This information included the calculation used to calculate the probabilities for recovery of offsite power in the Dresden IPE. [IPE Responses 2] The calculation used the selection criteria of NUREG-1032 to quantify recovery. The calculation concluded that Dresden is in switchyard configuration group I2, a grid group G1 and a grid reliability/recovery group GR5, a severe weather/recovery group SR7, and an extremely severe weather loss of offsite power frequency group SS1. Consideration of these subgroups places Dresden

in the Offsite Power Cluster Group 1. Data from NUREG-1032 for this cluster group were used with exponential interpolation used to calculate values for times between the data points in the NUREG, and the results were used for the probabilities of not recovering offsite power as a function of time.

We conclude that the CDF from station blackout in the IPE is relatively low for three reasons:

- (1) distinguishing between single and dual unit LOSP
- (2) data used for non-recovery of offsite power by 4 hours
- (3) use of common cause factors for failures of the DGs lower than typically assumed in other IPE/PRA studies (as discussed in section 2.3.5 of this report)

The assumption that seal leakage is negligible during station blackout is a notable assumption used in the IPE. The licensee states that this leakage was considered negligible. [IPE Responses, Question #5] The fact that the IPE did not address vessel leakage during cooling with the isolation condenser during station blackout has little impact on the CDF as calculated in the IPE since the IPE assumed that the isolation condenser is lost due to battery depletion anyway.

The licensee provided information verifies that two changes have been implemented as a result of the IPE: (a) a procedural change to align LPCI and core spray to the CST prior to loss of adequate NPSH, and (b) a procedural change to direct operators to open isolation condenser valve circuit breakers. These changes lower the overall CDF by about 76%, from $1.85E-5$ /year to $4.36E-6$ /year, for Unit 3, and they lower the overall CDF by about 80%, from $1.85E-5$ /year to $3.67E-6$ /year, for Unit 2. [IPE Responses, Pages 13-6 and 13-7 for Question 13] With operator action to open isolation valve circuit breakers, the IPE model assumes that the isolation condensers can indefinitely cool the core during station blackout with no AC or DC power and with no makeup to the vessel, since makeup to the secondary of the isolation condensers can be provided with diesel-driven pumps.

An IPE for another BWR plant with isolation condensers calculated that 63% of the total CDF was due to station blackout. In this IPE, the top two specific accident sequences both lead to core damage due to station blackout with successful operation of the isolation condensers but loss of vessel inventory by leakage; these two sequences alone contributed 28% to the total CDF. [Nine Mile Point 1 IPE] [TER, Nine Mile Point 1]

The IPE distinguished between core damage sequences and sequences denoted as success with accident management (SAM). A SAM sequence is one for which core damage does not occur within the 24 hour mission time, but for which core damage will eventually occur unless accident management actions are taken. The licensee provided information as to the magnitude of the SAM sequences, and the major actions required to prevent core damage for these sequences. The licensee states

that the sum frequency of the SAM sequences is $7.3E-7$ /year. Major actions for recovery include: recovery of the isolation condenser and recovery of standby liquid control.

The licensee states that the estimated CDF for Dresden has changed since the date of the original IPE. With the inclusion of failure of DC power due to water spray effects, the total CDF for Unit 3 increased by 48% but the total CDF for Unit 2 did not change. With implementation of the two procedural actions to: (1) realign LPCI or core spray to the CST if suppression pool cooling is lost and (2) rack out circuit breakers to prevent automatic isolation of the isolation condenser during station blackout, the CDF for both units decreased. With credit for these changes and considering the loss of DC power in Unit 3 due to water spray, the total CDF for Unit 2 is $3.76E-6$ /year and the total CDF for Unit 3 is $4.36E-6$ /year, the difference being due to the CDF from water spray causing loss of DC power in Unit 3.

Loss of DC power at a unit is an important initiating event in terms of overall CDF. The licensee indicated that 15 insights were identified that would either eliminate or ameliorate the effects of loss of 125 V DC; some of these insights will require major modifications and others will only require changes to procedures. One procedural change has been implemented, specifically that dealing with prevention of automatic isolation of the isolation condenser during station blackout. There is a minor modification under active consideration that will eliminate the 125 V DC as an initiating event.

2.7.2 Vulnerabilities

No definition of "Vulnerability" was provided in the Submittal.

Section 7.2 of the Submittal states that there are no vulnerabilities, based on the low overall core damage frequency. [IPE submittal page 7-7]

2.7.3 Proposed Improvements and Modifications

As a result of the IPE, 130 insights were developed and evaluated. [IPE submittal Section 4.7] The evaluations were performed using the NUMARC Severe Accident Closure Guidelines.

The evaluation indicated that the greatest reduction in plant risk could be achieved by implementing a procedure change for realignment of core spray or LPCI to the condensate storage tank, to prevent loss of adequate NPSH for the pumps when pulling from the suppression pool without suppression pool cooling. CECO has decided to implement this procedure at Dresden. This change was credited in the IPE for Quad Cities. The CDF was recalculated with this change in procedure. [IPE submittal Section 6.0] This change lowered the CDF from $1.85E-5$ to $3.75E-6$ per reactor year. [IPE submittal Table 6.2-1]

One other procedural change was planned as a result of the IPE. This procedural change is directed at ensuring operability of the isolation condenser during station blackout. [IPE submittal Section 1.6.3] The change being considered is operator action to open circuit breakers for the 250 V DC operated valves in the isolation condenser piping prior to depletion of DC batteries under station blackout conditions.

The licensee indicates that both of these procedural changes have been implemented at Dresden.

3. CONTRACTOR OBSERVATIONS AND CONCLUSIONS

This section of the report provides our overall evaluation of the quality of the front-end portion of the IPE based on this review. Strengths and shortcomings of the IPE are summarized. Important assumptions of the model are summarized. Major insights from the IPE are presented.

Strengths of the IPE are as follows. The model did recognize the design characteristic of the NPSH margin for the low pressure ECCS pumps such that adequate NPSHA is lost for these pumps pulling from the suppression pool if suppression pool cooling is lost and no compensatory actions are taken.

Shortcomings of the IPE are as follows. (1) The common cause failure factors are much lower than those typically used in IPE/PRA's based on the plant-specific screening evaluation employed. Common cause failures are subtle and it is possible that the licensee has underestimated the potential for common cause failures. (2) Only one plant-specific initiating event was evaluated (loss of 125 V DC power at one unit) and that initiating event dominated the CDF. Other IPE/PRA's address plant-specific initiating events in more detail and retain more than one such event for quantification. The IPE for Dresden has not demonstrated that all potentially important plant-specific initiating events were evaluated. (3) The Dresden IPE assumed that leakage from recirculation pump seals is a negligible effect during station blackout. A recent IPE for a similar plant addressed leakage from recirculation pump seals and it dominated the CDF for that plant. For BWRs with isolation condensers, shutdown cooling can be provided without injection to the vessel, but leakage from failed seals can negate the effectiveness of the isolation condenser.

On the basis of our review, the following aspects of the modeling process have an impact on the overall CDF:

- Quantification of only one plant-specific initiating event. If more plant-specific initiating events had been quantified for core damage- as is typically the case in other IPE/PRA's- the CDF might have been increased.
- Negligible leakage from recirculation pump seals during station blackout. The CDF from station blackout could be higher if the IPE had considered leakage from the recirculation pump seals; seal leakage cannot be isolated during station blackout and cooling with the isolation condenser does not provide makeup to the vessel.
- Credit for maintaining adequate NPSH from the suppression pool after loss of suppression pool cooling by either injecting water to the suppression pool to allow continued use of low-pressure ECCS pumps or by realigning low-pressure ECCS pumps to inject from the Condensate Storage Tank (CST). The CDF was significantly reduced by crediting these compensatory actions to

maintain the use of low pressure ECCS systems following loss of suppression pool cooling.

- The low common cause failure factors used. The use of common cause failure factors lower than typically assumed in other IPE/PRA studies lowered the CDF.

Significant level-one IPE findings are as follows:

- Loss of 125 V DC power at one unit dominates the CDF.
- Station blackout is a low contributor to the CDF.
- Realigning the low pressure ECCS pumps to the CST over the long term after loss of suppression pool cooling substantially decreases the total CDF.

Loss of 125 V DC at one unit results in loss of the ability to use the isolation condenser for core cooling. Station blackout is a low contributor to the total CDF due to the ability to cross tie power between the units, due to the high probability for recovery of offsite power, and due to the low common cause failure factors used for Diesel Generators (DGs). Credit for realigning the low pressure ECCS pumps to the CST over the long term after loss of suppression pool cooling decreases the total CDF by a factor of 5.

4. DATA SUMMARY SHEETS

This section of the report provides a summary of information from our review.

Overall CDF

The total CDF from internal initiating events was 1.85E-5/year. Internal flooding was screened from quantification in the original IPE. (In responses to RAI, the licensee provided summary information of an updated analysis; this update is discussed in previous sections of this report.)

Dominant Initiating Events Contributing to CDF

Initiating Event (IE)	IE Frequency (1/year)	CDF (1/year)	Percent of CDF
Loss of 125 V DC Power at One Unit ¹	8.7E-4	1.1E-5	60.2
Loss of Offsite Power to a Single Unit	9.6E-2	3.7E-6	19.9
Medium LOCA	8.0E-4	1.4E-6	7.5
Loss of Offsite power to Both Units	1.6E-2	1.2E-6	6.9
ATWS	2.3E-4	5.3E-7	2.9
General Transient	7.4	2.7E-7	1.4
Inadvertent Open Relief Valve	7.1E-2	1.8E-7	1.0
Large LOCA	3.0E-4	3.7E-8	0.2
Small LOCA	3.0E-3	6.2E-9	<0.1
Interfacing Systems LOCA	1.1E-4	4.3E-4	<<0.1

Dominant Hardware Failures and Operator Errors Contributing to CDF

Based on the discussions of the dominant core damage sequences, important failures in mitigating systems were: failures of Motor Operated Valves (MOV), operator failure to initiate suppression pool cooling, failure of Diesel Generator (DG) 2/3, operator failure to align to bus 24-1, operator failure to provide makeup to the isolation condenser, operator failure to depressurize, and failure of High Pressure Core Injection (HPCI) pump.

Dominant Accident Classes Contributing to CDF

The plant specific transient loss of 125 V DC power contributes about 60% to the total CDF

Loss of offsite power (single or dual) without station blackout contributes about 20% to the total CDF

LOCAs contribute about 7% to the CDF

station blackout contributes about 5% to the CDF

ATWS contributes about 2% to the CDF

General transients contribute about 1% to the total CDF.

Design Characteristics Important for CDF

The following design features impact the CDF:

- Isolation condenser for shutdown cooling with secondary makeup available from diesel-driven pumps.
- Automatic isolation of the isolation condenser after loss of 125 V DC power at one unit.
- Ability to crosstie AC power between the two units.
- Shared DC power between the two units.
- Net positive suction head (NPSH) margin for low-pressure emergency core cooling system (ECCS) pumps using the suppression pool.

The impact of these design features on the overall CDF is discussed in Section 1.2 of this report.

Modifications

The evaluation indicated that the greatest reduction in plant risk could be achieved by implementing a procedure change for realignment of core spray or LPCI to the

condensate storage tank, to prevent loss of adequate NPSHA for the pumps when pulling from the suppression pool without suppression pool cooling. CECO has decided to implement this procedure at Dresden. This change was credited in the IPE for Quad Cities. The CDF was recalculated with this change in procedure. [IPE submittal Section 6.0] This change lowered the CDF from 1.85E-5 to 3.75E-6 per reactor year. [IPE submittal Table 6.2-1]

One other procedural change is being considered as a result of the IPE. This procedural change is directed at ensuring operability of the isolation condenser during station blackout. [IPE submittal Section 1.6.3] The change being considered is operator action to open the 250 V DC operated valves in the isolation condenser piping prior to depletion of DC batteries under station blackout conditions.

The licensee responses to our questions indicates that both of these procedural changes have been implemented at Dresden. [IPE Responses]

Other USI/GSIs Addressed

No other GSI/USIs are addressed by the IPE Submittal for Dresden.

Significant PRA Findings

Significant findings on the front-end portion of the IPE are as follows:

Significant level-one IPE findings are as follows:

- Loss of 125-V DC power at one unit dominates the CDF.
- Station blackout is a low contributor to the CDF.
- Realigning the low pressure ECCS pumps to the CST over the long term after loss of suppression pool cooling substantially decreases the total CDF.

Loss of 125 V DC at one unit results in loss of the ability to use the isolation condenser for core cooling. Station blackout is a low contributor to the total CDF due to the ability to cross tie power between the units, due to the high probability for recovery of offsite power, and due to the low common cause failure factors used for Diesel Generators (DGs). Credit for realigning the low pressure ECCS pumps to the CST over the long term after loss of suppression pool cooling decreases the total CDF by a factor of 5.

REFERENCES

- [CL 88-20] *Individual Plant Examination For Severe Accident Vulnerabilities - 10 CFR 50.54 (f)", Generic Letter 88.20, U.S. Nuclear Regulatory Commission, November 23, 1988
- [NUREG-1335] *Individual Plant Examination Submittal Guidance", NUREG-1335, U. S. Nuclear Regulatory Commission, August, 1989
- [IPE] Dresden IPE Submittal January 28, 1993
- [IPE Responses] Letter from J.D. Peter Piet CECo to NRC, October 28, 1994
- [IPE Responses 2] Letter from John Schrage CECo to NRC, December 23, 1994
- [UFSAR] Updated Final Safety Analysis Report for Dresden
- [NUREG/CR 4550 Peach Bottom] "Analysis of Core Damage Frequency: Peach Bottom, Unit 2 Internal Events", NUREG/CR-4550, Vol. 4. Rev. 1, Part 1, August 1989.
- [IPE Quad Cities] IPE Submittal for Quad Cities
- [Nine Mile Point 1 IPE] IPE Submittal for Nine Mile Point 1
- [TER, Quad Cities] SEA TER for Quad Cities IPE Submittal
- [TER, Hatch] SEA TER for Hatch IPE Submittal
- [TER, Nine Mile Point 1] SEA TER for Nine Mile Point 1
- [NUREG/CR 6144] *Evaluation of Potential Severe Accidents during Low Power and Shutdown Operations at Surry, Unit 1," NUREG/CR-6144, Vol. 2, Part 1A, June 1994.

ENCLOSURE 3

DRESDEN UNITS 2 & 3 INDIVIDUAL PLANT EXAMINATION
TECHNICAL EVALUATION REPORT

(BACK-END)