OPTIONAL PORM NO. 10
MAY 1982 ADITION
GSA GION. REG. NO. 27
UNITED STATES GOVERNMENT

Memorandum

R. S. Boyd, Assistant Director

DATE: August 7, 1967

TO: R. S. Boyd, Assistant Director for Reactor Projects, DRL

(THRU) R. L. Tedesco, Chief, RPB#2

FROM : V. Stello V5

Reactor Project Branch #2, DRL

SUBJECT: ACRS MEETING SUMMARY -- O"STER CREEK, JULY 27 AND 28, 1967

DOCKET NO. 50-219 Regulatory Suppl File Cy.

A meeting was held on July 27, 1967, with representatives of General Electric, Burns & Roe, Jersey Central and the staff. Attendees at this meeting and those for the Subcommittee meeting on July 28, 1967, are attached. The purpose of the meeting was to discuss the contents of our July 14, 1967 letter from P. A. Morris and prepare for the Subcommittee meeting.

The following matters, discussed in the letter now appear to be resolved:

- 1. Both the AC and DC on-site electrical systems would meet the single failure criterion.
- 2. All four electronomagnetic relief valves will be programmed for automatic operation.
- 3. High drywell pressure will be added as an initiation signal for actuation of the core spray signal. The instrumentation will be designed so that high drywell pressure or low pressure vessel water level will actuate the core spray system.

We cannot establish a position on the remaining items of the July 14 letter until we receive the cetails of the supporting data. One of the items, in essence a request for a high head system, was discussed in detail. General Electric has performed a "realistic" calculation for the small break region wherein the maximum temperature and percentage of fuel rod perforations for small breaks are considerably lower than those reported in Amendment No. 5. If the supporting calculations are acceptable, we may be in a position to accept the ECCS for Oyster Creek without a high head system.

In a closed session between the ACRS and DRL, Dr. McKee indicated that another subcommittee on ECCS (and possibly other related areas) would be required before the subcommittee could recommend bringing the Oyster Creek Plant before the full committee. He also indicated that he wanted resolution of all of the items in the July 14 letter as well as a statement of differences for the dose calculations performed by DRL and GE. We agreed to respond to this request. Dr. McKee told Jersey Central that another

Buy U.S. Savings Bonds Regularly on the Payroll Savings Plan

9509220069 950824 PDR FOIA DEKOK95-258 PDR A123

subcommittee meeting on ECCS would be required and encouraged Jersey Central to respond formally to all of the items in the July 14 letter. Jersey Central did agree to respond formally by August 14, 1967.

Distribution: Suppl. DRL Reading

RPB#2 Reading Orig: V. Stello

R. Tedesco

M. Rosen

I. Spickler

J. Sears, CO

Compliance (2)

ATTENDEES AT ACRS STAFF MEETING THURSDAY, JULY 27, 1967

Jersey Central Power & Light Company

G. H. Ritter

J. V. Neely

D. R. Rees (p.t.)

I. R. Finfrock

T. J. McCluskey

D. E. Hetrick

L. H. Roddis, Jr. (p.t.)

W. W. Lowe - Consultant

General Electric Company

R. A. Huggins

P. W. Ianni

R. V. Poe

A. J. Mc Crocklin

W. Williams

T. E. Bloom

R. McWhorter

E. M. Kratz

Burns and Roe, Inc.

E. Nobile

G. A. Lari

J. C. Archer

AEC, DRL

V. Stello

R. Tedesco

R. Boyd

M. Rosen

I. Spickler

J. Sears CO

L. Kornblith

ACRS

C. W. Zabel

S. H. Bush

S. H. Hanauer

H. G. Mangelsdorf

J. E. Mckee

A. A. O'Kelly

M. Gaske