Docket No. 5C-219

Jersey Central Power & Light Company Madison Avenue at Punch Bowl Road Morristown, New Jersey 079/0

Attention: Mr. John E. Ligan Vice President

Gentlemen:

At the meeting held on January 26, 1968, with representatives of your Company, Burns and Roe and the General Electric Company, we discussed the results of our review of Amendment No. 27 in regard to the overall Oyeter Creek quality assurance program. We indicated at this meeting that additional information would be required to permit us to continue our review of the program. The type of information required was discussed at the meeting and generally concerns the complete organizational structure and the responsibility for the efforts of the various subcontractors.

For all safety associated systems and structures, the organization(s) responsible for establishing the functional requirements and the equipment specifications or drawings including specifications and procedures for shipment, storage and installation, inspection and procedures for shipment, storage and installation, inspection and procedures testing should be identified. Quality control systems established and functions performed by the organization(s) involved, during such of the above phases should be discussed. The quality control systems (inspection) should be described with respect to scope, number of people involved and authority.

An organisation chart which denotes the quality assurance and quality control roles of various contractors including General Electric, Buras and Ene, Combustion, CB&I, Ebasco, Avery and consultants should be provided. Based on this chart, the machanism by which the quality assurance and control measures, needs and devices were communicated to all parties concerned should be described. In particular, the method wood to incorporate changes in functional requirements and/or specifications or physical changes to plant systems should be

OFFICE | 9509220138 950824

PDR FDIA DEKOK95-258 PDR

| DATE | DEKOK95-258 PDR | DEK

9509220138

to effectively approve or sign off on a particular component, system or structure should be identified.

We will be available to discuss and clarify any of the foregoing with you.

Sincerely yours,

ORIGINAL SIGNED BY Peter A. Morris

Peter A. Morris, Director Division of Reactor Licensing

cc: George F. Trowbridge, Esquire Shaw, Pittman, Potts, Trowbridge & Madden The Berr Building 910 - 17th Street, N. W. Washington, D. C. 20006

Distribution:

AEC Doc. Room

Formal

Suppl.

REG Reading

DRL Reading

RPB-2 Reading

Orig: RLTedesco

M. M. Mann

R. S. Boyd

L. Kornblith (2)

H. Steele

bcc: J. R. Buchanan, ORNL

W. McCool, USAEC, Japan

OFFICE DRL: RP. DRL: RT RLTedesdo 2/5/68 DATE &