

ENCLOSURE 1

NOTICE OF VIOLATION

Virginia Electric and Power Company
Surry

Docket Nos. 50-280, 281
License Nos. DPR-32, 37

The following violations were identified during an inspection conducted on May 29 - June 1, 1984. The Severity Levels were assigned in accordance with the NRC Enforcement Policy (10 CFR Part 2, Appendix C).

10 CFR 20.311(d)(3) requires that any licensee who transfers radioactive waste to a land disposal facility conduct a quality control program to assure compliance with 10 CFR 61.55 and 61.56. The quality control program must include audits.

Contrary to the above, the requirement to conduct a quality control program which included audits was not met, in that no audits which evaluated licensee compliance with the requirements of 10 CFR 61 had been performed or scheduled.

This is a Severity Level V violation (Supplement IV).

Pursuant to 10 CFR 2.201, you are required to submit to this office within 30 days of the date of this Notice, a written statement or explanation in reply, including: (1) admission or denial of the alleged violations; (2) the reasons for the violations if admitted; (3) the corrective steps which have been taken and the results achieved; (4) corrective steps which will be taken to avoid further violations; and (5) the date when full compliance will be achieved.

Security or safeguards information should be submitted as an enclosure to facilitate withholding it from public disclosure as required by 10 CFR 2.790(d) or 10 CFR 73.21.

JUL 03 1984

Date: _____