



DUKE POWER

September 18, 1995

U.S. Nuclear Regulatory Commission
Attention: Document Control Desk
Washington, D.C. 20555

Subject: Catawba Nuclear Station, Unit 2
Docket No. 50-414
Request for Relief Number 95-04
Reply to NRC Request for Additional Information

- References:
- 1) Letter from W.R. McCollum to NRC dated July 25, 1995
 - 2) Electronic communication from R.E. Martin to Z.L. Taylor dated September 11, 1995

Gentlemen:

In response to R.E. Martin's Request for Additional Information (Reference 2), Catawba offers the following reply:

Catawba is requesting the referenced relief only for Unit 2 for the first ten-year inservice inspection interval. For the Unit 2 first ten-year inservice inspection interval, the applicable ASME Code edition is the 1980 Edition through Winter 1981 addenda. Catawba is not requesting corresponding relief for Unit 1 because all Code-required inspections for Unit 1 had been previously completed during its first ten-year inservice inspection interval.

Regarding our submittal of a Unit 1 examination boundary drawing in Reference 1, it was indicated in Reference 1 that a corresponding Unit 2 drawing was in the course of preparation when Relief Request 95-04 was submitted and that the Unit 1 and Unit 2 examination boundaries are identical. No corresponding Unit 2 drawing is available at present. In addition, FSAR Figure Number 6-116 is a flow diagram of the containment valve injection water system (NW). Although the FSAR figure is labelled for Unit 1, it is equally applicable to Unit 2.


250019

A047.1/0

Document Control Desk
Page 2
September 18, 1995

If you have any questions pertaining to this relief request, please call L.J. Rudy at (803) 831-3084.

Very truly yours,



W.R. McCollum

LJR/s

xc:
S.D. Ebnetter, Regional Administrator
Region II

R.J. Freudenberger, Senior Resident Inspector

R.E. Martin, Senior Project Manager
ONRR

Document Control Desk

Page 3

September 18, 1995

bxc:

L.J. Rudy

Z.L. Taylor

J.C. Bigham

J.O. Barbour

NCMPA-1

NCEMC

PMPA

SREC

Document Control File 801.01

Group File 801.01

ELL-EC050