

TABLE 2.2-1 (Continued)

REACTOR TRIP SYSTEM INSTRUMENTATION TRIP SETPOINTS

FUNCTIONAL UNIT	TRIP SETPOINT	ALLOWABLE VALUE
12. Steam Generator Water Level Low-Low		
a. Unit 1	<del> <math>\geq 17\%</math> of span from 0% to 30% RTP* increasing linearly to <math>\geq 40.0\%</math> of span from 30% to 100% RTP*                 </del> $\geq 10.7\%$ of narrow range span	<del> <math>\geq 15.3\%</math> of span from 0% to 30% RTP* increasing linearly to <math>\geq 26.3\%</math> of span from 30% to 100% RTP*                 </del> $\geq 9\%$ of narrow range span
b. Unit 2	$\geq 36.8\%$ of narrow range span	$\geq 35.1\%$ of narrow range span
13. Undervoltage - Reactor Coolant Pumps	$\geq 77\%$ of bus voltage (5082 volts) with a 0.7s response time	$\geq 76\%$ (5016 volts)
14. Underfrequency - Reactor Coolant Pumps	$\geq 56.4$ Hz with a 0.2s response time	$\geq 55.9$ Hz
15. Turbine Trip		
a. Stop Valve EH Pressure Low	$\geq 550$ psig	$\geq 500$ psig
b. Turbine Stop Valve Closure	$\geq 1\%$ open	$\geq 1\%$ open
16. Safety Injection Input from ESF	N.A.	N.A.

\*RTP = RATED THERMAL POWER

CATAMBA - UNITS 1 & 2

2-5

Amendment No. 107 (Unit 1)  
Amendment No. 101 (Unit 2)

Attachment 1

9509260004 950918  
PDR ADDCK 05000413  
PDR

TABLE 2.2-1 (Continued)  
TABLE NOTATIONS (Continued)

NOTE 1: (Continued)

$T' < \overset{581.5^\circ F}{-590.0^\circ F}$  (Nominal  $T_{avg}$  allowed by Safety Analysis);

$K_3$  = Overtemperature  $\Delta T$  reactor trip depressurization setpoint penalty coefficient as presented in the Core Operating Limits Report;

$P$  = Pressurizer pressure, psig;

$P'$  = 2235 psig (Nominal RCS operating pressure);

$S$  = Laplace transform operator,  $s^{-1}$ ;

and  $f_1(\Delta I)$  is a function of the indicated difference between top and bottom detectors of the power-range neutron ion chambers; with gains to be selected based on measured instrument response during plant STARTUP tests such that:

(i) For  $q_t - q_b$  between the "positive" and "negative"  $f_1(\Delta I)$  breakpoints as presented in the Core Operating Limits Report;

$f_1(\Delta I) = 0$ , where  $q_t$  and  $q_b$  are percent RATED THERMAL POWER in the top and bottom halves of the core respectively, and  $q_t + q_b$  is total THERMAL POWER in percent of RATED THERMAL POWER;

(ii) For each percent  $\Delta I$  that the magnitude of  $q_t - q_b$  is more negative than the  $f_1(\Delta I)$  "negative" breakpoint presented in the Core Operating Limits Report, the  $\Delta T$  Trip Setpoint shall be automatically reduced by the  $f_1(\Delta I)$  "negative" slope presented in the Core Operating Limits Report; and

(iii) For each percent  $\Delta I$  that the magnitude of  $q_t - q_b$  is more positive than the  $f_1(\Delta I)$  "positive" breakpoint presented in the Core Operating Limits Report, the  $\Delta T$  Trip Setpoint shall be automatically reduced by the  $f_1(\Delta I)$  "positive" slope presented in the Core Operating Limits Report.

NOTE 2: The channel's maximum Trip Setpoint shall not exceed its computed Trip Setpoint by more than 4.5% of Rated Thermal Power.

TABLE 2.2-1 (Continued)  
TABLE NOTATIONS (Continued)

NOTE 3: (Continued)

- $K_6$  = Overpower  $\Delta T$  reactor trip heatup setpoint penalty coefficient as presented in the Core Operating Limits Report for  $T > 590.8^\circ F$  and  $K_6 = 0$  for  $T \leq 590.8^\circ F$ .
- $T$  = As defined in Note 1,
- $T''$  = Indicated  $T_{avg}$  at RATED THERMAL POWER (Calibration temperature for  $\Delta T$  instrumentation,  ~~$< 590.8^\circ F$~~ ,  $585.7^\circ F$ ),
- $S$  = As defined in Note 1.

and  $f_2(\Delta I)$  is a function of the indicated differences between top and bottom detectors of the power-range neutron ion chambers; with gains to be selected based on measured instrument response during plant startup tests such that:

- (i) for  $q_t - q_b$  between the "positive" and "negative"  $f_2(\Delta I)$  breakpoints as presented in the Core Operating Limits Report;  $f_2(\Delta I) = 0$ , where  $q_t$  and  $q_b$  are percent RATED THERMAL POWER in the top and bottom halves of the core respectively, and  $q_t + q_b$  is total THERMAL POWER in percent of RATED THERMAL POWER;
- (ii) for each percent  $\Delta I$  that the magnitude of  $q_t - q_b$  is more negative than the  $f_2(\Delta I)$  "negative" breakpoint presented in the Core Operating Limits Report, the  $\Delta T$  Trip Setpoint shall be automatically reduced by the  $f_2(\Delta I)$  "negative" slope presented in the Core Operating Limits Report; and
- (iii) for each percent  $\Delta I$  that magnitude of  $q_t - q_b$  is more positive than the  $f_2(\Delta I)$  "positive" breakpoint presented in the Core Operating Limits Report the  $\Delta T$  Trip Setpoint shall be automatically reduced by the  $f_2(\Delta I)$  "positive" slope presented in the Core Operating Limits Report.

NOTE 4: The channel's maximum Trip Setpoint shall not exceed its computed Trip Setpoint by more than 3.0% (Unit 1) and 3.3% (Unit 2) of Rated Thermal Power.

Proposed revision to Technical Specification Table 2.2-1 Reactor Trip System  
Instrumentation Trip Setpoints

**In Note 1**

change " $T' \leq 590.8$  ° F (Nominal  $T_{AVG}$  allowed by Safety Analysis)"

to " $T' \leq 585.1$  ° F, (Nominal  $T_{AVG}$  allowed by Safety Analysis)"

**In Note 3**

change " $T'' =$  Indicated  $T_{AVG}$  at RATED THERMAL POWER (Calibration temperature for  $\Delta T$  instrumentation,  $\leq 590.8$  °F)"

to " $T'' =$  Indicated  $T_{AVG}$  at RATED THERMAL POWER (Calibration temperature for  $\Delta T$  instrumentation,  $\leq 585.1$  °F)"

Technical Justification

The values for  $T'$  and  $T''$  are defined as  $T_{AVG}$  Allowed by Safety Analysis and Reference  $T_{AVG}$  at RATED THERMAL POWER respectively. In Note 1 and 3 of Table 2.2-1. When the steam generators are replaced at Catawba Unit 1, programmed full power  $T_{AVG}$  will be changed from 590.8 °F to 585.1 °F. This temperature was chosen based on returning the secondary side steam pressure to the original value after replacement of the steam generators. 585.1 °F was the assumed value for nominal full power  $T_{AVG}$  in all applicable safety analyses related to replacement of the steam generators.

No Significant Hazards Analysis

The following analysis, required by 50.91, concludes that the proposed amendment will not involve significant hazards considerations as defined by 10 CFR 50.92.

10 CFR 50.92 states that a proposed amendment involves no significant hazards considerations if operation in accordance with the proposed amendment would not:

- (1) Involve a significant increase in the probability or consequences of an accident previously evaluated; or
- (2) Create the possibility of a new or different kind of accident from any accident previously evaluated; or

- (3) Involve a significant reduction in a margin of safety.

This proposed change to the Technical Specifications does not involve a significant increase in the probability or consequences of an accident previously evaluated. Changing the value for  $T_{AVG}$  in Notes 1 and 3 of Table 2.2-1 will update the value to agree with the  $T_{AVG}$  assumed in the applicable safety analyses for replacement of the steam generators. Acceptable results were obtained for all required reanalyses. The probability of an accident will not be significantly affected by operation with the new  $T_{AVG}$  value, because all equipment will be operated within acceptable design limits. The consequences of previously evaluated accidents which are affected by this change have been evaluated, and have been determined to be within acceptable limits.

This proposed change will not create the possibility of a new or different kind of accident from any previously evaluated. This change does not change the physical configuration of the plant, and all analyses which are affected by replacement of the steam generators have been determined to have acceptable results assuming this value for  $T_{AVG}$ .

This proposed change to the Technical Specifications will not involve a significant reduction in the margin of safety. All safety analyses which were affected by replacement of the steam generators assumed this value for  $T_{AVG}$  and the results were determined to be within previously acceptable limits.

Attachment 3