

Georgia Power Company
40 Inverness Center Parkway
Post Office Box 1295
Birmingham, Alabama 35201
Telephone 205 877-7122

C. K. McCoy
Vice President, Nuclear
Vogtle Project



September 22, 1995

LCV-0655

Docket Nos. 50-424
50-425

TAC- M92131
M92132

U. S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, D. C. 20555

Gentlemen:

**VOGTLE ELECTRIC GENERATING PLANT
PROPOSED CONVERSION OF THE UNIT 1 AND UNIT 2
TECHNICAL SPECIFICATIONS BASED ON NUREG-1431**

By letter dated May 1, 1995, (LCV-0603) Georgia Power Company (GPC) proposed to amend the Vogtle Electric Generating Plant (VEGP) Unit 1 and Unit 2 Technical Specifications. The proposed amendment would, in part, convert the existing VEGP TS requirements to the format and content of NUREG-1431, the Westinghouse improved Standard Technical Specifications. Subsequent to our May 1, 1995, submittal, GPC identified additional changes that would render the proposed conversion closer to NUREG-1431. Specifically, GPC noted that with respect to unborated water source isolation valves, NUREG-1431 (LCO 3.9.2) simply specifies that each valve used to isolate unborated water sources shall be closed and secured in position. The equivalent existing VEGP TS requirements specify that valves 1208-U4-175, 176, 177, and 183 be closed and secured in position. GPC proposes to modify our submittal to more closely conform to NUREG-1431.

The enclosed changed pages contain the information necessary to modify our May 1, 1995, submittal to reflect the subject change. Instructions are provided to facilitate insertion of the changed pages into the original submittal.

Sincerely,


C. K. McCoy

000014

9509260096 950922
PDR ADDCK 05000424
P PDR

Handwritten initials: A001
11

U. S. Nuclear Regulatory Commission
LCV-0655
Page 2

CKM/NJS

Enclosure

xc: Georgia Power Company
Mr. J. B. Beasley, Jr.
Mr. M. Sheibani
NORMS

U. S. Nuclear Regulatory Commission
Mr. S. D. Ebnetter, Regional Administrator
Mr. L. L. Wheeler, Licensing Project Manager, NRR
Mr. C. R. Ogle, Senior Resident Inspector, Vogtle

The following page replaces the
corresponding page behind the
Enclosure 1 tab for Chapter 3.3, Volume 3.