

**PHILADELPHIA ELECTRIC COMPANY**

2301 MARKET STREET

P.O. BOX 8699

PHILADELPHIA, PA. 19101

(215) 841-4000

September 18, 1984

Docket Nos. 50-352  
50-353

Mr. A. Schwencer, Chief  
Division of Licensing  
Licensing Branch No. 2  
U.S. Nuclear Regulatory Commission  
Washington, DC 20555

Subject: Limerick Generating Station  
Information for Emergency Preparedness Branch

Reference: Meeting between PECO and NRC  
September 14, 1984

Dear Mr. Schwencer:

At the above referenced meeting, the NRC requested PECO to provide the following information:


1. The Limerick Generating Station Emergency Plan implementing procedure EP-317, Determination of Protective Action Recommendations, will be revised prior to fuel load to incorporate the information in IE Notice 83-28. This information is currently reflected in procedure EP-105, General Emergency Response. EP-317 will be revised to include the same information.
2. Regarding the LGS public alert/notification, Philadelphia Electric Company has the capability to activate the siren system and to contact radio stations from the LGS Technical Support Center. The Emergency Director, located at the Technical Support Center, would receive direction from the Site Emergency Coordinator to activate the siren system and contact the radio stations. In the event the Site Emergency Coordinator was unavailable, the Emergency Director would be able to direct these actions to be taken. An Emergency Plan implementing procedure describing this process will be prepared prior to initial criticality.

8409250205 840918  
PDR ADOCK 05000352  
F PDR

A045  
1/0

If you have any questions regarding these items, please do not hesitate to contact us.

Very truly yours,



S. L. Daltroff  
Vice President  
Electric Production Dept.

cc: Document Control Desk  
U.S. Nuclear Regulatory Commission  
Washington, DC 20555

J. T. Wiggins, Site Inspector

See attached Service List

bcc: V. S. Boyer  
J. S. Kemper  
M. J. Cooney  
E. J. Bradley  
R. H. Moore  
G. M. Leitch  
R. H. Logue  
R. A. Kankus  
W. J. Knapp  
J. M. Corcoran  
C. Brenner  
DAC

RAK/cmb