Commonwealth Edison Company Quad Cities Generating Station 22710 206th Avenue North Cordova, IL 61242-9740 Tel 309-654-2241

LWP-95-086

September 21, 1995

ComEd

U.S. Nuclear Regulatory Commission Document Control Desk Washington, DC 20555

Reference: Quad Cities Nuclear Power Station Docket Number 50-265, DPR-30, Unit Two

Enclosed is Licensee Event Report (LER) 95-005, Revision 00, for Quad Cities Nuclear Power Station.

This report is submitted in accordance with the requirements of the Code of Federal Regulations, Title 10, Part 50.73(a)(2)(v)(D). The licensee shall report any event or condition that alone could have prevented the fulfillment of the safety function of structures or systems than are needed to mitigate the consequences of an accident.

The following commitments are being made by this letter.

The following revisions will be incorporated into the vendor recommended EHC lineup instructions currently utilized at Quad Cities Station to calibrate the EHC system:

- Proper method for setting up the 3 psig "effective" pressure setpoint bias between the pressure regulators.
- Inclusion of the 500 mS minor lag time constant on the SLRC circuit boards.

If there are any questions or comments concerning this letter, please refer them to Nick Chrissotimos, Regulatory Assurance Administrator at 309-654-2241, ext. 3100.

Respectfully,

COMMONWEALTH EDISON COMPANY
QUAD CITIES NUCLEAR POWER STATION

L. W. Pearce Station Manager

LWP/NC/plm

Enclosure

cc: J. Schrage C. Miller INPO Records Center NRC Region III

D. B. Cock for

0.2004 MGR108695.LWP

9510030164 950921 PDR ADDCK 05000265 S PDR JE38.

Licensee Event Report Reviewer Assignment Form

Revised 12/01/94

Subject: Unit Two Automatic Reactor Scram during EHC Prescure Regulator Fail-Over		
esting.		
ignatures of reviewers indicating review and	approval of item:	
ystems Eng. Supv: Storen K Owy 9:	-22-95 Date	Date
Operating Eng.: B& Swalesma 9	-22-95 Date	Date
DyBn) 19.	21-95 Date	Date
D. W. Cook 19/	22/95 Date	/ Date