

Mr. Gary J. Taylor
 Vice President, Nuclear Operations
 South Carolina Electric & Gas Company
 Virgil C. Summer Nuclear Station
 Post Office Box 88
 Jenkinsville, South Carolina 29065

September 29, 1995

SUBJECT: EVALUATION OF THE SECOND TEN-YEAR INTERVAL INSPECTION PROGRAM PLAN
 REQUEST FOR RELIEF NO. RR-02, VIRGIL C. SUMMER NUCLEAR STATION
 (VCSNS), UNIT 1 (TAC NO. M88860)

Dear Mr. Taylor:

The staff, with technical assistance from its contractor, the Idaho National Engineering Laboratory (INEL), has reviewed and evaluated the information provided by your company in letters dated February 17, 1994, and April 27, 1995, related to the second ten-year interval inservice inspection program plan Request for Relief No. RR-02 for VCSNS. The staff concluded that your proposed alternative to the Code requirements is authorized pursuant to 10 CFR 50.55a(a)(3)(i), provided that you schedule a minimum of 10% of all integral attachments in non-exempt Code Class 1, 2, and 3 systems.

The staff's and INEL's evaluations and conclusions are contained in the enclosures. The February 17, 1994 letter also submitted a relief request (RR-06) regarding snubbers. This request was previously granted in a July 29, 1994 letter. Therefore, this completes all staff action associated with the February 17, 1994, and April 27, 1995 letters and closes TAC No. M88860.

Sincerely,

Original signed by D. LaBarge for
 Frederick J. Hebdon, Director
 Project Directorate II-3
 Division of Reactor Projects - I/II
 Office of Nuclear Reactor Regulation

Docket No. 50-395

Enclosures: 1. Safety Evaluation
 2. Technical Letter Report

cc w/enclosures: See next page

DISTRIBUTION

Docket File	E. Merschhoff
PUBLIC	T. McLellan
SUM Rdg.	J. Zwolinski
W. Russell/F. Miraglia	R. Zimmerman
S. Varga	ACRS(4)
G. Hill (2)	G. Tracy
OGC	

DOCUMENT NAME: G:\SUM88860.REL

To receive a copy of this document, indicate in the box: "C" = Copy without attachment/enclosure "E" = Copy with attachment/enclosure "N" = No copy

OFFICE	PD11-3/LA	<input checked="" type="checkbox"/> PD11-3/PM	<input checked="" type="checkbox"/> OGC <i>216</i>	<input checked="" type="checkbox"/> PD11-3/D	<input checked="" type="checkbox"/>
NAME	B. Clayton <i>BC</i>	S. Dember <i>S. Dember</i>	<i>CHOLLER</i>	F. Hebdon <i>F. Hebdon</i>	
DATE	09/20/95	09/20/95	09/28/95	09/29/95	

*RF01
11*

9510040186 950929
 PDR ADOCK 05000395
 PDR

OFFICIAL RECORD COPY

NRC FILE CENTER COPY