

H₂ COMBUSTION TESTING IN A 1/20TH
SCALE MODEL OF A BWR MARK III CONTAINMENT

BY

JOHN HOSLER

NUCLEAR SAFETY ANALYSIS CENTER
NUCLEAR POWER DIVISION
ELECTRIC POWER RESEARCH INSTITUTE

PRESENTATION TO
U.S. NUCLEAR REGULATORY COMMISSION
BETHESDA, MARYLAND

29 JUNE 1983

H₂ COMBUSTION TESTING IN A 1/20TH SCALE MODEL
A BWR MARK III CONTAINMENT

- OBJECTIVE/SCOPE
- SCALING LAWS APPLIED
- TEST FACILITY DESCRIPTION
- TEST RESULTS
- SUMMARY

H₂ COMBUSTION TESTING IN A 1/20TH -
SCALE MODEL OF A MARK III CONTAINMENT

- CONTRACTOR
 - ACUREX CORPORATION
- OBJECTIVES
 - PROVIDE A VISUAL RECORD OF GLOBAL H₂ COMBUSTION BEHAVIOR IN A FULL 360° MODEL OF A MK III CONTAINMENT
 - PROVIDE DATA TO ESTIMATE THERMAL ENVIRONMENT (TEMPERATURES, RADIANT HEAT FLUX) DUE TO H₂ COMBUSTION AS A CONTINUOUS FLAME
- SCOPE
 - 41 TESTS PERFORMED INCLUDING TESTS TO ASSESS THE EFFECTS OF VARIATIONS IN:
 - TOTAL H₂ RELEASE RATE
 - BLOCKAGES/IN WETWELL ANNULUS
 - SPARGER VS. VENT RELEASE
 - NUMBER/LOCATION OF ACTIVE SPARGERS
 - POOL TEMP
 - HEAT LOSS FROM OUTER CONT. SHELL
- STATUS
 - TESTING COMPLETED 6/23/83
 - TEST REPORT BY 10/1/83

JH 6/83

SCALING LAWS APPLIED

- FROUDE MODELLING
 - APPLICABLE TO TURBULENT BUOYANTLY CONTROLLED DIFFUSION FLAMES

- RESULTING SCALING RELATIONS

LENGTH (S)¹

H₂ RELEASE RATE (S)^{5/2}


TIME (S)^{1/2}

VELOCITY (S)^{1/2}

•TEMPERATURE (S)[•]

CONCENTRATION (S)[•]



WHERE S = 1/20 FOR A 1/20TH SCALE MODEL




1/20TH SCALE Mk III CONTAINMENT COMBUSTION
VISUALIZATION TEST FACILITY

J. HOSLER
6/83

PLAN VIEW OF 1/20TH
SCALE VISUALIZATION FACILITY





J. HOSLER
6/83




- MIXING OF VIDEO FROM EACH OF THE 4 CAMERAS ON A SINGLE TAPE WILL ALLOW CONTINUOUS VIEWING OF THE FULL 360° SIMULTANEOUSLY

J. HOSLER
6/83


REVISIONS				
ZONE	LTR	DESCRIPTION	DATE	APPROVED




SECTION A
TYP. SECTION +4' 0" & +6' 0"



SECTION B
TYP. SECTION +6' 0" & +8' 0"



SECTION C



ELEVATION VIEW

D
C
B
A


NO.	QTY. REQ'D.	ITEM NO.	QUANTITY	PART NO.	DESCRIPTION



<p>WE MAKE GUARANTEES AND OTHER STATEMENTS AND AS THESE STATEMENTS ARE IN THESE SECTIONS:</p> <p>DATE: 11 JUL 1950</p> <p>ENGINEER: ONCEFD</p> <p>APPROVED:</p>	<p>ACOREX Aerotherm</p> <p>495 CLAYTON AVE., MOUNTAIN VIEW, CALIF.</p> <p>FACILITY VENT LOCATIONS</p> <p>MARK III CONTAINMENT MODEL</p> <p>REV. C 50726 7104-1030</p>
---	---



ITEM NO.	QTY.	UNITS	QTY.

HOW H₂ COMBUSTION IS VISUALIZED

- PYREX TRANSMITTANCE
- - - CAMERA ACCEPTANCE
- H₂O EMISSIVITY









VENT & SPARGER
LOCATIONS

ROLL-OUT OF 1/20th SCALE DRYWELL





PLAN VIEW




PHASE II

ELEVATION VIEW




"FULL SCALE (IN PLANT) DIMENSIONS (FT)
SHOWN"

PLAN VIEW






PHASE III

ELEVATION VIEW



"FULL SCALE (IN PLANT) DIMENSIONS (FT)
SHOWN"



" FULL SCALE (IN PLANT) DIMENSIONS (FT)
SHOWN "

TESTS PERFORMED

- PHASE II
 - PHASE III
 - PHASE IV
-
- NOTE PHASE I WAS FACILITY SHAKEDOWN

1/20th Scale Phase II Test Matrix

Test #	Total H ₂ Flow (Full Scale) lbr/sec	Pool Temp °F	Gas Temp °F	Pool Water Level	H ₂ Release Locations	Insul.	40° Floor
II-1	1.0	185	140	UPD*	8 ADS + 312°	No	In
II-2	2.0	↓	↓	↓	↓	↓	↓
II-3	1.0	125	90	↓	↓	↓	↓
II-4	2.0	↓	↓	↓	↓	↓	↓
II-5	1.0	↓	↓	↓	9SPGRS + VENTS	↓	↓
II-6	2.0	↓	↓	↓	↓	Yes	↓
II-7	1.0	↓	↓	↓	8 ADS + 312°	↓	↓
II-8	2.0	↓	↓	↓	↓	↓	↓
II-9	1.0	185	140	↓	↓	↓	↓
II-10	2.0	↓	↓	↓	↓	↓	↓
II-11	1.0	↓	↓	↓	↓	↓	↓
II-12	2.0	↓	↓	↓	↓	↓	↓
II-13	1.0	125	90	↓	↓	↓	↓
II-14	2.0	↓	↓	↓	↓	↓	↓
II-15	1.0	↓	↓	↓	↓	No	Out
II-16	2.0	↓	↓	↓	↓	↓	↓
II-17	1.0	↓	↓	↓	728° SPGR ONLY	↓	↓
II-18	2.0	↓	↓	↓	↓	↓	↓
II-19	0.8	185	140	↓	8 ADS + 312°	↓	In
II-21	0.8	125	90	↓	↓	↓	↓
II-22	0.6	↓	↓	↓	↓	↓	↓
II-23	0.4	↓	↓	↓	↓	↓	↓
II-24	0.6	185	140	↓	↓	↓	↓

*UPD = Upper Pool Dump Water Level

**No. II-20 Data Recorded.

1/20th Scale Phase III Test Matrix

Test:	Total H ₂ Flow (Full Scale) lbm/sec	Pool Temp °F	Gas Temp °F	Pool Water Level	H ₂ Release Locations	Heat Flux Meas.	Insul.	40° Floor
III-1	0.8	185	140	UPD*	8 ADS + 312°	Total	No	In
III-2	2.0	↓	↓	↓	↓	↓	↓	↓
III-3	0.8							
III-4	2.0							
III-5	0.8							
III-6	2.0							
III-7	0.8							
III-8	2.0							
III-9	0.8							
III-10	1.0							
III-11	1.0							
III-12	0.8							
III-13	1.0							

* UPD = Upper Pool Dump Water Level

** NWL = Normal Operation Water Level.

1/20th Scale Phase IV Test Matrix

Test	Total H ₂ Flow (Full Scale) lbm/sec	Pool Temp °F	Gas Temp °F	Pool Water Level	H ₂ Release Locations	Heat Flux Meas.	Insul.	40 ^o Floor
IV-1	0.8	185	140	UPD *	8 ADS + 312 ^o	Total	No	In
IV-2	↓	↓	↓	↓	↓	↓	↓	↓
IV-3	↓	↓	↓	↓	↓	↓	↓	↓
IV-4	↓	↓	↓	NWL **	↓	↓	↓	↓


*UPD - Upper Pool Dump Water Level.

**NWL - Normal Operation Water Level.


SUMMARY OF RESULTS

- STEADY DIFFUSION FLAMES ESTABLISHED ABOVE POOL FOR TOTAL H₂ INJECTION RATES GREATER THAN 0.4 LBM/SEC (FULL SCALE)
- BURNING CHARACTERIZED BY THE FOLLOWING SEQUENCE
 - H₂ INJECTION BEGINS (ADS + 312° (SORV) SPARGERS)
 - WEAK UPWARD FLAME PROPAGATION FROM LOWEST IGNITERS
 - ALMOST IMMEDIATELY A FAST DOWNWARD PROPAGATION TO POOL (MINIMAL PRESSURIZATION <.1 PSIG)
 - IMMEDIATE ESTABLISHMENT OF STEADY FLAMES ANCHORED ABOVE SPARGERS (PRIMARY BURNING)
 - STRONG HORIZONTAL AIR FLOWS ABOVE POOL ESTABLISHED QUICKLY
 - DIRECTION OF FLOWS DEPENDENT ON ANNULAR FLOW BLOCKAGE
 - BURNING MOST INTENSE IN 312° CHIMNEY (GRAND GULF CONFIG.)
 - AS O₂ IS DEPLETED FLAMES WEAKEN, GROW TALLER AND EVENTUALLY MOVE UPWARD AND ANCHOR ON HCU FLOOR GRATING (312° CHIMNEY ONLY) (SECONDARY BURNING)
 - ALL BURNING TERMINATES

JH 6/83



HEAT FLUXES OBSERVED
AT HCU FLOOR (AT $\frac{1}{20}$ SCALE)
VS H_2 RELEASE RATE
(PRIMARY BURNING)



TOTAL H_2 RELEASE RATE g/sec (F.S.)

EFFECTS OF VARIATIONS IN PARAMETERS
ON PEAK GAS TEMP (T_G) JUST BELOW HCU FLOOR

- TOTAL H_2 FLOW RATE (\dot{Q})
 - INCREASING \dot{Q} FROM 0.8 LBM/SEC - 1.0 LBM/SEC INCREASED $T_G \sim 200^\circ F$
 - INCREASING \dot{Q} FROM 0.8 LBM/SEC - 2.0 LBM/SEC INCREASED $T_G \sim 450^\circ F$

- NUMBER OF ACTIVE SPARGERS
 - DELETION OF ADJACENT SPARGER (9 TO 8 SPARGERS) DECREASES T_G (EFFECT MORE PRONOUNCED AT HIGH H_2 FLOW RATE)
 - T_G DECREASED $\sim 100^\circ F$ FOR 0.8 LBM/SEC TESTS
 - T_G DECREASED $\sim 350^\circ F$ FOR 2.0 LBM/SEC TESTS
 - RELEASE OF ALL H_2 THROUGH A SINGLE SPARGER INCREASED $T_G \sim 400^\circ F$ (RELATIVE TO 9 TOTAL (2 ADJACENT) CASE)

JH 6/83

EFFECTS OF VARIATIONS IN PARAMETERS
ON PEAK GAS TEMPERATURE JUST BELOW
HCU FLOOR (CONT'D)

- .50-.50 SPLIT BETWEEN LOCA VENTS AND SPARGER FLOW
 - DECREASED $T_G \sim 100^\circ\text{F}$ IN HOTTEST CHIMNEY
 - T_G IN OTHER CHIMNEYS MAY INCREASE SLIGHTLY

- POOL WATER LEVEL
 - LOWERING POOL WATER LEVEL FROM UPPER POOL DUMP LEVEL TO NWL:
 - HAD NO EFFECT IN REGION DIRECTLY ABOVE SPARGER
 - LOWERED $T_G \sim 50^\circ$ NEAR CENTER OF HCU FLOOR

J. HOSLER 6/83

EFFECTS OF VARIATIONS IN PARAMETERS
ON PEAK GAS TEMPERATURE JUST BELOW --
HCU FLOOR (CONT'D)

- INSULATING PYREX OUTER SHELL OF FACILITY
 - NO RESOLVABLE EFFECT

- REMOVAL OF SOLID FLOOR IN WETWELL ANNULUS AT 40° AZIMUTH
 - $T_{G(\text{MAX})}$ LIKELY UNAFFECTED (FLAMES SHIFTED AWAY FROM INSTRUMENTATION)
 - OVERALL GAS CIRCULATION PATTERNS MODIFIED (FLAMES LEAN RIGHT RATHER THAN LEFT; SOME "UP" CHIMNEY'S BECAUSE "DOWN" CHIMNEY AND VICE-A-VERSA).

J.HOSLER 6/83

SUMMARY

- 41 TESTS PERFORMED IN A 1/20TH SCALE MODEL OF A MARK III CONTAINMENT
 - OBJECTIVES:
 - OVERALL H₂ COMBUSTION PHENOMENA UNDERSTANDING
 - COMBUSTION VISUALIZATION
 - ASSESSMENT OF THERMAL ENVIRONMENT IN WETWELL RESULTING FROM DIFFUSION FLAMES
 - SCOPE
 - ASSESS EFFECTS OF VARIATIONS IN
 - H₂ FLOW RATE
 - NO. OF ACTIVE SPARGERS
 - VENT VS. SPARGER FLOW
 - POOL WATER LEVEL
 - POOL TEMPERATURE
 - HEAT LOSS FROM OUTER SHELL CONTAINMENT
 - FLOW BLOCKAGE IN WETWELL ANNULUS
- FROUDE SCALING LAWS APPLIED

SUMMARY (CONT'D)

● RESULTS

- PHENOMENA CHARACTERIZED BY STEADY FLAMES BASED AT POOL SURFACE FOR H₂ RATES ABOVE 0.4 LBM/SEC FULL SCALE

- FLAMES LIFT TO HCU FLOOR LEVEL LATE IN BURN
(O₂ ~ 6%)

● FOR BASE CASE ($\dot{Q} = 0.8$ LBM/SEC, 8 ADS +
312° SPRAGER, 185° POOL)

● PEAK GAS TEMP JUST BELOW HCU FLOOR
GENERALLY RANGED FROM 560 TO 700°F (ONE TEST
SHOWED TEMP AS HIGH AS 836°F)

● OBSERVED HEAT FLUX TO HCU FLOOR FROM
BELOW:

TOTAL ~ 4K BTU/HR FT²
CONVECTIVE ~ 3.2K BTU/HR FT²

● THERMAL ENVIRONMENT INFLUENCED MOST BY
H₂ RELEASE RATE AND NUMBER OF RELEASE
LOCATIONS

J. HOSLER
6/83