

50-352
50-353

PHILADELPHIA ELECTRIC COMPANY

2301 MARKET STREET

P.O. BOX 8699

PHILADELPHIA, PA. 19101

(215) 841-4502

JOHN S. KEMPER
VICE-PRESIDENT
ENGINEERING AND RESEARCH

SEP 24 1984

Mr. A. Schwencer, Chief
Licensing Branch No. 2
Division of Licensing
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

SUBJECT: Limerick Generating Station, Units 1 & 2
Additional Information for Auxiliary Systems
Branch Regarding SER Open Issue #2 (Tornado
Missile Effects on Ultimate Heat Sink)

- REFERENCE:
- 1) Letter J. S. Kemper to A. Schwencer,
dated 9/4/84 with Attachment dated
August, 1984
 - 2) Letter J. S. Kemper to A. Schwencer,
dated 9/11/84 with Attachment dated
September, 1984
 - 3) Telecon 9/21/84, R. Martin to J. T. Robb

Dear Mr. Schwencer:

This letter confirms the information clarifying the reference 1
and 2 responses provided in the reference 3 telecon.

The cooling tower failure speeds were determined by evaluation of
the tower assuming steady winds over the entire tower.

The Weibull distribution parameters in the reference 2 response
were estimated by fitting the 78 mph and 102 mph points from
NUS-4507. These correspond to frequency of 1×10^{-2} and 5×10^{-4}
respectively.

Very truly yours,

V. S. Boyer
for JSK

8409260243 840924
PDR ADOCK 05000352
E PDR

ARD/dg/09218402

Boyl
1/0

See Attached Service List

cc: Judge Lawrence Brenner
Judge Peter A. Morris
Judge Richard F. Cole
Judge Christine N. Kohl
Judge Gary J. Edles
Judge Reginald L. Gotchy
Troy B. Conner, Jr., Esq.
Ann P. Hodgdon, Esq.
Mr. Frank R. Romano
Mr. Robert L. Anthony
Ms. Maureen Mulligan
Charles W. Elliot, Esq.
Zori G. Ferkin, Esq.
Mr. Thomas Gerusky
Director, Penna. Emergency Management Agency
Angus R. Love, Esq.
David Wersan, Esq.
Robert J. Sugarman, Esq.
Martha W. Bush, Esq.
Spence W. Perry, Esq.
Jay M. Gutierrez, Esq.
Atomic Safety & Licensing Appeal Board
Atomic Safety & Licensing Board Panel
Docket & Service Section
Mr. James Wiggins
Mr. Timothy R. S. Campbell