

OFFSITE DOSE CALCULATION MANUAL

GRAND GULF NUCLEAR STATION

8409260264 840914  
PDR ADOCK 05000416  
R PDR

Revision No. 4

Date: July 30, 1984

GRAND GULF NUCLEAR STATION  
OFFSITE DOSE CALCULATION MANUAL  
SAFETY RELATED

---

EVALUATION APPLICABILITY

---

SAFETY EVALUATION

- APPLICABLE  
 NOT APPLICABLE

ENVIRONMENTAL EVALUATION

- APPLICABLE  
 NOT APPLICABLE
- 

Reviewed/Approved: [Signature] | 7-30-84  
Supervisor, Environmental Services Date

Reviewed/Approved: James E. Wallace Jr | 7/30/84  
Supervisor, Radiological Services Date

Reviewed/Approved: [Signature] | 7/30/84  
Manager, Radiological & Environmental Services Date

Reviewed/Approved: [Signature] | 7/30/84  
Vice President, Nuclear Support Date


Reviewed/Approved: C. H. Hutchinson | 7/31/84  
Chairman, Plant Safety Review Committee Date

ODCM  
LIST OF EFFECTIVE PAGES

	<u>PAGE NO.</u>	<u>REV. NO.</u>	<u>PAGE NO.</u>	<u>REV. NO.</u>	
4	i	4	2.0-22	1	
	ii	2	2.0-23	2	
	iii	2	2.0-24	2	
	iv	2	2.0-25	0	
	v	1	2.0-26	3	
	vi	2	2.0-27	3	
4	vii	4	2.0-28	3	
			2.0-29	3	
	1.0-1	0	2.0-30	3	
	1.0-2	2	2.0-31	0	
	1.0-3	2	2.0-32	0	
	1.0-4	1	2.0-33	0	
	1.0-5	0	2.0-34	0	
	1.0-6	1	2.0-35	4	4
	1.0-7	1			
	1.0-8	0	3.0-1	1	
	1.0-9	2	3.0-2	4	4
	1.0-10	0	3.0-3	3	
	1.0-11	0	3.0-3a	4	4
	1.0-12	0	3.0-3b	3	
	1.0-13	2	3.0-4	3	
	1.0-14	1	3.0-5	3	
4	1.0-15	4	3.0-6	3	
			3.0-6a	3	
	2.0-1	3	3.0-6b	3	
	2.0-2	3	3.0-6c	3	
	2.0-3	2	3.0-7	3	
	2.0-4	3	3.0-8	1	
	2.0-5	3	3.0-9	3	
	2.0-6	0	3.0-10	2	
	2.0-7	2			
	2.0-8	2			
	2.0-9	2			
	2.0-10	2			
	2.0-11	1			
	2.0-12	1			
	2.0-13	2			
	2.0-14	1			
	2.0-15	2			
	2.0-16	2			
	2.0-17	1			
	2.0-18	2			
	2.0-19	1			
	2.0-20	1			
	2.0-21	2			

### 1.3 Liquid Radwaste Treatment System

The essential components of the liquid radwaste treatment system are indicated below by an asterisk (\*).



#### NOTES

- The essential components outlined above are those necessary to collect, process and sample liquid radwaste prior to discharge to the environment.
- Only one of the following is required in order to process liquid waste.
  - Equipment drain filter
  - Floor drain filter
  - Equipment drain demineralizer
  - Floor drain demineralizer
- One of the Waste Surge Tanks may be used to replace the Floor Drain Waste Collection Tank.


(A COMMON SYSTEM SCALED TO A PER UNIT BASIS)

## 2.5 GASEOUS RADWASTE TREATMENT SYSTEM

The instruments required to be checked by RETS 3/4.11.2.4 to ensure that the GASEOUS RADWASTE TREATMENT (OFFGAS) SYSTEM is functioning are:

1. Absorber train bypass switch (IN64-HS-M611)
2. Bypass valve indication (IN64-F045)

When the absorber train bypass switch is in the TREAT position and the bypass valve indicates closed, the GASEOUS RADWASTE TREATMENT (OFFGAS) SYSTEM is functioning.



### NOTE

The charcoal beds may be bypassed provided the limits of Technical Specification 3.11.2.1 are not exceeded. The charcoal beds will be used as much as possible to ensure releases are as low as reasonably achievable.

ODCM  
TABLE 3.0-1  
AIR SAMPLER COLLECTION SITES

AIR SAMPLERS

<u>NUMBER</u>	<u>FIGURE</u>	<u>LOCATION</u>	
* AS-1 PG	3.0-3	Southeast of GGNS at the Port Gibson City Barn. (Sector G Radius 5.5 miles)	
AS-2 61N	3.0-2	North Northeast of GGNS, on Hwy 61 South across from the Yokena Church. (Sector B Radius 13 miles)	
* AS-3 61 VA	3.0-2	North Northeast of GGNS on Hwy 61 south at the Vicksburg Airport. (Sector E Radius 18 miles)	
AS-4 GJOE	3.0-1	Southwest of GGNS. Glodjo property on Waterloo Road. (Sector L Radius .9 miles)	4
AS-5 TC	3.0-1	South of GGNS behind MP&L training center building. (Sector J Radius .4 miles)	
* AS-6 PS	3.0-1	Northeast of GGNS, South of Grand Gulf Road. (Sector C Radius .8 miles)	4
* AS-7 MT	3.0-1	North of GGNS, located next to the Meteorolo- gical Tower. (Sector A Radius .8 miles)	
* AS-8 WR	3.0-1	East of GGNS, located at Maggie Jackson's trailer on Waterloo Road near the Eastern Site Boundary. (Sector E Radius .5 miles)	4
AS-9 GGMP	3.0-1	North of GGNS, located in Grand Gulf Military Park. (Sector A Radius 1.5 miles)	4
AS-10 NLT	3.0-3	West Northwest of GGNS, located at Newellton, Louisiana. (Sector P Radius 12.5 miles)	
AS-11 STJ	3.0-3	West Southwest of GGNS, located at St. Joseph, Louisiana. (Sector M Radius 13.0 miles)	

\* Technical Specification requirements

From Grand Gulf Nuclear Station's Annual Radiological Environmental  
Operating Report.

ODCM  
TABLE 3.0-2 (CONTINUED)  
 Page 2 of 3

SURFACE WATER

	<u>Figure</u>	
Upstream *	3.0-4	4500 ft. upstream of the GGNS outfall to allow adequate mixing of the Mississippi and Big Black Rivers. (Sector Q)
Downstream *	3.0-4	5000 ft. downstream of GGNS outfall, near the most southern radial well. (Sector N)
Discharge Basin *	3.0-4	West of GGNS, 0.5 miles, Sector P

VEGETATION

Broad Leaf Vegetation*	3.0-4	South of GGNS near the training center (Sector J, 0.4 miles) and North Northwest of GGNS near the Meteorological Tower (Sector R, 0.8 miles)	4
		Alcorn State University Southwest of GGNS (Sector K, 10.5 miles)	4

FISH SAMPLES

Commercially or recreationally important species *	3.0-4	Downstream of the discharge point in the Mississippi River	4
	3.0-4	Upstream of Discharge Point uninfluenced by Plant Operations.	

\* Technical Specification requirements  
 From Grand Gulf Nuclear Station's Annual Radiological Environmental Operating Report.

OFFSITE DOSE CALCULATION MANUAL

GRAND GULF NUCLEAR STATION

MARKUP



Revision No. 84

Date 8/84

GRAND GULF NUCLEAR STATION  
OFFSITE DOSE CALCULATION MANUAL  
SAFETY RELATED

EVALUATION APPLICABILITY	
<u>SAFETY EVALUATION</u>	<u>ENVIRONMENTAL EVALUATION</u>
<input type="checkbox"/> APPLICABLE	<input type="checkbox"/> APPLICABLE
<input checked="" type="checkbox"/> NOT APPLICABLE	<input checked="" type="checkbox"/> NOT APPLICABLE

Reviewed/Approved: [Signature] 4/10/84  
Supervisor, of Environmental Services/Date

Reviewed/Approved: [Signature] 4/10/84  
Supervisor, of Radiological Services/Date

Reviewed/Approved: [Signature] 4/10/84  
Manager, of Radiological & Environmental Services/Date

Reviewed/Approved: [Signature] 4/16/84  
Manager of Nuclear Services/Date

Reviewed/Approved: [Signature] 4/29/84  
Chairman, Plant Safety Review Committee/Date

→  
Vice President, Nuclear Support

ODCM  
LIST OF EFFECTIVE PAGES

	<u>PAGE NO.</u>	<u>REV. NO.</u>	<u>PAGE NO.</u>	<u>REV. NO.</u>	
481	i	34	2.0-22	1	
	ii	2	2.0-23	2	
	iii	2	2.0-24	2	
	iv	2	2.0-25	0	
	v	1	2.0-26	3	
	vi	2	2.0-27	3	
481	vii	34	2.0-28	3	 8
	1.0-1	0	2.0-29	3	
	1.0-2	2	2.0-30	3	
	1.0-3	2	2.0-31	0	
	1.0-4	1	2.0-32	0	
	1.0-5	0	2.0-33	0	
	1.0-6	1	2.0-34	0	
	1.0-7	1	2.0-35	34	134
	1.0-8	0	3.0-1	1	
	1.0-9	2	3.0-2	34	4
	1.0-10	0	3.0-3	3	
	1.0-11	0	3.0-3a	34	4
	1.0-12	0	3.0-3b	3	
	1.0-13	2	3.0-4	3	
	1.0-14	1	3.0-5	3	 3
41	1.0-15	24	3.0-6	3	
			3.0-6a	3	
29	2.0-1	3	3.0-6b	3	
	2.0-2	3	3.0-6c	3	
	2.0-3	2	3.0-7	3	
39	2.0-4	3	3.0-8	1	
	2.0-5	3	3.0-9	3	 13
	2.0-6	0	3.0-10	2	
	2.0-7	2			
	2.0-8	2			
	2.0-9	2			
	2.0-10	2			
	2.0-11	1			
	2.0-12	1			
	2.0-13	2			
	2.0-14	1			
	2.0-15	2			
	2.0-16	2			
	2.0-17	1			
	2.0-18	2			
	2.0-19	1			
	2.0-20	1			
	2.0-21	2			


vii



2.5 GASEOUS RADWASTE TREATMENT SYSTEM

Insert A →

~~The essential components of the GASEOUS RADWASTE TREATMENT (OFFGAS) SYSTEM for the OPERABILITY requirement of RETS Specification 3/4.11.2.4 are indicated below by an asterisk (\*).~~



NOTES →

- 1. ~~The essential components included above are those necessary to process gaseous radwaste prior to discharge to the environment.~~
- 2. ~~The charcoal beds may be bypassed provided the limits of Technical Specification 3.11.2.1 are not exceeded. The charcoal beds will be used as much as possible to ensure releases are as low as reasonably achievable.~~

Insert A to Section 2.5  
Gaseous Radwaste Treatment System  
Page 2.0-35

The instruments required to be checked by RETS 3/4.11.2.4 to ensure that the GASEOUS RADWASTE TREATMENT (OFFGAS) SYSTEM is functioning are:

1. Absorber train bypass switch (IN64-HS-M611)
2. Bypass valve indication (IN64-F045)

When the absorber train bypass switch is in the TREAT position and the bypass valve indicates closed, the GASEOUS RADWASTE TREATMENT (OFFGAS) SYSTEM is functioning.

(DDM)  
TABLE 3.0-1  
AIR SAMPLER COLLECTION SITES

AIR SAMPLERS

<u>NUMBER</u>	<u>FIGURE</u>	<u>LOCATION</u>	
* AS-1 PG	3.0-3	Southeast of GGNS at the Port Gibson City Barn. (Sector G Radius 5.5 miles)	3
AS-2 61N	3.0-2	North Northeast of GGNS, on Hwy 61 South across from the Yokena Church. (Sector B Radius 13 miles)	3
* AS-3 61 VA	3.0-2	North Northeast of GGNS on Hwy 61 south at the Vicksburg Airport. (Sector B Radius 18 miles)	
<del>AS-4</del> GJOE	3.0-1	Southwest of GGNS. Glodjo property on Waterloo Road. (Sector L Radius .9 miles)	
AS-5 TC	3.0-1	South of GGNS behind MP&L training center building. (Sector J Radius .4 miles)	3
* AS-6 RS	3.0-1	Northeast of GGNS, South of Grand Gulf Road. (Sector C Radius .8 miles)	
* AS-7 MT	3.0-1	North of GGNS, located next to the Meteorolo- gical Tower. (Sector A Radius .8 miles)	3
* AS-8 WR	3.0-1	East of GGNS, located at Maggie Jackson's trailer on Waterloo Road near the Eastern Site Boundary. (Sector E Radius .5 miles)	
<del>AS-9</del> GGMP	3.0-1	North of GGNS, located in Grand Gulf Military Park. (Sector A Radius 1.5 miles)	3
AS-10 NLT	3.0-3	West Northwest of GGNS, located at Newellton, Louisiana. (Sector P Radius 12.5 miles)	
AS-11 STJ	3.0-3	West Southwest of GGNS, located at St. Joseph, Louisiana. (Sector M Radius 13.0 miles)	
* Technical Specification requirements			
From Grand Gulf Nuclear Station's Annual Radiological Environmental Operating Report.			

ODCM  
TABLE 3.0-2 (CONTINUED)  
 Page 2 of 3

SURFACE WATER

	<u>figure</u>		
Upstream *	3.0-4	4500 ft. upstream of the GGNS outfall to allow adequate mixing of the Mississippi and Big Black Rivers. (Sector Q)	3
Downstream *	3.0-4	5000 ft. downstream of GGNS outfall, near the most southern radial well. (Sector N)	3
Discharge Basin *	3.0-4	West of GGNS, 0.5 miles, Sector P	

VEGETATION

Broad Leaf Vegetation*	3.0-4	South of GGNS <del>in the MP&amp;L garden</del> <sup>a</sup> near the training center, <del>or</del> <sup>a</sup> South Southwest in Glodje <del>garden, or areas adjacent to</del> <sup>a</sup> these gardens. (Sector J, 0.4 miles)	
------------------------	-------	---	--

→ and North Northwest of GGNS near the Meteorological Tower (Sector R, 0.8 miles)

~~Lake Claiborne Willis garden~~<sup>a</sup>  
~~(Sector E, 3.0 miles)~~<sup>a</sup>  
~~Nelson Truck Farm (Sector E, 4.5~~<sup>a</sup>  
~~miles)~~<sup>a</sup>  
 Alcorn State University South-  
 west of GGNS (Sector K, 10.5  
 miles)

FISH SAMPLES

<del>Catfish</del> <sup>a</sup>	3.0-4	Downstream of the discharge point in the Mississippi River	
{		Commercially or recreationally important species	
	3.0-4	Upstream of Discharge Point uninfluenced by Plant Operations.	

\* Technical Specification requirements From Grand Gulf Nuclear Station's Annual Radiological Environmental Operating Report.