

UNIT 2 SCRAM NO. 02-84-04
ACTION ITEMS OF 07/30/84

ACTION ITEM NO.
2-84-04-33

DESCRIPTION:

Review of Labeling Blackout Instrumentation.

<u>ACTION:</u>	<u>RESPONSIBLE GROUP</u>	<u>PRIORITY</u>	<u>STATUS</u>
1. Evaluate advisability of Labeling Blackout Instrumentation	Tech	2	

8409240347 840913
PDR 7.DOCK 05000388
S PDR

IE22
1/1

UNIT 2 SCRAM NO. 02-84-04
ACTION ITEMS OF 07/30/84

ACTION ITEM NO.
2-84-04-34

DESCRIPTION:

Staffing

<u>ACTION:</u>	<u>RESPONSIBLE GROUP</u>	<u>PRIORITY</u>	<u>STATUS</u>
1. Given the type of event, was our Operating Staffing adequate? (2 Units worst case)	Ops	3	

UNIT 2 SCRAM NO. 02-84-04
ACTION ITEMS OF 07/30/84

ACTION ITEM NO.
2-84-04-35

DESCRIPTION:

Procedure Review: 480V, 4KV & 13.8KV, 250VDC, 125VDC,
and Diesel Generator cubicles.

<u>ACTION:</u>	<u>RESPONSIBLE GROUP</u>	<u>PRIORITY</u>	<u>STATUS</u>
1. Review for adequacy SM's, PM's, OP's, and SO's that enter 480V, 4KV, 13.8KV L.C., 250VDC, 125VDC, and Diesel Generator cubicles.	Ops	3	
2. Review for adequate control, PM's that enter 480V, 4KV, 13.8KV L.C., 250VDC, 125VDC, and Diesel Generator cubicles.	Maint	3	
3. Review for adequate control, ST's that enter 480V, 4KV, 13.8KV L.C., 250VDC, 125VDC, and Diesel Generator cubicles.	S&T	3	

UNIT 2 SCRAM NO. 02-84-04
ACTION ITEMS OF 07/30/84

ACTION ITEM NO.
2-84-04-36

DESCRIPTION:

Review of RHR and CS circuit breaker response for various combinations of Motive and Control Power availability.

- Examples: a) Closure of circuit breaker on a "dead bus".
b) Closure of circuit breaker on a "dead bus" with no control power to under voltage relays.

<u>ACTION:</u>	<u>RESPONSIBLE GROUP</u>	<u>PRIORITY</u>	<u>STATUS</u>
1. Conduct review	NPE	2	
2. Conduct training	Trng	2	

UNIT 2 SCRAM NO. 02-84-04
ACTION ITEMS OF 07/30/84

ACTION ITEM NO.
2-84-04-37

DESCRIPTION:

Recorder Pen Colors Discrepancy between Unit 1 and 2
HFE Post Accident Inst. Levels, Pressure.

<u>ACTION:</u>	<u>RESPONSIBLE GROUP</u>	<u>PRIORITY</u>	<u>STATUS</u>
1. Resolve recorder pen color differences in Control Room Recorders identified during event.	Tech	3	

UNIT 2 SCRAM NO. 02-84-04
ACTION ITEMS OF 07/30/84

ACTION ITEM NO.
2-84-04-38

DESCRIPTION:

Communications

ACTION:

1. Write radio communications procedure.
Include unit separation requirements.

RESPONSIBLE
GROUP

Ops

PRIORITY

2

STATUS

UNIT 2 SCRAM NO. 02-84-04
ACTION ITEMS OF 07/30/84

ACTION ITEM NO.
2-84-04-39

DESCRIPTION:

Pre-Test Walk-Through

<u>ACTION:</u>	<u>RESPONSIBLE GROUP</u>	<u>PRIORITY</u>	<u>STATUS</u>
1. Test Director to walk through with Operations and involved primary groups which have an active role prior to major tests.	S&T	4	

UNIT 2 SCRAM NO. 02-84-04
PRIORITY 1 ACTION ITEMS
REQUIRED FOR STARTUP

OPERATIONS AND TRAINING

<u>ITEM NO.</u>	<u>ACTION ITEM NO.</u> <u>2-84-04-</u>	
1.	05-10	Verify that there are no 480V Load Center alarms indicating open D.C. Knife Switches.
2.	09-6	Provide procedure changes to NRC for their review.
3.	10-3	Conduct training on indications available to detect loss of Control Power to 13.8KV, 4KV, and 480V LC.
4.	10-6	Revise SO or Round's Sheets to include Supv/Bkr. Control Lights to 4KV SWGR. Training to be provided prior to procedure use.
5.	12-3	Conduct Operator Training regarding Full Core Display Response to LOOP.
6.	17-1,3	Conduct Operator Training required for Startup.
7.	25-2	Perform training on Diesel Generator Trip Resets.

STARTUP AND TEST

<u>ITEM NO.</u>	<u>ACTION ITEM NO.</u> <u>2-84-04-</u>	
1.	06-3	Test the 'C' Diesel Generator ability to close in on a dead bus with under-voltage relay disabled. Have NRC review test procedure and witness test.

TECHNICAL

<u>ITEM NO.</u>	<u>ACTION ITEM NO.</u> <u>2-84-04-</u>	
1.	18-1	Conduct PORC prior to Startup (Notify NRC prior to meeting).



Pennsylvania Power & Light Company

Two North Ninth Street • Allentown, PA 18101 • 215 / 770-5151

September 13, 1984

U.S. Nuclear Regulatory Commission
Document Control Desk
Washington, DC 20555

SUSQUEHANNA STEAM ELECTRIC STATION
LICENSEE EVENT REPORT 84-013-00
ER 100450 FILE 841-23
PLA-2311

Docket No. 50-388
License No. NPF-22

Attached is an addition to Licensee Event Report 84-013-00.
These attachments were included with Licensee Event Report 84-013-00,
but failed to get transmitted.

H.W. Keiser
Superintendent of Plant-Susquehanna

RWS/pjg

Attachment

cc: Dr. Thomas E. Murley
Regional Administrator, Region I
U.S. Nuclear Regulatory Commission
631 Park Avenue
King of Prussia, PA 19406

Mr. R.H. Jacobs
Senior Resident Inspector
U.S. Nuclear Regulatory Commission
P.O. Box 52
Shickshinny, PA 18655

IE22

11