

Georgia Power Company
40 Inverness Center Parkway
Post Office Box 1295
Birmingham, Alabama 35201
Telephone 205 877-7122

C. K. McCoy
Vice President, Nuclear
Vogtle Project

October 2, 1995



Docket No. 50-424

TAC No. M92321

U. S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, D. C. 20555

VOGTLE ELECTRIC GENERATING PLANT
ADDITIONAL INFORMATION RELATIVE TO GEORGIA
POWER COMPANY REQUEST FOR EXEMPTION FROM
10 CFR 50, APPENDIX J TYPE A TEST SCHEDULE FOR UNIT 1 AND ASSOCIATED
TECHNICAL SPECIFICATIONS CHANGE

Gentlemen:

By letter LCV-0610, dated May 12, 1995, Georgia Power Company (GPC) requested an exemption from 10 CFR 50, Appendix J schedule requirements and an associated change to Technical Specification 4.6.1.2 for Vogtle Electric Generating Plant (VEGP), Unit 1. The request will allow the next Type A test, which is currently scheduled to be performed during the 1R6 refueling outage in March and April, 1996 to be rescheduled in accordance with the new criteria (Option B) of the 10 CFR 50, Appendix J. The exemption was approved by the NRC on August 29, 1995, and the associated Technical Specification change is currently being reviewed by NRC.

Georgia Power Company proposes to amend the requested Technical Specification change by the addition of a footnote to specification 4.6.1.2 .a, stating "The Type A test scheduled for VEGP Unit 1 during 1R6 will be rescheduled to the 1997 refueling outage." This change is reflected in the attached mark up of Technical Specification page 3/4 6-2 which should replace the marked up page that was contained in our letter LCV-0610. The conclusions of the significant hazards evaluation in accordance with 50.92, which was attached to LCV-0610 is unaffected by the addition of this footnote.

If additional information is required, please advise.

Sincerely,

C.K.M. S
C. K. McCoy

060039

9510060291 951002
PDR ADDCK 05000424
P PDR

AD17.1

Attachment

CKM/HWM

c(w): Georgia Power Company

Mr. J. B. Beasley, Jr.

Mr. M. Sheibani

NORMS

U. S. Nuclear Regulatory Commission

Mr. S. D. Ebnetter, Regional Administrator

Mr. L. L. Wheeler, Licensing Project Manager

Mr. C. R. Ogle, Senior Resident Inspector, Vogtle