

CONTAINMENT SYSTEMS

CONTAINMENT LEAKAGE

LIMITING CONDITION FOR OPERATION

---

3.6.1.2 Containment leakage rates shall be limited to:

- a. An overall integrated leakage rate of less than or equal to  $L_a$ , 0.20% by weight of the containment air per 24 hours at a pressure not less than  $P_a$ , 37 psig, or
- b. A combined leakage rate of less than 0.60  $L_a$  for all penetrations and valves subject to Type B and C tests, when pressurized to a pressure not less than  $P_a$ , 37 psig.

APPLICABILITY: MODES 1, 2, 3, and 4.

ACTION:

With either the measured overall integrated containment leakage rate exceeding 0.75  $L_a$  or the measured combined leakage rate for all penetrations and valves subject to Types B and C tests exceeding 0.60  $L_a$ , restore the overall integrated leakage rate to less than 0.75  $L_a$ , and the combined leakage rate for all penetrations subject to Type B and C tests to less than 0.60  $L_a$  prior to increasing the Reactor Coolant System temperature above 200°F.

SURVEILLANCE REQUIREMENTS

---

*Except as modified by NRC approved exemptions*

4.6.1.2 The containment leakage rates shall be demonstrated at the following test schedule and shall be determined in conformance with the criteria specified in Appendix J of 10 CFR Part 50 using the methods and provisions of ANSI N45.4-1972:

- a. Three Type A tests (Overall Integrated Containment Leakage Rate) shall be conducted at 40 ± 10 month intervals\* during shutdown at a pressure not less than  $P_a$ , 37 psig, during each 10-year service period. The third test of each set shall be conducted during the shutdown for the 10-year plant inservice inspection;

\* The Type A test scheduled for VEGP Unit 1 during IRG will be rescheduled to the 1997 refueling outage.

VOGTLE UNITS - 1 & 2

3/4 6-2

Amendment No. 63 (Unit 1)  
Amendment No. 42 (Unit 2)

9510060296 951002  
PDR ADOCK 05000424  
P PDR