

October 4, 1995

Mr. E. Kraft  
Site Vice President  
Quad Cities Station  
Commonwealth Edison Company  
22710 206th Avenue North  
Cordova, IL 61242

Dear Mr. Kraft:

During a recent inspection, the U.S. Nuclear Regulatory Commission was not able to ascertain whether a quality control inspector at the Quad Cities Station met the requirements of ANSI N45.2.6-1978, "Qualifications of Inspection, Examination, and Testing Personnel for Nuclear Power Plants," due to incomplete documentation associated with the inspector's certification. Details of this matter are provided for your review and followup.

We request that the results of your review and disposition of this matter be submitted to Region III within 60 days of the date of this letter. We also request that your response contain no personal privacy, proprietary, or safeguards information so it can be released to the public and placed in the NRC Public Document Room. If necessary, such information shall be contained in a separate attachment which will be withheld from public disclosure. The affidavit required by 10 CFR Part 2.790(b) must accompany your response if proprietary information is included.

The enclosure to this letter should be controlled, and distribution limited to personnel with a "need to know" until your investigation of the matter has been completed and reviewed by NRC Region III. The enclosure to this letter is considered Exempt from Public Disclosure in accordance with 10 CFR Part 2.790(a). However, a copy of this letter, excluding the enclosure, will be placed in the NRC Public Document Room.

The response requested by this letter and the accompanying enclosure are not subject to the clearance procedures of the Office of Management and Budget as required by the Paperwork Reduction Act of 1980, PL 96-511.

9510100045 951004  
PDR ADOCK 05000254  
G PDR

060037

IEO/ 1/0  
ENCLOSURE CONTAINS  
10CFR2.790 INFORMATION  
UPON SEPARATION THIS  
PAGE IS DECONTROLLED

Your cooperation with us is appreciated. We will gladly discuss any questions you have concerning this information.

Sincerely,

/s/ R. N. Gardner

Ronald N. Gardner, Chief  
Engineering Specialists Branch 2

Docket No. 50-254  
Docket No. 50-265

Enclosure: Details (Enclosure Contains  
10 CFR 2.790(a) Information)

cc w/o encl: J. C. Brons, Vice President,  
Nuclear Support  
J. S. Perry, Vice President,  
BWR Operations  
L. W. Pearce, Station Manager  
N. Chrissotimos, Regulatory  
Assurance Supervisor  
D. Farrar, Nuclear Regulatory  
Services Manager  
Richard Hubbard  
Nathan Schloss, Economist  
Office of the Attorney General  
State Liaison Officer  
Chairman, Illinois Commerce Commission  
J. R. Bull, Vice President, General &  
Transmission, MidAmerican Energy Company

Distribution w/o encl:

Docket File                   DRP                                   W. Axelson, RIII  
PUBLIC IE-01                 RIII PRR                           LPM, NRR  
OC/LFDCB                   SRIs, Quad Cities,  
DRS                             Dresden, LaSalle

ENCLOSURE CONTAINS  
10CFR2.790 INFORMATION  
UPON SEPARATION THIS  
PAGE IS DECONTROLLED

DOCUMENT NAME: G:QCALLEG.RAL

To receive a copy of this document, indicate in the box "C" = Copy w/o attach/encl "E" = Copy w/attach/encl "N" = No copy

OFFICE	RIII:DRS	<input checked="" type="checkbox"/> E	RIII:DRP	<input checked="" type="checkbox"/> N	RIII:EIG	<input checked="" type="checkbox"/> E	RIII:DRS	<input checked="" type="checkbox"/> E
NAME	Langstaff/kjc		Hiland <i>Pal</i>		BBurges <i>BB</i>		Gardner <i>RN</i>	
DATE	10/4/95 <i>AK</i>		10/4/95		10/4/95		10/04/95	

OFFICIAL RECORD COPY