

DMB

AUG 29 1984

Docket No. 50-341

The Detroit Edison Company
ATTN: Wayne H. Jens
Vice President
Nuclear Operations
6400 North Dixie Highway
Newport, MI 48166

Gentlemen:

This refers to the routine safety inspection conducted by Messrs. P. M. Byron, M. E. Parker, and G. Cashett of this office on June 16 through July 31, 1984, of activities at Enrico Fermi 2 Nuclear Power Station, Unit 2, authorized by NRC Construction Permit No. CPPR-87 and to the discussion of our findings with Mr. R. Lenart at the conclusion of the inspection.

The enclosed copy of our inspection report identifies areas examined during the inspection. Within these areas, the inspection consisted of a selective examination of procedures and representative records, observations, and interviews with personnel.

During this inspection, certain of your activities appeared to be in non-compliance with NRC requirements, as specified in the enclosed Appendix. A written response is required. In addition to responding to the specific item of noncompliance it is requested that you respond to the generic issue after reviewing your nonconformance procedure and its implementation on the Duke findings and other QC findings. Based on this inspection thirty-three percent of the Duke sample revealed that nonconforming conditions were not identified on nonconformance reports.

In accordance with 10 CFR 2.790(a), a copy of this letter and the enclosure(s) will be placed in the NRC Public Document Room unless you notify this office, by telephone, within ten days of the date of this letter and submit written application to withhold information contained therein within thirty days of the date of this letter. Such application must be consistent with the requirements of 2.790(b)(1). If we do not hear from you in this regard within the specified periods noted above, a copy of this letter, the enclosure(s), and your response to this letter will be placed in the Public Document Room.

8409260528 840829
PDR ADOCK 05000341
Q PDR

IECI 11

AUG 29 1984

The responses directed by this letter (and the accompanying Notice) are not subject to the clearance procedures of the Office of Management and Budget as required by the Paperwork Reduction Act of 1980, PL 96-511.

We will gladly discuss any questions you have concerning this inspection.

Sincerely,

"Original signed by R. F. Warnick"

R. F. Warnick, Chief
Projects Branch 1

Enclosures:

- 1. Appendix, Notice of Violation
- 2. Inspection Report No. 50-341/84-19(DRP)

cc w/encls:

- L. P. Bregni, Licensing Engineer
- P. A. Marquardt, Corporate Legal Department
- DMB/Document Control Desk (RIDS)
- Resident Inspector, RIII
- Ronald Callen, Michigan Public Service Commission
- Harry H. Voigt, Esq.

RIII

McCormick-Barger/db
08/23/84

JMB
8/24

RIII

Knop
RCK
8/28/84

RIII

RFW
Warnick
8/29/84