

300 Madison Avenue
Toledo, OH 43652-0001
419-249-2300

John P. Stetz
Vice President - Nuclear
Davis-Besse

Docket Number 50-346

License Number NPF-3

Serial Number 2313

September 29, 1995

United States Nuclear Regulatory Commission
Document Control Desk
Washington, DC 20555

Subject: License Amendment Application to Revise Technical Specifications
Regarding Reactivity Control Systems, Emergency Core Cooling
Systems, and Refueling Operations

Ladies and Gentlemen:

Enclosed is an application for an amendment to the Davis-Besse Nuclear Power Station (DNPS), Unit Number 1 Operating License Number NPF-3, Appendix A, Technical Specifications, to reflect the changes attached. The proposed changes involve Technical Specification (TS) 3/4.1.2.8, Reactivity Control Systems - Borated Water Sources - Shutdown, TS 3/4.1.2.9, Reactivity Control Systems - Operating, TS 3/4.5.1, Emergency Core Cooling Systems (ECCS) - Core Flooding Tanks, TS 3/4.5.2, Emergency Core Cooling Systems - ECCS Subsystems - Tavg >280°F, TS 3/4.5.4, ECCS - Borated Water Storage Tank, TS 3/4.9.1, Refueling Operations - Boron Concentration, and associated TS Bases.

The proposed changes would increase the minimum available borated water volume requirement for the Boric Acid Addition System (BAAS), the minimum and maximum boron concentration requirements for the Borated Water Storage Tank (BWST), and the minimum boron concentration requirement for the Core Flooding Tanks (CFTs), thereby providing flexibility for longer fuel cycles, including the upcoming Cycle 11. The proposed changes would also modify the Surveillance Requirements relating to trisodium phosphate dodecahydrate (TSP), and would modify the refueling boron concentration requirements and the associated Action statement.

100110

Operating Companies:
Cleveland Electric Illuminating
Toledo Edison

9510100109 950929
PDR ADDCK 05000346
P PDR


Adol
1/1

Docket Number 50-346
License Number NPF-3
Serial Number 2313
Page 2

Toledo Edison requests that this amendment be issued by the NRC by April 8, 1996, the currently scheduled commencement date for the Tenth Refueling Outage.

Should you have any questions or require additional information, please contact Mr. William T. O'Connor, Manager - Regulatory Affairs, at (419) 249-2366.

Very truly yours,



MKL/laj

Enclosure

cc: L. L. Gundrum, NRC/NRR Project Manager
H. J. Miller, Regional Administrator, NRC Region III
S. Stasek, NRC Region III, DB-1 Senior Resident Inspector
J. R. Williams, Chief of Staff, Ohio Emergency Management Agency,
State of Ohio (NRC Liaison)
Utility Radiological Safety Board