

300 Madison Avenue
Toledo, OH 43652-0001
419-249-2300

John P. Stetz
Vice President - Nuclear
Davis-Besse

Docket Number 50-346

License Number NPF-3

Serial Number 2323

October 2, 1995

United States Nuclear Regulatory Commission
Document Control Desk
Washington, D. C. 20555

Subject: License Amendment Application to Revise Technical Specification
Section 5.0, Design Features

Ladies and Gentlemen:

Enclosed is an application for an amendment to the Davis-Besse Nuclear Power Station (DBNPS), Unit Number 1 Operating License Number NPF-3, Appendix A, Technical Specifications. The proposed changes involve revising Technical Specification (TS) Section 5.0, Design Features, and would, for the most part, adopt the improved "Standard Technical Specifications for Babcock and Wilcox Plants" (NUREG-1430, Revision 1) format and content.

The proposed changes would add a site location description, remove site area maps, remove containment and reactor coolant system design parameters, remove the description of the meteorological tower location, remove component cyclic or transient limits, and revise the fuel assembly description to include the use of ZIRLO clad fuel rods. These revisions to TS Section 5.0 are being proposed as line item TS improvements generally consistent with the improved "Standard Technical Specifications for Babcock and Wilcox Plants" (NUREG-1430, Revision 1) and a lead plant change approved by the NRC for the Calvert Cliffs Nuclear Power, Unit 1, Operating License No. DPR-53 (Amendment 204, dated March 14, 1995, TAC No. M88429) and Unit 2, Operating License No. DPR-69 (Amendment 182, dated March 14, 1995, TAC No. M88430).

Toledo Edison requests this amendment be issued by the NRC by April 1, 1996.

100013

Operating Companies:
Cleveland Electric Illuminating
Toledo Edison


9510100174 951002
PDR ADDCK 05000346
P PDR

ADD

Docket Number 50-346
License Number NPF-3
Serial Number 2323
Page 2

Should you have any questions or require additional information, please contact Mr. William T. O'Connor, Manager - Regulatory Affairs, at (419) 249-2366.

Very truly yours,



KAS/laj

cc: L. L. Gundrum, DB-1 NRC/NRR Project Manager
H. J. Miller, Regional Administrator, NRC Region III
S. Stasek, DB-1 NRC Senior Resident Inspector
J. R. Williams, Chief of Staff, Ohio Emergency Management
Agency, State of Ohio (NRC Liaison)
Utility Radiological Safety Board