

PERRY NUCLEAR POWER PLANT

10 CENTER ROAD
PERRY, OHIO 44081
(216) 259-3737

Mail Address:
P.O. BOX 97
PERRY, OHIO 44081

Donald C. Shelton
SENIOR VICE PRESIDENT
NUCLEAR

October 5, 1995
PY-CEI/OEPA-0231L

Ohio Environmental Protection Agency
Attention: Ruth Wilburn
P.O. Box 163669
Columbus, Ohio 43216-3669

Ladies and Gentlemen:

Enclosed are the revised NPDES monthly report forms for the month of August, 1995.

If you have questions or require additional information, please contact Donna Tizzano at (216) 280-5514.

Very truly yours,

DGT:sc

Enclosure

cc: NRC Project Manager
NRC Resident Inspectors Office
NRC Document Control Desk
NRC Region III

100063

9510100387 951005
PDR ADOCK 05000440
R PDR

Operating Companies
Cleveland Electric Illuminating
Toledo Edison

JK23.1

CLEVELAND ELECTRIC ILLIUM CO 3IB00016800 AUG 95
NUCLEAR GROUP
C/O PERRY NUCLEAR POWER PLANT
10 CENTER ROAD ROOM E210
NORTH PERRY 44081 LAKE

1 1

OHIO
63461

800 INTAKE WATER AT INLET TO PLANT
FROM LAKE ERIE

FORM

CEI, PERRY

D.G. Tizzano

1
999

WATER
TEMP
F.

00011


01	76
02	77
03	76
04	76
05	77
06	77
07	68
08	63
09	66
10	69
11	70
12	75
13	76
14	76
15	77
16	78
17	74
18	71
19	71
20	73
21	76
22	76
23	76
24	76
25	75
26	75
27	75
28	69
29	73
30	74
31	75

2211
71.3
78
63

NONE


REPORTER

9-25-95



V. President

3IB00016800



NUCLEAR GROUP
C/O PERRY NUCLEAR POWER PLANT
10 CENTER ROAD ROOM E210
NORTH PERRY 44081 LAKE

001 DISCHARGE FROM REGENERATE
NEUTRALIZATION PITS

FORM

CEI. PERRY D.G. TIZZANO

1 1 1 2 3
999 999 999 96 1

CONDUI PH PH RESIDUE O&G
FLOW (MAX) (MIN) T NFLT TOTAL
MGD S.U. S.U. MG/L MG/L

	50050	00401	00402	00530	00550
01	0.0192	6.7	6.6	16	AA
02	AH	AH	AH		
03	AH	AH	AH		
04	AH	AH	AH		
05	AH	AH	AH		
06	AH	AH	AH		
07	AH	AH	AH		
08	AH	AH	AH		
09	AH	AH	AH		
10	0.0204	7.4	7.4	14	AA
11	AH	AH	AH		
12	AH	AH	AH		
13	AH	AH	AH		
14	AH	AH	AH		
15	0.0182	7.8	7.7	10	AA
16	AH	AH	AH		
17	AH	AH	AH		
18	0.0206	7.7	7.6		
19	AH	AH	AH		
20	AH	AH	AH		
21	AH	AH	AH		
22	0.0185	7.2	7.2	23	AA
23	AH	AH	AH		
24	AH	AH	AH		
25	AH	AH	AH		
26	0.0184	6.8	6.6		
27	AH	AH	AH		
28	AH	AH	AH		
29	AH	AH	AH		
30	AH	AH	AH		
31	AH	AH	AH		
	0.1153	43.6	43.1	62	AA
	0.0192	7.3	7.2	16	AA
	0.0206	7.8	7.7	23	AA
	0.0182	6.7	6.6	10	AA

AA - BELOW DETECTABLE LIMIT (5 mg/l for O&G and 2.5 mg/l for RESIDUE)
AH - SAMPLE NOT TAKEN, NO DISCHARGE PERFORMED THIS DATE

REPORTER

9-25-95

Vice President

3IB00016001



CLEVELAND ELECTRIC ILLUM CO 3IB00016004 AUG 95
NUCLEAR GROUP
C/O PERRY NUCLEAR POWER PLANT
10 CENTER ROAD ROOM E210
NORTH PERRY 44081 LAKE

1 1

OHIO
63461

004 POINT REP OF DISCHARGE PRIOR TO
ENTRY TO TUNNEL

FORM

CEI, PERRY

D.G. Tizzano

1 1 3 3
999 999 1 1

WATER CONDUI CHLOR PH
TEMP FLOW FREE A
F. MGD MG/L S.U.

00011 50050 50064 00400

01	82	93.4	0.00	8.1
02	83	97.2	0.00	
03	82	94.8	0.00	
04	83	98.1	0.00	8.1
05	83	97.8	0.00	
06	82	97.3	0.00	
07	76	93.0	0.00	
08	72	95.2	0.00	8.1
09	74	108.2	0.00	
10	76	99.8	0.00	
11	77	98.3	0.00	8.1
12	82	94.1	0.00	
13	82	93.9	0.00	
14	83	103.1	0.00	
15	84	92.6	0.00	8.1
16	84	98.2	0.00	
17	82	94.1	0.00	
18	79	90.3	0.00	8.1
19	79	94.4	0.00	
20	80	92.7	0.00	
21	82	101.8	0.00	
22	81	98.1	0.00	8.2
23	81	104.1	0.00	
24	81	104.1	0.00	
25	80	109.1	0.00	8.2
26	80	106.0	0.00	
27	80	105.3	0.00	
28	76	101.2	0.00	
29	79	102.4	0.00	8.1
30	80	102.2	0.00	
31	79	110.1	0.00	

2484 2971.2 0.00 73.1
80 95.8 0.00 8.1
84 110.1 0.00 8.2
72 90.3 0.00 8.1

NONE

REPORTER

9-25-95

Delu

V. President

3IB00016004



CLEVELAND ELECTRIC ILLUM CO 3IB00016002 AUG 95
NUCLEAR GROUP
C/O PERRY NUCLEAR POWER PLANT
10 CENTER ROAD ROOM E210
NORTH PERRY 44081 LAKE

1 1

OHIO
63461

002 DISCHARGE FROM CHEMICAL CLEANING
LAGOON E PLANT FORM

CEI. PERRY

D.G. Tizzano

1	1	2	3	2	2	2
999	999	96	1	96	96	96

CONDUIT	PH	RESIDUE	O&G	PHOS-T	COPPER	IRON
FLOW		T NFLT	TOTAL	P-WET	CU.TOT	FE.TOT
MGD	S.U.	MG/L	MG/L	MG/L	MG/L	MG/L
50050	00400	00530	00550	00665	01042	01045

01
02
03
04
05
06
07
08
09
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31

NO DISCHARGE OCCURRED DURING THE MONTH.

REPORTER

9-25-95

V. President

3IB00016002

3IB00016002

