



Log # TXX-92249
File # 827.1

TU ELECTRIC May 21, 1992

William J. Cahill, Jr.
Group Vice President

U. S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, DC 20555

SUBJECT: COMANCHE PEAK STEAM ELECTRIC STATION (CPSES)
DOCKET NOS. 50-445 AND 50-446
REQUEST FOR INFORMATION ON AMENDMENT 79 TO THE CPSES
FINAL SAFETY ANALYSIS REPORT (FSAR)

Gentlemen:

In response to the NRC's request for additional information on Amendment 79 to the CPSES FSAR, TU Electric submits the following.

Amendment 79 to the CPSES FSAR revised tables 7.1-2.3 and 7.1-2.4 "Applicability Matrix for Engineered Safety Systems" and "Applicability Matrix for Systems Required for Safe Shutdown." The change removed the applicability of General Design Criterion (GDC) 54 of 10 CFR 50 Appendix A from the Auxiliary Feedwater System Instrumentation. At the staff's request, TU Electric re-evaluated the change and determined that GDC 54 is applicable to the Auxiliary Feedwater System Instrumentation. TU Electric will submit a change in a future FSAR amendment to re-instate the GDC 54 applicability to the Auxiliary Feedwater System Instrumentation.

If you have any additional questions please contact Jose' D. Rodriguez at (214) 812-8674.

Sincerely,

William J. Cahill, Jr.

By: J. S. Marshall
J. S. Marshall
Generic Licensing Manager

JDR/grp

c - Mr. R. D. Martin, Region IV
Resident Inspectors, CPSES (2)
Mr. T. A. Bergman, NRR
Mr. B. E. Holian, NRR

9205280024 920521
PDR ADOCK 05000445
PDR

00 N. Olive Street L.B. 81 Dallas, Texas 75201

1029
1/0