



# Nebraska Public Power District

GENERAL OFFICE  
P.O. BOX 499, COLUMBUS, NEBRASKA 68602-0499  
TELEPHONE (402) 564-8561  
FAX (402) 563-5551

NSD920526  
May 19, 1992

U. S. Nuclear Regulatory Commission  
Attention: Document Control Desk  
Washington, DC 20555

Subject: Followup Response to Emergency Response Data System (ERDS)  
Cooper Nuclear Station  
NRC Docket No. 50-298, DPR-46

Reference: Letter from G. R. Horn (NPPD) to USNRC dated January 31, 1992,  
"Emergency Response Data System - Communication Description, Survey  
Questionnaire, and Data Point Library (DPL)"

Gentlemen:

The Nebraska Public Power District (the District) hereby provides a followup response for the Emergency Response Data System - Data Point Library. This response provides the information requested during a phone conversation between Mr. John Jolicoeur (NRC-ERDS Project Manager) and members of my staff on May 5, 1992, and completes the District's previous response (Reference) to the NRC for ERDS implementation.

Attached are the two revised DPL sheets requested during the phone conversation incorporating the requested range and units in which the parameters are to be monitored. This information is provided in the format requested by NUREG-1394 Revision 1.

If you have any questions concerning this subject, please contact the individuals identified in the survey questionnaire (Reference), or myself at this office.

Sincerely,

G. R. Horn  
Nuclear Power Group Manager

GRH/tja:erds.rfi  
Attachment

cc: NRC Regional Office  
Region IV  
Arlington, TX

NRC Resident Inspector  
Cooper Nuclear Station

9205280127 920519  
PDR ADDCK 05000298  
F PDR

A026

May 11, 1992

Date : 05/11/92  
Reactor Unit : CO1  
Data Feeder : N/A  
NRC ERDS Parameter : EFF LIQ RAD  
Point ID : EFF LIQ RAD  
Plant Spec Point Desc. : EFF LIQ RAD  
Generic/Cond Desc. : RADIOACTIVITY OF RELEASED LIQDS  
Analog/Digital : A  
Engr Units/Dig States : UC/CC  
Engr Units Conversion : N/A  
Minimum Instr Range : 1.00E-6  
Maximum Instr Range : 1.00E-1  
Zero Point Reference : N/A  
Reference Point Notes : N/A  
PROC or SENS : S  
Number of Sensors : 1  
How Processed : N/A  
Sensor Locations : LIQ RAD WASTE DISCHRG LINE, RAD WASTE BLDG  
Alarm/Trip Setpoints : N/A  
Cut-Off Power Level : N/A  
Turn-On Power Level : N/A  
Instrument Failure Mode : LAST VALID VALUE  
For DP Transmitters : N/A  
Level Reference Leg : N/A  
Unique System Desc : LIQUID RADWASTE DISCHARGE LINE FLOW IS 70 GPM,  
WITH THE SENSING LINE FLOW ADJUSTED TO GREATER THAN 3 GPM AT THE START OF  
EACH DISCHARGE.

May 11, 1992

Date : 05/11/92  
Reactor Unit : CO1  
Data Feeder : N/A  
NRC ERDS Parameter : STAB CLASS  
Point ID : STA<sup>2</sup> CLASS  
Plant Spec Point Desc. : AIR STABILITY CLASS AT 100M  
Generic/Cond Desc. : AIR STABILITY AT REACTOR SITE  
Analog/Digital : A  
Engr Units/Dig States : STABA  
Engr Units Conversion : N/A  
Minimum Instr Range : 1  
Maximum Instr Range : 7  
Zero Point Reference : N/A  
Reference Point Notes : N/A  
PROC or SENS : F  
Number of Sensors : 2  
How Processed : PROGRAM USING DATA POINT REFERENCE LIBRARY  
Sensor Locations : METEROLOGICAL TOWER  
Alarm/Trip Setpoints : N/A  
Cut-Off Power Level : N/A  
Turn-On Power Level : N/A  
Instrument Failure Mode : LAST VALID VALUE  
For DP Transmitters : N/A  
Level Reference Leg : N/A  
Unique System Desc : VALUES 1-7 REPRESENT STABILITY CLASSES A-G.