

OPERATING DATA REPORT

DOCKET NO. 50-336
 DATE 9/12/84
 COMPLETED BY R. Borchert
 TELEPHONE (203) 447-1791
 Ext. 4418

OPERATING STATUS

1. Unit Name: Millstone Unit 2 Notes Items 21 and 22 cumulative
 2. Reporting Period: August 1984 are weighted ave. unit
 3. Licensed Thermal Power (Mwt): 2700 operated at 2560 MW Thermal
 4. Nameplate Rating (Gross MWe): 909 prior to its uprating to
 5. Design Electrical Rating (Net MWe): 870 the current 2700 MW thermal
 6. Maximum Dependable Capacity (Gross MWe): 895 power level.
 7. Maximum Dependable Capacity (Net MWe): 864
 8. If Changes Occur in Capacity Ratings (Items Number 3 Through 7)
 Since Last Report, Give Reasons:
N/A

9. Power Level To Which Restricted, If Any (Net MWe): N/A
 10. Reasons For Restrictions, If Any:
N/A

	This Month	Yr.-to-Date	Cumulative
11. Hours In Reporting Period	744	5855	76127
12. Number Of Hours Reactor Was Critical	744	5731.9	54097.2
13. Reactor Reserve Shutdown Hours	0	0	2205.5
14. Hours Generator On-Line	744	5429.1	51611.3
15. Unit Reserve Shutdown Hours	0	0	468.2
16. Gross Thermal Energy Generated (MWH)	1995846	14000111	130311780
17. Gross Elec. Energy Generated (MWH)	630800	4505001	42311379
18. Net Electrical Energy Generated (MWH)	607738	4327011	40542712
19. Unit Service Factor	100	92.7	67.8
20. Unit Availability Factor	100	92.7	68.4
21. Unit Capacity Factor (Using MDC Net)	94.5	85.5	63.3
22. Unit Capacity Factor (Using DER Net)	93.9	84.9	62.5
23. Unit Forced Outage Rate	0	3.1	17.7

24. Shutdowns Scheduled Over Next 6 Months (Type, Date, and Duration of Each):
 Millstone Unit 2 is scheduled to shutdown in February 1985 for a 16 week refueling and maintenance outage

25. If Shut Down At End Of Report Period, Estimated Date of Startup: N/A
 26. Units In Test Status (Prior to Commercial Operation): Forecast Achieved
- | | | |
|----------------------|------------|------------|
| INITIAL CRITICALITY | <u>N/A</u> | <u>N/A</u> |
| INITIAL ELECTRICITY | <u>N/A</u> | <u>N/A</u> |
| COMMERCIAL OPERATION | <u>N/A</u> | <u>N/A</u> |

IE24
 1/1

AVERAGE DAILY UNIT POWER LEVEL

DOCKET NO. 50-336

UNIT Millstone 2

DATE 9/12/84

COMPLETED BY R. Borchert

TELEPHONE (2⁰³) 447-1791
Ext. 4418

MONTH August 1984

DAY	AVERAGE DAILY POWER LEVEL (MWe-Net)	DAY	AVERAGE DAILY POWER LEVEL (MWe-Net)
1	<u>828</u>	17	<u>824</u>
2	<u>733</u>	18	<u>824</u>
3	<u>822</u>	19	<u>822</u>
4	<u>825</u>	20	<u>822</u>
5	<u>826</u>	21	<u>822</u>
6	<u>824</u>	22	<u>821</u>
7	<u>749</u>	23	<u>820</u>
8	<u>824</u>	24	<u>821</u>
9	<u>825</u>	25	<u>821</u>
10	<u>825</u>	26	<u>820</u>
11	<u>825</u>	27	<u>819</u>
12	<u>825</u>	28	<u>819</u>
13	<u>824</u>	29	<u>817</u>
14	<u>824</u>	30	<u>815</u>
15	<u>820</u>	31	<u>814</u>
16	<u>821</u>		

INSTRUCTIONS

On this format, list the average daily unit power level in MWe-Net for each day in the reporting month. Compute to the nearest whole megawatt.

UNIT SHUTDOWNS AND POWER REDUCTIONS

DOCKET NO. 50-336
 UNIT NAME Millstone 2
 DATE 9/12/84
 COMPLETED BY R. Borchert
 TELEPHONE (203) 447-1791
Ext. 4418

REPORT MONTH August 1984

No.	Date	Type ¹	Duration (Hours)	Reason ²	Method of Shutting Down Reactor ³	Licensee Event Report #	System Code ⁴	Component Code ⁵	Cause & Corrective Action to Prevent Recurrence
8	840802	F	0	A	5	N/A	AA	ROD	While at 100% power and during CEA power supply measurement, CEA dropped into core. Power was reduced to < 70% power and CEA was recovered.

1
 F: Forced
 S: Scheduled

2
 Reason:
 A-Equipment Failure (Explain)
 B-Maintenance or Test
 C-Refueling
 D-Regulatory Restriction
 E-Operator Training & License Examination
 F-Administrative
 G-Operational Error (Explain)
 H-Other (Explain)

3
 Method:
 1-Manual
 2-Manual Scram
 3-Automatic Scram
 4-Continued from previous month
 5-Power Reduction 5 (Duration = 0)
 9-Other (Explain)

4
 Exhibit G - Instructions for Preparation of Data Entry Sheets for Licensee Event Report (LER) File (NUREG-0161)
 Exhibit 1 - Same Source

Docket No. 50-336
Date 9/12/84
Unit Name Millstone 2
Completed By R. Borchert
Telephone (203) 447-1791
Ext. 4418

CORRECTIVE MAINTENANCE SUMMARY FOR SAFETY RELATED EQUIPMENT

REPORT MONTH August 1984

DATE	SYSTEM	COMPONENT	MAINTENANCE ACTION
8/8/84	Gaseous Radwaste	2-GR-4A	Replaced valve.
8/20/84	RPS	RPS Channels "B" and "D"	Replaced Bi-stable power supplies.
8/21/84	Diesel Generator	"A" Diesel Generator	Replaced bearing.
8/31/84	RPS	RPS Channels "A", "B", "C" and "D".	Repair linear power amplifiers.

Docket No. 50-336
Date: 9/12/84
Completed By: R. Borchert
Telephone: (203) 447-1791
Ext. 4418

REFUELING INFORMATION REQUEST

1. Name of facility: Millstone 2
2. Scheduled date for next refueling shutdown: Next refueling is in February 1985.
3. Schedule date for restart following refueling: June 1985
4. Will refueling or resumption of operation thereafter require a technical specification change or other license amendment?

Currently under evaluation due to the impact of failed fuel.

5. Scheduled date(s) for submitting licensing action and supporting information:

4th quarter of 1984.

6. Important licensing considerations associated with refueling, e.g., new or different fuel design or supplier, unreviewed design or performance analysis methods, significant changes in fuel design, new operating procedures:

Discharge of failed fuel will impact reload analysis.

7. The number of fuel assemblies (a) in the core and (b) in the spent fuel storage pool:

(a) In Core: 217 (b) 376

8. The present licensed spent fuel pool storage capacity and the size of any increase in licensed storage capacity that has been requested or is planned, in number of fuel assemblies:

Currently 667

Plans are being formulated to rack the spent fuel pool.

9. The projected date of the last refueling that can be discharged to the spent fuel pool assuming the present licensed capacity:

1985, Spent Fuel Pool, Full core off load capacity is reached.

1987, Core Full, Spent Fuel Pool contains 648 bundles.

OPERATING DATA REPORT

DOCKET NO. 50-336
 DATE 9/12/84
 COMPLETED BY R. Borchert
 TELEPHONE (203) 447-1791
 EXT. 4418

OPERATING STATUS

- | | |
|---|--|
| <ol style="list-style-type: none"> 1. Unit Name: <u>Millstone Unit 2</u> 2. Reporting Period: <u>July 1984 (Revised)</u> 3. Licensed Thermal Power (Mwt): <u>2700</u> 4. Nameplate Rating (Gross MWe): <u>909</u> 5. Design Electrical Rating (Net MWe): <u>870</u> 6. Maximum Dependable Capacity (Gross MWe): <u>895</u> 7. Maximum Dependable Capacity (Net MWe): <u>864</u> 8. If Changes Occur in Capacity Ratings (Items Number 3 Through 7) Since Last Report, Give Reasons:
N/A | Notes Items 21 and 22 cumulative are weighted averages. Unit 2 operated at 2560 MW thermal prior to its uprating to the current 2700 MW Thermal power level. |
|---|--|

-
9. Power Level To Which Restricted, If Any (Net MWe): N/A
 10. Reasons For Restrictions, If Any:
N/A
-

	This Month	Yr.-to-Date	Cumulative
11. Hours In Reporting Period	744	5111	75383
12. Number Of Hours Reactor Was Critical	744	4987.9	53353.2
13. Reactor Reserve Shutdown Hours	0	0	2205.5
14. Hours Generator On-Line	744	4685.1	50867.3
15. Unit Reserve Shutdown Hours	0	0	468.2
16. Gross Thermal Energy Generated (MWH)	1903852	12004265	128315934
17. Gross Elec. Energy Generated (MWH)	604700	3874201	41680579
18. Net Electrical Energy Generated (MWH)	581715	3719273	39934974
19. Unit Service Factor	100	91.7	67.5
20. Unit Availability Factor	100	91.7	68.1
21. Unit Capacity Factor (Using MDC Net)	90.5	84.2	63.0
22. Unit Capacity Factor (Using DER Net)	89.9	83.6	62.1
23. Unit Forced Outage Rate	0	3.6	17.9
24. Shutdowns Scheduled Over Next 6 Months (Type, Date, and Duration of Each): N/A			

-
25. If Shut Down At End Of Report Period, Estimated Date of Startup: N/A
 26. Units In Test Status (Prior to Commercial Operation):
- | | | |
|----------------------|----------|----------|
| | Forecast | Achieved |
| INITIAL CRITICALITY | N/A | N/A |
| INITIAL ELECTRICITY | N/A | N/A |
| COMMERCIAL OPERATION | N/A | N/A |

UNIT SHUTDOWNS AND POWER REDUCTIONS

DOCKET NO. 50-336

UNIT NAME MILLSTONE 2

DATE 9/12/84

COMPLETED BY R. Borchert

TELEPHONE (203) 447-1791

EXT. 4418

REPORT MONTH JULY 1984 (Revised)

No.	Date	Type ¹	Duration (Hours)	Reason ²	Method of Shutting Down Reactor ³	Licensee Event Report #	System Code ⁴	Component Code ⁵	Cause & Corrective Action to Prevent Recurrence
7	840703	F	0	A	5	N/A	AA	ROD	While at 100% power and during CEA power supply voltage measurement, CEA dropped into core. Power was reduced to < 70% power and CEA recovered.

NORTHEAST UTILITIES



THE CONNECTICUT LIGHT AND POWER COMPANY
WESTERN MASSACHUSETTS ELECTRIC COMPANY
HOLYOKE WATER POWER COMPANY
NORTHEAST UTILITIES SERVICE COMPANY
NORTHEAST NUCLEAR ENERGY COMPANY

General Offices • Selden Street, Berlin, Connecticut

P.O. BOX 270
HARTFORD, CONNECTICUT 06141-0270
(203) 666-6911

September 12, 1984
MP-6331

Director Office of Management Information and Program Control
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Reference: Facility Operating License No. DPR-65
Docket No. 50-336

Dear Sir:

This letter is forwarded to provide the report of operating and shutdown experience relating to Millstone Unit 2 Monthly Operating Report 84-8 in accordance with Appendix A Technical Specifications, Section 6.9.1.3. One additional copy of the report is enclosed. Also attached are revisions for July 1984.

Very truly yours,

NORTHEAST NUCLEAR ENERGY COMPANY

A handwritten signature in cursive script, appearing to read 'E. J. Mroczka'.

E. J. Mroczka
Station Superintendent
Millstone Nuclear Power Station

EJM/RB:ejz

cc: Director, Office of Inspection and Enforcement, Region I

Director, Office of Inspection and Enforcement, Washington, D. C. (10)
U. S. Nuclear Regulatory Commission, c/o Document Management Branch,
Washington, D.C. 20555

IE24

'/1