

WOLF CREEK
NUCLEAR OPERATING CORPORATION

John A. Bailey
Vice President
Operations

May 26, 1992

NO 92-0156


U. S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Mail Station P1-137
Washington, D. C. 20555

Subject: Docket No. 50-482: Special Report 92-001

Gentlemen:

The attached Special Report is being submitted in accordance with Technical Specification 4.8.1.1.3 concerning an invalid failure of Emergency Diesel Generator "A".

Very truly yours,



John A. Bailey
Vice President
Operations

JAB/aem

cc: A. T. Howell (NRC), w/a
R. D. Martin (NRC), w/a
G. A. Pick (NRC), w/a
W. D. Reckley (NRC), w/a

9205290281 920526
PDR ADOCK 05000482
PDR

920051

P.O. Box 411 / Burlington, KS 66839 / Phone: (316) 364-8831

An Equal Opportunity Employer M/F/H/VET

IE22
41

SPECIAL REPORT 92-001

Invalid Failure of Emergency Diesel Generator "A"

This report describes an invalid failure of Emergency Diesel Generator (EDG) "A" which occurred on April 23, 1992. This report is being submitted in accordance with Technical Specifications 4.8.1.1.3 and 6.9.2.

DESCRIPTION OF EVENTS

On April 22, 1992, at 0300 CDT, EDG "A" was taken out of service for maintenance. Following completion of maintenance activities on April 23, 1992, surveillance procedure STS KJ-005A, "Manual/Auto Start, Synchronization, and Loading of Emergency Diesel Generation NE01", was commenced to prove operability of EDG "A" prior to placing it back in service. The EDG was started at 2216 CDT and at 2225 CDT the operator closed the EDG output breaker and began to apply load. Pursuant to surveillance procedure STS KJ-005A, the EDG was immediately loaded to 0.2 Megawatts (MW), as indicated in the Control Room, by operating the governor speed control switch. Shortly after the EDG output breaker tripped on reverse power. It was then decided that the EDG should be loaded to 0.5 MW instead of 0.2 MW to ensure that the EDG output breaker would remain closed. The operator reset and reclosed the output breaker and applied a load of 0.5 MW. The output breaker remained closed with the additional load.

The EDG was operated at full load for one hour and the surveillance procedure was successfully completed. Following completion of the surveillance procedure, EDG "A" was declared operable at 0340 CDT on April 24, 1992. This event had no effect on the reliability or availability of the EDG.

ROOT CAUSE AND CORRECTIVE ACTIONS

An investigation following the event determined that the MW meter used in the Control Room to load the EDG was reading 0.2 MW with the EDG idle and in standby. Loading the EDG to an indicated 0.2 MW would actually result in a real power level of approximately zero. This would result in the output breaker opening on reverse power. This function protects the generator from motoring when connected to an energized bus.

The MW meters for EDGs "A" and "B" have been rezeroed to ensure that the proper load is added to the EDGs. Also, a work request was initiated to examine an apparent drift when the EDG was loaded. The operator noted that the EDG load appeared to drift downward prior to the EDG output breaker tripping on reverse power. The governor for EDG "A" was determined to be functioning properly. Surveillance procedures STS KJ-005A and STS KJ-005B have been revised to require the operator to immediately load the EDG to approximately 0.5 MW instead of 0.2 MW.

FAILURE CLASSIFICATION

The EDG output breaker reverse power trip function is not required and does not operate in the emergency operating mode. Therefore, the unsuccessful load attempt discussed in this report is considered to be an invalid test and failure in accordance with Regulatory Position C.2.e(2) of Regulatory Guide 1.108, Revision 1. It does not affect the current surveillance test interval of 31 days as required by Table 4.8-1 of Technical Specification 3.8.1.1. Through April 23, 1992, there have been three valid and three invalid failures of EDG "A" in the last 100 valid tests. From the time of the last valid failure of EDG "A" on December 11, 1987, EDG "A" has undergone 77 successful valid tests. The last invalid failure of EDG "A" occurred on November 21, 1991.