



September 24, 1984
L-84-257

Office of Nuclear Reactor Regulation
Attention: Mr. S. A. Varga, Chief
Operating Reactors Branch #1
Division of Operating Reactors
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Dear Mr. Varga:

Re: Turkey Point Units 3 and 4
Docket Nos. 50-250 and 50-251
Vent/Purge Valve Operability

By your letter dated August 17, 1984, you requested schedular information on the Turkey Point 54 and 48 inch containment purge valves. In response to this request, the following information is provided:

1. The bolts in the operators for the 54 inch valves (see L-84-86, April 2, 1984), for Unit 3 are scheduled to be replaced during the next refueling outage (Spring '85). They have been replaced for Unit 4.
- 2.-3. In order to allow for thorough internal review and approval, we intend to submit the containment purge valve related, proposed technical specifications, by January 2, 1985. The interim operation limit of 200 hours per year is being re-evaluated in light of the resolution of the operability concerns. The installation schedule for the purge valve debris screens is dependent on the technical specification, and will be submitted with the technical specification.

If you have any further questions, please contact us.

Very truly yours,

A handwritten signature in dark ink, appearing to read "J. Williams, Jr.", written in a cursive style.

J. W. Williams, Jr.
Group Vice President
Nuclear Energy

JWW/SAV/js

cc: J. P. O'Reilly, Region II
Harold F. Reis, Esquire
PNS-LI-84-334

8409280029 840924
PDR ADOCK 05000250
P PDR

A034
1/0