

September 25, 1985

PRELIMINARY NOTIFICATION OF EVENT OR UNUSUAL OCCURRENCE PNO-II-84-62

This preliminary notification constitutes EARLY notice of events of POSSIBLE safety or public interest significance. The information is as initially received without verification or evaluation, and is basically all that is known by the Region II staff on this date.

FACILITY: Tennessee Valley Authority
Sequoyah Unit 1
Docket No. 50-327
Soddy-Daisy, Tennessee

Licensee Emergency Classification:
 Notification of Unusual Event
 Alert
 Site Area Emergency
 General Emergency
 X Not Applicable

SUBJECT: SHUTDOWN GREATER THAN 48 HOURS

Unit 1 was shut down at 8:30 p.m. (EDT) on September 22 to correct a problem with a leaking feedwater drain valve and to investigate a small steam leak in the manway on the secondary side of steam generator No. 1.

The licensee reports no release to the environment associated with this event.

The Unit is expected to remain out of service until September 29.

Media interest is not anticipated. Neither the licensee nor the NRC plans to issue a news release.

The State of Tennessee has been informed.

This PN is being issued for information purposes only. Region II plans routine followup.

Region II (Atlanta) received initial notification of this event by telephone from the Resident Inspector at 10:30 a.m. (EDT) on September 24.

This information is current as of 11:00 a.m. (EDT) on September 25.

Contact: P. Frederickson, 242-4668

D. Verrelli, 242-5526

DISTRIBUTION:

H. Street	MNBB	Phillips	E/W	Willste	MAIL:
Chairman Palladino	EDO	NRRT 1.75	IE	NMSS	ADM:DMB
Comm. Roberts	PA		OIA	RES	DOT: Trans Only
Comm. Asselstine	MPA		AEOD		Applicable State
Comm. Bernthal	ELD				
Comm. Zech	Air Rights	INPO 1.25			
SECY	SP	NSAC			
ACRS					
CA					
PDR					

Regions:
Licensee: 1.18
(Reactor Licensees)
Applicable Resident Site 1.20

8409280035 840925
PDR I&E
PNO-II-84-062 PDR

o/i DMB
IE-34