

Log # TXX-92256
 File # 916 (3/4.3)
 Ref. # 10CFR50.90

TU ELECTRIC May 26, 1992

William J. Cahill, Jr.
 Group Vice President

U. S. Nuclear Regulatory Commission
 Attn: Document Control Desk
 Washington, DC 20555

SUBJECT: COMANCHE PEAK STEAM ELECTRIC STATION (CPSES)
 DOCKET NOS. 50-445 AND 50-446
 BORON DILUTION MITIGATION SYSTEM (BDMS)
 ADDITIONAL INFORMATION FOR LICENSE AMENDMENT REQUEST (LAR) 92-001

REF: 1) TU Electric letter logged TXX-92116 from William J. Cahill, Jr. to the NRC dated February 28, 1992
 2) TU Electric letter logged TXX-92169 from William J. Cahill, Jr. to the NRC dated April 6, 1992

Gentlemen:

Reference 1 requested an amendment to the CPSES Unit 1 Operating License (NPF-8) to revise the Technical Specifications as they relate to the BDMS. Reference 2 provided an "effective time period" for the amendment and compensatory actions which would be in effect during that time period.

As a result of further discussions with the NRC, TU Electric requests that the statements which refer to Unit 2 be removed from the amendment. The Technical Specification for Unit 2 will be addressed separately. A six month evaluation period following Unit 2 criticality (similar to the evaluation period for Unit 1) will be requested. In addition, prior to Unit 2 startup, TU Electric will verify that at least fifteen minutes are available from the start of a dilution event until the loss of shutdown margin.

Revised Technical Specification pages (NUREG-1399) are attached which are modified to reflect the changes discussed above. If there are further questions, please contact David Bize at (214) 812-8879.

Sincerely,

William J. Cahill, Jr.

DNB/dnb
 Attachment

010012

9206010131 920526
 PDR ADOCK 05000445
 P PDR

400 N. Olive Street L.B. 81 Dallas, Texas 75201

2024 11/11

NY-9, 56
2 of 3


Mr. R. D. Martin, Region IV
Assistant Inspectors, CPSES (2)
A. Bergman, NRR
E. Hollan, NRR

UNITED STATES OF AMERICA
NUCLEAR REGULATORY COMMISSION

In the Matter of)
)
Texas Utilities Electric Company) Docket Nos. 50-445
) and 50-446
(Comanche Peak Steam Electric)
Station, Units 1 & 2))

AFFIDAVIT


William J. Cahill, Jr. being duly sworn, hereby deposes and says that he is Group Vice President, Nuclear of TU Electric, the lead Applicant herein; that he is duly authorized to sign and file with the Nuclear Regulatory Commission this response to the Boron Dilution Mitigation System, Additional Information Related to License Amendment Request 92-001 for the captioned facility; that he is familiar with the content thereof; and that the matters set forth therein are true and correct to the best of his knowledge, information and belief.




William J. Cahill, Jr.
Group Vice President, Nuclear

STATE OF TEXAS)
)
COUNTY OF SOMERVELL)

Subscribed and sworn to before me, on this 26th day of
May, 1992.





Notary Public