

September 26, 1984  
EN 84-31A

OFFICE OF INSPECTION AND ENFORCEMENT  
NOTIFICATION OF SIGNIFICANT ENFORCEMENT ACTION

Licensee: Duke Power Company  
Docket Nos. 50-369, 50-370  
McGuire, Unit 1 and Unit 2

Subject: IMPOSITION OF CIVIL PENALTY - \$40,000

By EN 84-31 dated June 5, 1984, the Commission was notified of the intent of IE to issue a Notice of Violation and Proposed Imposition of Civil Penalty in the amount of \$40,000 to the Duke Power Company. This action was based upon the mispositioning of a Unit 2 containment spray recirculation valve and the failure to properly perform an independent verification of the valve position.

The license responded to the Notice of Violation in a letter dated July 6, 1984. After careful consideration of the licensee's response, the staff has concluded that the violation did occur as set forth in the Notice of Violation and Proposed Imposition of Civil Penalty. Accordingly, an Order Imposing Civil Monetary Penalties in the amount of Forty Thousand Dollars (\$40,000) has been issued today. Under terms of the Order, the licensee may within 30 days of the date of the Order, pay the civil penalty or request a hearing.

Contact: G. Klingler, IE 24923

J. Axelrad, IE 24909

Distribution:

H Street <u>8:20</u>	MNBB <u>8:25</u>	Phillips <u>8:26</u>	EW _____	Willste <u>8:27</u>
Chairman Palladino	EDO	NRR	IE	NMSS
Comm. Roberts	DED/ROGR		OIA	RES
Comm. Asselstine	PA		OI	
Comm. Bernthal	ELD		AEOD	
Comm. Zech	RM			
ACRS				
SECY	Air Rights <u>8:29</u>	Regional Offices	MAIL	
CA	SP	RI <u>8:30</u>	ADM: Doc. Mgt. Br.	
PE		RIV <u>8:35</u>	PJR	
		RII <u>8:31</u>		
		RV <u>8:36</u>		
		RIII <u>8:32</u>		

8409280384 840926  
PDR I&E  
EN-84-031A PDR

IE 33  
d/i